

SYDNEY CANTERBURY, Australia

WMO: 947660

Lat: 33.9058S

Lon: 151.1133E

Elev: 3

StdP: 101.29

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	4.7	-3.2	2.9	16.7	-1.8	3.3	15.0	10.1	16.4	8.5	15.3	0.7	300	0.416

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.2	33.0	20.1	30.7	20.3	28.9	20.1	23.2	28.4	22.5	27.3	21.9	26.3	5.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.7	16.4	25.2	21.1	15.7	24.7	20.4	15.1	24.1	68.9	28.5	66.2	27.5	63.8	26.3	26.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.0	8.3	7.4	DB	1.1	39.2	1.0	2.5	0.4	41.0	-0.2	42.5	-0.7	43.9	-1.4	45.7	(4)
(5)			WB	0.5	24.7	1.0	0.8	-0.2	25.2	-0.7	25.7	-1.3	26.1	-2.0	26.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.4	22.8	22.4	20.9	18.0	14.8	12.5	11.6	12.6	15.3	17.6	19.4	21.4	(6)	
	DBStd	4.56	2.69	2.47	2.24	2.23	2.10	1.84	1.70	2.02	2.66	2.92	3.03	2.81	(7)	
	HDD10.0	7	0	0	0	0	0	2	4	2	0	0	0	0	(8)	
	HDD18.3	882	1	1	4	31	111	174	209	179	97	49	21	4	(9)	
	CDD10.0	2716	396	348	339	240	149	77	53	81	161	235	282	354	(10)	
	CDD18.3	549	139	114	85	21	2	0	0	1	7	26	53	101	(11)	
	CDH23.3	3407	879	647	376	121	11	0	1	6	113	256	371	626	(12)	
(13)	CDH26.7	1012	286	172	77	22	0	0	0	0	29	86	132	208	(13)	
(14)	Wind	WSAvg	3.1	3.8	3.6	3.2	2.6	2.4	2.5	2.9	3.2	3.5	3.8	3.7	(14)	
(15) Precipitation	PrecAvg	1090	98	110	120	109	89	125	62	79	58	70	87	78	(15)	
	PrecMax	2025	400	581	393	476	388	372	250	411	248	268	396	359	(16)	
	PrecMin	523	6	7	6	8	3	2	0	1	0	0	11	5	(17)	
	PrecStd	299	80	96	89	96	77	94	50	91	49	63	75	64	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.7	35.1	31.5	29.6	24.9	21.1	22.3	24.1	30.1	32.9	34.8	35.2	(19)	
		MCWB	21.4	21.6	20.5	17.8	15.4	13.8	13.0	13.4	16.3	17.0	19.1	20.1	(20)	
	2%	DB	32.1	30.8	28.5	26.2	22.7	19.4	19.5	21.5	26.5	29.2	30.3	31.4	(21)	
		MCWB	21.3	22.1	21.1	17.9	15.6	13.3	11.8	12.7	14.8	16.7	19.1	20.1	(22)	
	5%	DB	29.5	28.4	26.8	24.5	21.1	18.2	17.9	19.7	23.8	26.0	27.2	28.8	(23)	
		MCWB	21.6	21.6	20.3	17.7	15.0	12.9	11.3	12.2	14.3	16.6	18.7	19.9	(24)	
	10%	DB	27.6	26.8	25.3	22.9	19.8	17.1	16.5	18.2	21.5	23.6	24.9	26.6	(25)	
		MCWB	20.8	21.0	19.6	17.3	14.7	12.5	11.0	11.5	14.0	16.1	18.3	19.6	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.0	24.6	23.0	20.6	19.0	16.2	15.7	15.7	18.0	20.0	22.0	23.1	(27)	
		MCDB	31.1	29.9	27.3	25.2	21.0	18.3	18.6	20.3	24.0	25.9	29.6	29.5	(28)	
	2%	WB	23.1	23.5	22.0	19.7	17.7	15.1	14.0	14.7	16.9	18.9	20.8	22.1	(29)	
		MCDB	28.8	27.8	26.1	23.5	20.0	17.4	16.3	18.5	21.9	24.3	26.5	27.5	(30)	
	5%	WB	22.3	22.7	21.3	19.0	16.6	14.3	13.0	13.6	16.1	18.0	19.9	21.2	(31)	
		MCDB	27.3	26.7	25.1	22.3	19.5	16.7	15.9	17.5	20.9	23.1	24.6	26.0	(32)	
	10%	WB	21.7	21.9	20.6	18.2	15.5	13.5	12.1	12.7	15.2	17.3	19.1	20.5	(33)	
		MCDB	26.1	25.7	24.2	21.6	18.8	16.0	15.1	16.5	19.9	21.8	23.4	25.0	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.2	7.6	8.1	9.4	10.3	9.7	10.7	11.2	11.3	10.1	8.8	8.6	(35)	
		MCDBR	12.7	11.1	11.0	12.5	12.4	11.6	13.3	14.2	16.0	15.8	14.2	13.5	(36)	
	5% WB	MCWBR	4.5	4.2	4.7	5.3	6.1	6.3	6.8	6.8	6.3	5.8	5.2	4.6	(37)	
		MCWBR	10.1	8.9	9.2	9.5	9.2	8.7	9.9	11.3	12.1	11.4	11.0	10.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.397	0.396	0.362	0.335	0.320	0.312	0.302	0.310	0.344	0.363	0.387	0.398	(40)	
		taud	2.452	2.472	2.554	2.604	2.596	2.615	2.624	2.592	2.495	2.474	2.446	2.426	(41)	
	Ebn at Noon		941	920	917	889	850	832	863	903	920	942	945	943	(42)	
		Edh at Noon	120	113	97	83	74	68	70	82	101	112	120	124	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.49	5.59	4.75	3.83	3.00	2.37	2.78	3.68	4.91	5.71	6.10	6.64	(44)	
	RadStd		0.47	0.48	0.41	0.32	0.20	0.22	0.22	0.20	0.27	0.48	0.55	0.53	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(46)	
(47) Regional (33 neighbors)	+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-1	-86	+187	+98 (47)

Nomenclature: See separate page