

SYDNEY AP, Australia

WMO: 947670

Lat: 33.9464S

Lon: 151.1731E

Elev: 16

StdP: 14.69

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	44.1	45.6	25.1	19.1	64.7	28.2	22.2	61.3	32.4	58.1	29.0	58.0	9.7	330	0.529

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.4	91.9	67.0	87.6	68.1	84.1	68.3	74.1	81.8	72.8	80.1	71.8	78.8	16.2	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
71.9	118.0	76.6	70.7	113.0	75.9	69.7	109.1	75.3	37.6	82.0	36.5	80.3	35.6	79.1	79.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.6	26.5	23.9	DB	40.8	103.1	1.7	5.3	39.6	106.9	38.6	110.0	37.7	113.0	36.5	116.8	(4)
(5)			WB	36.8	76.0	1.2	1.4	36.0	77.1	35.3	77.9	34.6	78.7	33.7	79.7	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.4	74.2	73.8	71.5	66.4	61.3	57.0	55.5	57.4	62.0	65.7	68.6	71.9	(6)
(7)		DBStd	7.93	4.84	4.46	4.19	4.28	3.99	3.37	3.45	4.23	5.19	5.69	5.62	5.14	(7)
(8)		HDD50	1	0	0	0	0	0	0	1	0	0	0	0	0	(8)
(9)		HDD65	1145	0	0	3	31	128	241	295	240	120	59	23	5	(9)
(10)		CDD50	5623	751	667	667	493	349	209	172	230	360	487	558	680	(10)
(11)		CDD65	1291	286	247	204	74	13	0	1	4	30	81	131	220	(11)
(12)		CDH74	6819	1633	1290	829	276	45	1	5	35	232	554	746	1173	(12)
(13)		CDH80	1986	517	327	166	51	2	0	0	4	69	204	267	379	(13)
(14)	Wind	WSAvg	12.1	13.4	12.8	12.1	10.8	10.7	11.1	11.0	11.8	12.3	12.8	13.4	13.6	(14)
(15)	Precipitation	PrecAvg	42.9	3.9	4.3	4.7	4.3	3.5	4.9	2.4	3.1	2.3	2.8	3.4	3.1	(15)
(16)		PrecMax	79.7	15.7	22.9	15.5	18.7	15.3	14.6	9.8	16.2	9.8	10.6	15.6	14.1	(16)
(17)		PrecMin	20.6	0.2	0.3	0.2	0.3	0.1	0.1	0.0	0.0	0.0	0.0	0.4	0.2	(17)
(18)		PrecStd	11.8	3.1	3.8	3.5	3.8	3.0	3.7	2.0	3.6	1.9	2.5	3.0	2.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.4	96.4	90.0	85.5	78.5	71.7	73.6	78.1	87.6	93.3	96.4	96.5	(19)
(20)			MCWB	68.5	70.7	69.1	63.7	59.8	57.4	55.9	57.0	61.1	62.3	65.9	67.5	(20)
(21)		2%	DB	89.8	87.3	84.0	80.2	74.6	68.3	68.4	73.0	80.5	85.6	87.2	88.4	(21)
(22)			MCWB	70.9	71.6	69.6	64.0	60.2	56.6	53.8	55.0	58.8	61.6	66.3	67.6	(22)
(23)		5%	DB	84.9	83.5	80.9	76.9	71.5	66.2	65.9	69.2	75.1	79.5	81.5	83.8	(23)
(24)			MCWB	70.7	70.6	68.6	64.6	59.8	55.9	53.1	54.4	58.3	61.6	65.7	68.3	(24)
(25)		10%	DB	81.7	80.7	78.5	74.0	69.1	64.2	63.0	66.2	71.5	75.3	77.3	80.0	(25)
(26)			MCWB	69.8	69.6	67.6	63.7	59.4	55.3	52.5	53.9	57.3	61.3	65.1	67.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	75.9	75.6	73.8	69.9	66.2	62.1	60.7	61.7	64.9	68.4	71.7	73.9	(27)
(28)			MCDWB	83.9	83.3	79.9	76.7	69.9	66.8	66.9	69.5	74.3	77.4	83.2	82.8	(28)
(29)		2%	WB	74.1	74.2	72.1	68.2	64.8	60.3	58.0	59.4	63.0	66.5	69.8	72.2	(29)
(30)			MCDWB	82.6	81.0	78.2	74.4	69.7	64.2	62.6	66.7	70.8	75.0	78.6	80.1	(30)
(31)		5%	WB	72.8	72.8	71.0	66.9	63.0	59.0	56.3	57.9	61.6	65.1	68.4	70.8	(31)
(32)			MCDWB	80.5	79.4	77.1	72.8	68.3	63.0	61.2	64.9	69.5	73.3	76.4	78.3	(32)
(33)		10%	WB	71.7	71.6	69.9	65.6	61.3	57.6	54.9	56.2	60.2	63.8	67.0	69.5	(33)
(34)			MCDWB	78.6	78.2	75.8	71.6	66.7	62.1	60.3	62.9	68.2	71.6	74.4	76.6	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.4	11.5	11.7	13.5	14.3	13.8	15.2	16.2	16.2	15.3	13.4	13.1	(35)
(36)			MCDBR	19.5	16.9	16.5	18.4	18.2	17.1	19.4	21.4	24.0	24.6	22.5	21.2	(36)
(37)			MCWBR	6.7	6.0	6.8	7.9	8.6	9.1	9.5	9.8	9.8	9.5	8.0	7.3	(37)
(38)		5% WB	MCDBR	15.5	14.0	13.2	14.2	13.5	12.4	14.4	17.2	18.3	18.2	17.3	16.7	(38)
(39)			MCWBR	6.3	5.9	6.5	7.3	7.8	8.2	9.1	9.7	9.1	8.2	7.3	6.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.396	0.395	0.362	0.335	0.320	0.312	0.303	0.311	0.345	0.362	0.386	0.397	(40)	
(41)		taud	2.458	2.479	2.561	2.610	2.601	2.618	2.627	2.595	2.498	2.480	2.453	2.433	(41)	
(42)		Ebn at Noon	298	292	291	282	270	264	274	286	292	299	300	299	(42)	
(43)		Edh at Noon	38	36	31	26	23	22	22	26	32	35	38	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2066	1780	1512	1215	949	748	879	1165	1554	1812	1942	2112	(44)	
(45)		RadStd	148	151	128	101	64	70	70	61	85	148	172	163	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.95	+0.97	-1.24	+1.53	N/A	N/A	N/A	-166	+409	+230
(47) Regional (33 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	-2	-155	+337	+176

Nomenclature: See separate page