

NEWCASTLE WILLIAMTOWN, Australia

WMO: 947760

Lat: 32.7933S

Lon: 151.8358E

Elev: 8

StdP: 101.23

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	5.0	-3.8	2.7	18.2	-1.8	3.2	15.6	14.0	15.7	12.7	14.6	1.9	300	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	35.2	20.8	32.6	20.7	30.5	20.6	23.8	29.6	23.1	28.2	22.4	27.0	6.5	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.3	17.0	25.3	21.7	16.4	24.8	21.1	15.7	24.2	71.3	29.6	68.5	28.3	66.1	27.0	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.8	10.3	9.2	1.0	40.5	1.1	2.1	0.2	41.9	-0.4	43.1	-1.1	44.3	-1.8	45.8
			0.6	25.7	1.0	1.3	-0.1	26.6	-0.7	27.4	-1.3	28.2	-2.0	29.2
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	17.9	23.5	23.0	21.3	18.3	15.3	13.0	12.1	13.0	15.7	18.0	20.1	22.0	(6)
	DBStd	4.66	2.90	2.57	2.38	2.12	2.09	1.86	1.76	2.20	2.68	2.95	3.24	3.05	(7)
	HDD10.0	4	0	0	0	0	0	1	2	1	0	0	0	0	(8)
	HDD18.3	800	0	0	3	26	98	161	193	167	89	43	16	4	(9)
	CDD10.0	2886	417	364	351	248	163	91	67	93	170	247	303	371	(10)
	CDD18.3	639	159	131	96	23	3	0	0	1	9	32	69	116	(11)
	CDH23.3	4709	1226	881	493	139	17	0	1	18	144	348	567	874	(12)
(13)	CDH26.7	1717	505	297	126	26	1	0	0	2	41	131	237	351	(13)
(14)	Wind	WSAvg	4.2	4.5	4.3	4.0	3.5	3.8	4.2	4.3	4.4	4.3	4.4	4.5	(14)
(15) Precipitation	PrecAvg	1139	92	112	126	117	111	129	67	67	62	73	83	82	(15)
	PrecMax	1794	325	600	398	362	402	393	191	212	179	238	241	238	(16)
	PrecMin	541	2	6	2	4	5	15	0	1	1	1	11	14	(17)
	PrecStd	268	72	98	84	94	82	83	46	51	45	51	48	56	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	39.2	37.2	33.1	29.9	25.4	21.4	22.4	25.9	30.9	33.9	36.8	37.9	(19)
		MCWB	21.2	22.3	21.6	18.9	16.5	15.1	13.7	15.5	15.8	16.7	19.5	20.4	(20)
	2%	DB	34.9	32.6	29.7	26.6	23.1	19.6	19.8	22.8	27.3	30.4	32.4	33.5	(21)
		MCWB	22.0	22.5	21.1	18.5	16.0	13.8	12.2	13.3	15.5	17.0	19.5	20.7	(22)
	5%	DB	31.9	30.0	27.5	24.7	21.4	18.4	18.1	20.5	24.4	27.1	29.1	30.4	(23)
		MCWB	21.8	21.8	20.7	18.2	15.6	13.4	11.9	12.5	14.8	17.2	19.1	20.8	(24)
	10%	DB	29.0	27.8	25.8	23.1	20.1	17.3	16.9	18.8	21.9	24.3	26.2	27.8	(25)
		MCWB	21.6	21.5	20.3	17.7	15.1	13.1	11.6	12.2	14.4	16.7	18.9	20.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	25.0	23.8	21.2	19.3	16.8	16.3	16.8	18.6	20.7	23.0	23.9	(27)
		MCDB	32.2	31.2	28.1	24.8	21.7	18.8	19.1	22.5	23.9	26.3	30.8	30.4	(28)
	2%	WB	23.7	23.8	22.6	20.2	18.1	15.8	14.7	15.3	17.5	19.6	21.7	22.7	(29)
		MCDB	30.1	28.8	26.5	23.5	20.8	18.0	17.0	19.4	22.5	24.5	27.8	28.6	(30)
	5%	WB	23.1	23.0	21.9	19.4	17.0	15.1	13.6	14.3	16.7	18.7	20.6	21.9	(31)
		MCDB	28.4	27.3	25.5	23.0	20.2	17.1	16.1	18.2	21.2	23.4	25.7	27.1	(32)
	10%	WB	22.4	22.2	21.2	18.7	16.0	14.2	12.7	13.3	15.7	17.9	19.8	21.2	(33)
		MCDB	27.1	26.2	24.5	22.2	19.0	16.3	15.4	17.2	20.1	22.3	24.2	25.7	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	9.2	9.2	10.1	10.1	9.3	10.4	11.8	12.1	11.7	10.4	10.2	(35)
		MCDBR	16.0	13.9	12.5	13.1	12.1	10.7	12.9	15.5	17.3	17.8	16.6	15.7	(36)
	5% WB	MCWBR	5.5	5.1	5.3	6.2	6.3	6.2	7.0	7.6	7.3	7.1	6.1	5.5	(37)
		MCWBR	11.9	10.9	9.8	10.7	9.8	8.7	9.9	12.5	13.4	12.9	12.6	12.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.397	0.387	0.356	0.334	0.316	0.311	0.301	0.309	0.345	0.364	0.387	0.385	(40)
		taud	2.447	2.496	2.578	2.609	2.609	2.618	2.630	2.596	2.486	2.466	2.445	2.470	(41)
	Ebn at Noon		942	931	927	895	861	841	871	909	922	943	946	957	(42)
		Edh at Noon	120	111	96	83	74	69	71	82	103	113	120	119	(43)
(44) All-Sky Solar Radiation	RadAvg		6.61	5.82	4.89	3.92	3.08	2.47	2.87	3.80	5.00	5.75	6.19	6.65	(44)
	RadStd		0.42	0.48	0.42	0.31	0.24	0.20	0.23	0.24	0.27	0.47	0.57	0.52	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.42	+0.46	N/A	N/A	+0.39	N/A	N/A	-75	+184	+124	(46)
(47)	Regional (29 neighbors)	+0.43	N/A	N/A	+0.77	N/A	N/A	-1	-85	+190	+103	(47)

Nomenclature: See separate page