

GOSFORD, Australia

WMO: 947820

Lat: 33.4350S

Lon: 151.3614E

Elev: 23

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	36.9	39.0	29.5	23.6	60.0	31.8	26.2	55.9	20.6	57.4	16.9	60.4	0.3	350	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.6	92.4	69.9	87.9	70.1	84.4	69.8	75.5	83.9	74.1	81.7	72.8	79.9	8.8	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.3	124.0	78.2	71.9	117.9	77.0	70.7	113.0	76.0	38.9	83.6	37.6	81.9	36.5	80.3	82.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
15.8	13.3	11.4	DB	33.0	103.1	2.0	4.2	31.6	106.1	30.5	108.6	29.4	110.9	27.9	113.9
			WB	32.7	77.8	2.0	1.7	31.2	79.0	30.0	80.0	28.9	81.0	27.4	82.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	62.9	72.6	71.6	69.1	63.8	58.1	54.5	53.0	54.2	58.8	63.0	66.6	69.8	(6)
(7)		DBStd	8.14	5.00	4.53	4.25	4.09	3.87	3.49	3.41	3.60	4.61	5.43	5.68	5.13	(7)
(8)		HDD50	17	0	0	0	0	0	4	9	4	0	0	0	0	(8)
(9)		HDD65	1676	2	2	10	69	217	314	372	334	194	104	46	12	(9)
(10)		CDD50	4720	701	606	593	413	251	140	102	135	265	403	498	613	(10)
(11)		CDD65	904	238	188	138	31	3	0	0	9	42	94	161	161	(11)
(12)		CDH74	6278	1650	1160	669	207	20	0	1	15	186	470	785	1115	(12)
(13)		CDH80	2017	590	339	144	40	0	0	0	54	164	303	383	383	(13)
(14)	Wind	WSAvg	4.0	4.7	4.3	3.9	2.9	3.1	3.4	3.6	4.0	4.3	4.4	4.6	4.7	(14)
(15)	Precipitation	PrecAvg	54.4	6.0	6.1	6.6	4.9	4.6	5.4	2.3	3.1	2.6	3.7	4.4	4.3	(15)
(16)		PrecMax	83.3	18.4	26.1	15.5	24.2	12.7	14.4	7.6	11.5	8.0	12.2	15.4	11.0	(16)
(17)		PrecMin	33.1	0.4	1.1	0.3	0.2	0.5	0.0	0.0	0.2	0.1	0.1	0.6	0.4	(17)
(18)		PrecStd	14.6	4.7	5.7	4.1	4.9	3.3	4.1	1.9	3.3	2.2	3.4	3.2	3.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.6	96.4	89.3	85.1	76.9	70.5	72.6	76.1	87.1	91.6	96.3	96.2	(19)
(20)			MCWB	73.1	70.8	71.3	66.1	61.3	59.0	57.7	57.0	61.3	63.7	68.4	68.6	(20)
(21)		2%	DB	91.3	88.1	83.5	79.1	72.6	67.1	67.7	71.3	79.1	84.4	87.8	88.9	(21)
(22)			MCWB	72.0	73.5	71.4	65.7	61.0	57.5	54.3	55.7	59.6	63.4	67.9	70.2	(22)
(23)		5%	DB	86.1	83.4	80.3	75.7	69.9	64.8	64.7	67.5	74.0	78.8	82.2	83.9	(23)
(24)			MCWB	72.6	72.3	70.4	65.4	60.0	56.7	53.8	55.3	59.5	64.1	67.4	70.0	(24)
(25)		10%	DB	82.2	80.3	77.4	73.0	67.5	62.7	62.3	64.7	69.8	74.3	77.6	79.9	(25)
(26)			MCWB	71.2	70.8	68.7	64.3	58.8	55.7	53.1	53.6	58.3	62.7	66.6	68.8	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.2	78.0	75.2	70.8	66.3	62.9	61.8	62.0	65.6	70.5	74.3	75.3	(27)
(28)			MCDWB	88.2	85.7	82.6	76.6	69.9	66.7	67.1	67.5	73.1	78.1	82.1	84.9	(28)
(29)		2%	WB	75.4	75.6	73.2	68.4	64.1	60.7	58.2	59.6	63.7	67.8	71.7	73.2	(29)
(30)			MCDWB	84.2	83.5	79.6	74.3	68.9	64.1	62.7	65.6	71.4	76.2	81.3	82.5	(30)
(31)		5%	WB	74.1	73.8	71.8	67.1	62.2	59.1	56.4	57.7	62.2	66.0	69.7	71.6	(31)
(32)			MCDWB	82.0	80.5	77.8	72.8	67.4	62.3	60.9	63.7	69.3	73.2	77.9	79.9	(32)
(33)		10%	WB	72.8	72.3	70.5	65.8	60.6	57.5	54.8	55.8	60.6	64.4	68.1	70.1	(33)
(34)			MCDWB	80.0	78.4	75.9	71.1	65.6	61.1	59.8	62.2	67.5	71.4	75.4	77.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	16.6	15.8	16.1	18.1	19.4	18.0	20.0	21.9	22.2	20.5	18.5	17.3	(35)
(36)			MCDBR	26.0	22.7	20.8	23.6	22.9	21.0	24.4	27.5	30.9	30.7	29.2	25.9	(36)
(37)			MCWBR	10.0	9.7	10.0	11.6	12.5	12.5	13.4	13.8	13.9	12.9	11.6	10.3	(37)
(38)		5% WB	MCDWB	20.2	19.1	17.7	18.6	18.9	16.3	18.2	22.4	23.7	21.8	21.9	21.3	(38)
(39)	MCWBR		8.9	9.0	8.9	10.5	11.6	11.2	11.9	13.1	12.8	11.5	10.3	9.9	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.400	0.394	0.360	0.336	0.320	0.313	0.303	0.311	0.346	0.368	0.393	0.394	(40)	
(41)		taud	2.443	2.480	2.565	2.608	2.597	2.617	2.626	2.593	2.491	2.456	2.427	2.443	(41)	
(42)		Ebn at Noon	298	293	292	283	271	265	274	287	292	298	298	300	(42)	
(43)		Edh at Noon	38	36	31	26	23	22	23	26	32	36	39	39	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2043	1788	1517	1221	961	765	895	1184	1559	1796	1922	2087	(44)	
(45)		RadStd	144	151	132	103	71	68	72	68	81	149	175	169	(45)	

Historical Trends

		Heating		Cooling		Degree-Days						
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
(46)	Station Only	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(46)	
(47)	Regional (34 neighbors)	+0.81	N/A	N/A	+1.49	N/A	N/A	-4	-155	+342	+184	(47)

Nomenclature: See separate page