

GOSFORD, Australia

WMO: 947820

Lat: 33.4350S

Lon: 151.3614E

Elev: 7

StdP: 101.24

Time Zone: 10.00 (AUS)

Period: 99-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.7	3.9	-1.4	3.4	15.5	-0.1	3.7	13.3	9.2	14.1	7.5	15.8	0.1	350	0.331

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.2	33.6	21.0	31.1	21.2	29.1	21.0	24.2	28.8	23.4	27.6	22.7	26.6	3.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	17.7	25.7	22.1	16.8	25.0	21.5	16.1	24.4	72.7	28.7	69.6	27.7	66.9	26.9	27.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.1	5.9	5.1	0.6	39.5	1.1	2.3	-0.2	41.2	-0.8	42.5	-1.5	43.8	-2.3	45.5		
(5)			0.4	25.5	1.1	0.9	-0.4	26.1	-1.1	26.7	-1.7	27.2	-2.6	27.9	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	17.2	22.6	22.0	20.6	17.6	14.5	12.5	11.7	12.4	14.9	17.2	19.2	21.0
	DBStd	4.52	2.78	2.52	2.36	2.27	2.15	1.94	1.89	2.00	2.56	3.02	3.16	2.85
	HDD10.0	9	0	0	0	0	0	2	5	2	0	0	0	0
	HDD18.3	931	1	1	6	38	121	174	207	186	108	58	26	7
	CDD10.0	2622	389	337	329	229	139	78	57	75	147	224	277	341
	CDD18.3	502	132	104	77	17	2	0	0	0	5	23	52	89
	CDH23.3	3488	917	644	372	115	11	0	1	8	103	261	436	619
CDH26.7	1121	328	188	80	22	0	0	0	0	30	91	168	213	
Wind	WSAvg	1.8	2.1	1.9	1.7	1.3	1.4	1.5	1.6	1.8	1.9	2.0	2.1	2.1
Precipitation	PrecAvg	1382	152	154	167	125	116	136	59	80	66	95	112	108
	PrecMax	2117	468	664	394	614	322	366	194	293	203	310	390	279
	PrecMin	841	9	28	8	5	12	1	0	5	2	3	16	11
	PrecStd	372	120	145	104	125	85	105	47	84	56	86	81	83
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.1	35.8	31.8	29.5	24.9	21.4	22.6	24.5	30.6	33.1	35.7	35.7
		MCWB	22.8	21.6	21.8	19.0	16.3	15.0	14.3	13.9	16.3	17.6	20.2	20.3
	2%	DB	33.0	31.1	28.6	26.2	22.6	19.5	19.8	21.8	26.2	29.1	31.0	31.6
		MCWB	22.2	23.1	21.9	18.7	16.1	14.2	12.4	13.2	15.3	17.4	19.9	21.2
	5%	DB	30.0	28.6	26.8	24.3	21.1	18.2	18.2	19.7	23.3	26.0	27.9	28.8
		MCWB	22.6	22.4	21.3	18.6	15.6	13.7	12.1	12.9	15.3	17.8	19.7	21.1
	10%	DB	27.9	26.9	25.2	22.8	19.7	17.1	16.8	18.2	21.0	23.5	25.3	26.6
		MCWB	21.8	21.6	20.4	17.9	14.9	13.2	11.7	12.0	14.6	17.0	19.2	20.4
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.1	25.6	24.0	21.6	19.1	17.2	16.6	16.7	18.7	21.4	23.5	24.0
		MCDB	31.2	29.8	28.1	24.8	21.1	19.3	19.5	19.7	22.9	25.6	27.8	29.4
	2%	WB	24.1	24.2	22.9	20.2	17.8	15.9	14.6	15.3	17.6	19.9	22.0	22.9
		MCDB	29.0	28.6	26.5	23.5	20.5	17.8	17.1	18.7	21.9	24.6	27.4	28.0
	5%	WB	23.4	23.2	22.1	19.5	16.8	15.0	13.6	14.3	16.8	18.9	20.9	22.0
		MCDB	27.8	27.0	25.5	22.7	19.7	16.8	16.0	17.6	20.7	22.9	25.5	26.6
	10%	WB	22.7	22.4	21.4	18.8	15.9	14.2	12.7	13.2	15.9	18.0	20.0	21.1
		MCDB	26.7	25.8	24.4	21.7	18.7	16.2	15.4	16.8	19.7	21.9	24.1	25.1
Mean Daily Temperature Range	5% DB	MDBR	9.2	8.8	8.9	10.0	10.8	10.0	11.1	12.2	12.4	11.4	10.3	9.6
		MCDBR	14.5	12.6	11.6	13.1	12.7	11.7	13.6	15.3	17.2	17.1	16.2	14.4
		MCWBR	5.6	5.4	5.6	6.5	6.9	7.0	7.5	7.7	7.7	7.2	6.4	5.7
	5% WB	MCDBR	11.2	10.6	9.8	10.4	10.5	9.1	10.1	12.5	13.2	12.1	12.2	11.8
		MCWBR	4.9	5.0	4.9	5.8	6.4	6.2	6.6	7.3	7.1	6.4	5.7	5.5
Clear-Sky Solar Irradiance	taub	0.400	0.394	0.360	0.336	0.320	0.313	0.303	0.311	0.346	0.368	0.393	0.394	
	taud	2.443	2.480	2.565	2.608	2.597	2.617	2.626	2.593	2.491	2.456	2.427	2.443	
	Ebn at Noon	938	923	921	891	853	835	865	905	919	938	939	947	
	Edh at Noon	121	112	97	83	74	68	71	82	102	114	122	122	
All-Sky Solar Radiation	RadAvg	6.44	5.64	4.78	3.85	3.03	2.41	2.82	3.73	4.92	5.66	6.06	6.58	
	RadStd	0.45	0.47	0.41	0.32	0.22	0.21	0.23	0.21	0.26	0.47	0.55	0.53	

Historical Trends

		Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (34 neighbors)		+0.45	N/A	N/A	+0.83	N/A	N/A	-2	-86	+190	+102

Nomenclature: See separate page