

COFFS HARBOUR, Australia

WMO: 947910

Lat: 30.311S

Lon: 153.119E

Elev: 20

StdP: 14.69

Time Zone: 10.00 (AUS)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.3	41.9	28.4	22.4	58.5	31.9	26.3	57.2	24.5	62.3	22.4	61.2	4.0	310	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	86.1	72.0	83.5	72.0	81.8	71.7	75.7	81.8	74.6	80.5	73.6	79.3	14.5	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
73.7	125.6	79.3	72.7	121.3	78.5	71.6	116.7	77.5	39.3	82.0	38.2	80.8	37.2	79.3	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.8	22.3	19.9	34.9	96.4	1.6	4.7	33.7	99.7	32.8	102.5	31.9	105.2	30.7	108.6		
(5)			34.1	78.7	1.6	2.7	32.9	80.6	32.0	82.2	31.1	83.7	29.9	85.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	65.8	74.1	73.7	71.8	67.2	61.8	58.1	56.2	57.8	62.3	66.0	69.1	72.0	(6)
(7)		DBStd	7.34	3.65	3.31	3.04	3.31	4.02	3.96	4.02	4.30	4.47	4.38	4.31	3.93	(7)
(8)		HDD50	4	0	0	0	0	0	1	2	1	0	0	0	0	(8)
(9)		HDD65	992	0	0	0	14	112	208	273	229	106	40	9	1	(9)
(10)		CDD50	5767	746	664	677	516	367	244	195	241	369	495	572	681	(10)
(11)		CDD65	1282	281	244	213	80	14	1	1	5	25	70	131	217	(11)
(12)		CDH74	6263	1663	1378	924	240	36	4	7	31	132	279	518	1051	(12)
(13)		CDH80	898	255	202	93	12	1	0	0	5	27	54	98	151	(13)
(14)	Wind	WSAvg	9.5	10.7	10.1	9.5	8.7	7.8	8.3	8.1	8.8	9.3	10.6	11.0	10.8	(14)
(15)	Precipitation	PrecAvg	65.8	7.0	8.0	9.3	7.4	6.1	4.9	2.7	2.2	4.1	6.0	5.6	(15)	
(16)		PrecMax	113.5	20.2	20.6	30.8	29.6	21.1	20.9	14.8	12.0	8.9	19.5	21.5	15.6	(16)
(17)		PrecMin	42.2	0.5	2.0	0.8	0.6	0.4	0.3	0.0	0.0	0.0	0.3	0.9	1.3	(17)
(18)		PrecStd	17.2	4.6	4.6	5.8	6.2	5.0	4.3	2.9	2.9	2.0	3.8	3.7	3.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.6	88.6	85.9	81.1	77.4	73.7	74.2	77.8	84.2	86.2	89.8	88.7	(19)
(20)			MCWB	73.7	75.4	73.6	69.0	64.9	61.1	60.5	60.4	63.7	65.0	66.7	72.2	(20)
(21)		2%	DB	84.4	84.3	82.3	78.8	74.4	70.3	70.0	72.9	77.3	80.0	82.2	83.4	(21)
(22)			MCWB	73.7	73.9	72.8	68.2	63.7	60.4	58.3	59.0	63.0	66.0	69.2	71.7	(22)
(23)		5%	DB	82.4	82.3	80.4	76.8	72.0	68.2	67.6	70.0	74.0	76.6	78.8	80.8	(23)
(24)			MCWB	73.3	73.1	71.7	67.2	62.6	59.2	57.2	58.3	62.5	65.8	69.3	71.2	(24)
(25)		10%	DB	80.7	80.5	78.7	75.0	70.2	66.5	65.6	67.9	71.6	74.1	76.7	79.0	(25)
(26)			MCWB	72.2	71.9	70.4	66.1	61.5	58.0	56.1	57.4	61.5	64.8	68.1	70.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	77.7	77.2	76.1	71.9	68.3	64.8	63.9	65.0	68.4	71.1	73.1	76.2	(27)
(28)			MCD B	83.4	83.9	82.7	78.2	73.3	69.6	68.7	72.1	75.9	77.6	80.3	82.9	(28)
(29)		2%	WB	75.7	75.6	74.3	70.0	66.6	62.9	61.8	62.4	66.3	69.0	71.7	74.2	(29)
(30)			MCD B	81.4	81.9	79.9	76.1	71.7	67.7	66.7	68.7	72.8	76.0	78.6	80.4	(30)
(31)		5%	WB	74.6	74.4	72.8	68.7	64.9	61.3	59.6	60.5	64.8	67.4	70.2	72.7	(31)
(32)			MCD B	80.2	80.4	78.4	74.7	70.1	66.1	65.1	67.0	71.2	73.9	76.4	78.7	(32)
(33)		10%	WB	73.5	73.1	71.7	67.3	63.2	59.9	57.8	59.0	63.4	66.1	69.1	71.5	(33)
(34)			MCD B	79.0	78.7	77.2	73.1	68.0	64.7	63.4	65.7	69.7	72.4	75.0	77.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	12.3	12.1	12.9	14.6	16.6	16.8	18.9	19.9	18.3	15.7	13.6	13.1	(35)
(36)			MCDBR	14.5	14.6	15.1	17.3	18.6	18.3	21.6	23.3	22.0	20.1	17.0	15.7	(36)
(37)			MCWBR	7.3	6.8	7.7	8.9	10.0	10.4	12.2	12.6	11.7	10.3	8.5	8.2	(37)
(38)		5% WB	MCD BR	12.8	13.0	13.4	15.0	14.9	15.0	17.1	19.5	18.3	17.2	14.6	13.9	(38)
(39)			MCWBR	7.2	6.9	7.6	8.5	9.0	9.5	10.9	11.7	10.9	10.0	8.1	7.8	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.394	0.379	0.360	0.338	0.317	0.308	0.302	0.314	0.358	0.393	0.389	0.393	(40)	
(41)		taud	2.491	2.550	2.596	2.631	2.638	2.656	2.653	2.602	2.475	2.407	2.477	2.484	(41)	
(42)		Ebn at Noon	300	299	295	286	278	273	280	290	290	291	300	302	(42)	
(43)		Edh at Noon	37	34	30	26	23	22	23	27	34	38	37	37	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2079	1872	1572	1321	1069	889	1015	1307	1662	1862	1990	2071	(44)	
(45)		RadStd	158	149	107	80	73	57	82	87	109	162	177	177	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.56	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+254	+155
(47) Regional (13 neighbors)		+0.86	N/A	N/A	N/A	N/A	N/A	N/A	-110	+326	+166

Nomenclature: See separate page