

ALBANY, Australia

WMO: 948020

Lat: 34.941S

Lon: 117.802E

Elev: 69

StdP: 100.50

Time Zone: 8.00 (E08)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.4	5.5	1.3	4.2	12.1	2.5	4.6	10.8	11.2	14.0	10.3	14.1	2.0	0	0.540

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.0	30.1	18.8	27.4	18.4	25.3	17.9	20.4	26.1	19.5	24.5	18.8	23.1	5.8	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	13.7	21.3	18.0	13.0	20.7	17.3	12.4	20.4	58.9	26.5	56.0	24.5	53.7	23.2	24.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.3	9.3	8.5	1.8	37.4	0.6	2.5	1.4	39.2	1.0	40.6	0.7	42.0	0.2	43.8		
(5)			1.6	22.6	0.6	1.0	1.2	23.3	0.8	23.8	0.5	24.3	0.0	25.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.1	18.6	19.1	18.2	16.5	14.3	12.4	11.6	11.9	12.5	13.8	15.7	17.2		
	DBStd	3.55	2.64	2.65	2.90	2.62	2.05	1.80	1.76	1.88	2.04	2.45	2.66	2.60		
	HDD10.0	13	0	0	0	0	0	2	5	4	2	1	0	0		
	HDD18.3	1319	26	18	37	68	126	178	209	201	174	142	87	53		
	CDD10.0	1892	268	256	255	196	134	74	54	62	78	119	172	224		
	CDD18.3	155	36	40	34	13	1	0	0	0	0	3	9	19		
	CDH23.3	999	217	226	201	98	11	0	0	1	7	30	77	132		
	CDH26.7	316	67	73	73	28	1	0	0	0	1	8	24	41		
(14) Wind	WSAvg	4.4	5.0	4.9	4.5	3.8	3.7	4.1	4.2	4.3	4.4	4.3	4.6	4.7		
(15) Precipitation	PrecAvg	805	24	23	35	63	90	102	119	108	89	71	46	30		
	PrecMax	983	141	62	98	235	260	224	217	220	155	172	138	128		
	PrecMin	612	2	1	6	9	41	44	55	44	43	23	6	5		
	PrecStd	104	28	17	23	41	41	38	35	34	33	30	26	24		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	33.2	33.5	30.4	24.8	20.5	19.2	21.5	23.9	27.3	29.9	31.0		
		MCWB	20.3	19.4	18.3	16.7	15.8	14.0	13.1	13.9	15.4	15.8	17.9	18.8		
	2%	DB	28.0	28.6	28.1	26.0	22.1	18.9	17.7	19.0	20.4	22.6	25.1	26.7		
		MCWB	19.3	19.4	18.4	17.1	15.3	13.3	12.8	13.5	14.4	16.0	17.3	18.4		
	5%	DB	25.4	25.8	24.9	23.4	20.3	17.6	16.6	17.5	18.6	20.3	22.5	24.0		
		MCWB	18.4	18.5	18.1	16.8	15.0	12.9	12.4	12.7	13.6	14.9	16.4	17.4		
	10%	DB	23.4	23.7	22.7	21.3	18.9	16.4	15.5	16.0	17.0	18.5	20.5	22.0		
		MCWB	17.4	17.7	17.2	16.2	14.4	12.5	11.9	12.1	12.8	14.2	15.4	16.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.0	22.0	20.6	19.5	17.8	15.7	14.9	15.5	16.7	18.1	19.5	20.5		
		MCDB	28.0	29.4	26.3	23.8	20.9	18.6	17.1	19.1	21.4	22.7	25.8	27.3		
	2%	WB	20.2	20.2	19.6	18.6	16.6	14.6	13.8	14.3	15.0	16.7	18.0	19.1		
		MCDB	26.1	25.4	24.3	22.4	19.7	17.2	16.2	17.4	19.0	21.0	23.1	25.1		
	5%	WB	19.1	19.3	18.9	17.8	15.8	13.9	13.0	13.4	14.0	15.6	16.9	17.9		
		MCDB	24.2	23.6	22.7	21.2	18.6	16.3	15.5	16.1	17.6	19.0	21.2	22.7		
	10%	WB	18.1	18.6	18.1	17.0	15.0	13.1	12.3	12.6	13.2	14.7	16.0	17.0		
		MCDB	21.9	22.3	21.6	19.9	17.8	15.4	14.8	15.2	16.3	17.8	19.7	21.0		
(35) Mean Daily Temperature Range	5% DB	MDBR	9.1	9.0	9.1	9.4	9.1	8.1	7.7	8.2	8.7	8.9	9.1	9.0		
		MCDBR	13.4	13.3	13.4	13.3	11.9	10.2	9.6	10.8	11.9	12.6	13.1	13.3		
		MCWBR	5.6	5.3	5.2	5.8	6.1	5.8	5.7	6.0	6.5	6.6	6.2	5.9		
	5% WB	MCDBR	12.0	11.0	10.7	10.7	9.4	8.3	8.1	9.2	10.7	11.0	11.8	11.8		
		MCWBR	5.3	4.9	4.7	5.3	5.6	5.4	5.3	5.7	6.2	6.0	5.9	5.6		
(40) Clear-Sky Solar Irradiance	taub		0.343	0.347	0.332	0.320	0.306	0.305	0.301	0.308	0.330	0.333	0.336	0.338		
	taud		2.563	2.556	2.601	2.629	2.636	2.611	2.621	2.596	2.513	2.525	2.546	2.554		
	Ebn at Noon		994	967	947	903	862	833	858	902	932	971	994	1002		
	Edh at Noon		107	103	92	79	69	67	69	80	99	106	108	109		
(44) All-Sky Solar Radiation	RadAvg		7.22	6.29	5.00	3.67	2.73	2.24	2.43	3.26	4.39	5.60	6.62	7.34		
	RadStd		0.51	0.38	0.32	0.21	0.17	0.13	0.12	0.15	0.16	0.31	0.40	0.40		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	+0.43	N/A	N/A	N/A	+89	N/A
(47)	Regional (7 neighbors)	N/A	N/A	-0.53	N/A	N/A	N/A	N/A	N/A	+89	N/A

Nomenclature: See separate page