

EDITHBURGH, Australia

WMO: 948090

Lat: 35.1122S

Lon: 137.7394E

Elev: 7

StdP: 101.24

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	6.0	0.5	3.9	14.9	1.8	4.3	12.5	14.2	13.8	13.0	13.9	2.8	0	0.593

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.3	32.1	19.0	29.1	18.7	26.8	18.5	21.4	26.1	20.5	25.3	19.7	24.5	6.8	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.1	14.8	22.8	18.9	13.7	22.5	18.0	12.9	21.6	62.3	25.8	59.1	25.4	56.3	24.6	35.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.4	11.1	10.1	2.3	39.9	0.9	2.5	1.7	41.7	1.2	43.2	0.7	44.6	0.1	46.4		
(5)			1.8	25.0	0.9	4.0	1.2	27.8	0.7	30.1	0.2	32.4	-0.5	35.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	15.9	20.6	20.6	19.3	17.1	14.5	12.3	11.2	11.4	12.9	15.1	17.3	18.9		
	DBStd	4.21	3.11	2.81	2.68	2.42	2.01	1.71	1.62	1.84	2.43	3.07	3.13	3.14		
	HDD10.0	17	0	0	0	0	0	3	7	6	2	0	0	0		
	HDD18.3	1176	6	4	16	52	121	182	221	214	166	111	57	27		
	CDD10.0	2171	327	298	288	212	139	71	44	50	87	159	219	276		
	CDD18.3	288	74	68	46	15	2	0	0	0	2	11	26	44		
	CDH23.3	1626	446	334	211	63	9	0	0	2	15	88	171	287		
	CDH26.7	595	183	113	60	19	1	0	0	1	3	34	63	118		
(14) Wind	WSAvg	5.5	6.5	6.3	5.7	4.9	4.8	4.8	5.0	5.0	5.0	5.4	5.9	6.1		
(15) Precipitation	PrecAvg	392	14	15	14	30	46	51	58	51	42	32	19	18		
	PrecMax	591	83	95	50	123	101	111	99	104	116	70	84	62		
	PrecMin	265	0	0	0	1	11	10	24	14	6	3	1	2		
	PrecStd	81	16	21	14	28	22	23	22	21	23	20	17	14		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.4	34.2	32.2	29.1	24.2	18.7	18.2	21.2	25.5	31.2	32.5	35.4		
		MCWB	19.9	20.3	18.6	16.4	14.4	13.4	12.0	13.2	13.9	17.5	17.0	19.2		
	2%	DB	31.1	30.0	27.9	24.5	20.6	17.0	16.4	17.7	20.7	25.2	27.8	29.7		
		MCWB	19.5	19.4	18.9	16.4	14.9	13.2	11.9	12.6	13.5	15.3	17.7	18.2		
	5%	DB	27.7	27.1	25.5	22.3	19.0	16.0	15.2	16.0	18.5	21.8	24.5	26.1		
		MCWB	19.5	19.3	18.7	16.5	14.7	12.8	11.8	12.1	13.6	15.3	16.8	18.0		
	10%	DB	25.1	24.8	23.4	20.8	17.8	15.2	14.3	14.8	16.8	19.5	22.1	23.4		
		MCWB	19.0	19.2	18.2	16.0	14.3	12.3	11.4	11.6	13.0	14.7	16.3	17.3		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.5	23.0	22.0	19.1	17.7	15.2	14.5	15.3	16.3	19.6	20.2	21.1		
		MCDB	26.7	27.2	25.4	22.9	18.5	16.9	15.7	17.3	19.5	22.2	26.8	27.7		
	2%	WB	21.1	21.3	20.5	18.2	16.4	14.1	13.4	13.6	15.1	17.2	18.5	19.5		
		MCDB	26.3	26.0	24.6	21.7	18.5	16.0	14.8	15.9	18.4	21.8	24.2	25.4		
	5%	WB	20.2	20.4	19.5	17.4	15.5	13.5	12.6	12.8	14.2	16.0	17.6	18.6		
		MCDB	25.8	24.9	23.7	20.9	17.9	15.4	14.3	15.1	17.3	19.8	22.7	23.8		
	10%	WB	19.2	19.6	18.7	16.7	14.7	12.8	11.8	12.1	13.4	15.1	16.7	17.8		
		MCDB	24.5	24.0	22.7	20.1	17.1	14.7	13.7	14.3	16.3	18.7	21.3	22.6		
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	6.3	6.2	6.5	6.2	5.8	6.3	7.0	7.7	8.1	7.6	7.5		
		MCDBR	13.0	11.2	10.7	10.1	8.7	7.0	7.6	9.2	10.9	13.1	12.8	13.5		
		MCWBR	4.0	3.7	4.2	4.6	5.0	4.5	5.0	5.5	5.5	5.7	4.6	4.5		
	5% WB	MCDBR	10.4	8.8	8.8	8.2	7.4	6.5	7.0	8.3	9.3	10.9	10.6	10.7		
		MCWBR	4.4	3.9	4.4	4.6	5.1	4.7	5.3	5.8	5.5	5.7	4.8	4.5		
(40) Clear-Sky Solar Irradiance	taub		0.348	0.342	0.323	0.317	0.314	0.301	0.301	0.307	0.335	0.341	0.344	0.338		
	taud		2.546	2.582	2.634	2.635	2.617	2.641	2.636	2.607	2.514	2.501	2.522	2.562		
	Ebn at Noon		988	972	956	905	851	838	858	902	926	962	986	1002		
	Edh at Noon		109	101	89	79	71	65	68	80	98	108	110	108		
(44) All-Sky Solar Radiation	RadAvg		7.54	6.56	5.30	3.86	2.67	2.21	2.40	3.30	4.53	5.83	6.91	7.38		
	RadStd		0.37	0.30	0.20	0.22	0.11	0.12	0.10	0.19	0.34	0.37	0.33	0.30		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
Station Only	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
Regional (26 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70	

Nomenclature: See separate page