

SECOND VALLEY FOREST, Australia

WMO: 948110

Lat: 35.5694S

Lon: 138.2864E

Elev: 1122

StdP: 14.11

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.0	42.3	29.2	24.2	68.2	32.4	28.0	64.1	26.3	48.1	23.5	48.7	7.5	270	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.4	91.6	63.5	87.0	62.3	82.7	61.4	67.6	79.9	65.7	78.2	64.0	75.9	8.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
64.5	94.6	69.8	62.3	87.4	67.0	60.5	81.9	65.5	32.7	79.2	31.1	77.7	29.8	75.9	75.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.3	23.2	20.9	DB	38.0	98.9	1.2	3.7	37.1	101.6	36.4	103.7	35.7	105.7	34.8	108.4	(4)
(5)			WB	36.3	70.6	1.6	2.1	35.2	72.2	34.2	73.4	33.3	74.6	32.2	76.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	56.3	64.5	64.4	62.0	58.3	53.9	49.9	48.5	49.2	51.7	54.6	58.1	61.3
	DBStd	8.14	8.10	7.50	7.05	5.66	4.06	2.87	2.66	3.46	4.65	6.29	7.46	7.39
	HDD50	202	0	0	0	0	6	34	62	57	27	14	2	0
	HDD65	3513	111	96	151	216	346	452	512	490	399	333	238	169
	CDD50	2509	448	404	371	251	126	32	15	32	79	155	246	350
	CDD65	347	94	80	58	16	2	0	0	0	1	10	32	54
	CDH74	3753	1170	840	559	87	1	0	0	0	1	73	340	682
	CDH80	1510	560	344	192	16	0	0	0	0	0	10	105	283
Wind	WSAvg	10.4	13.6	12.8	11.3	9.1	8.3	8.5	8.8	9.0	9.3	10.5	11.9	12.0
Precipitation	PrecAvg	24.9	0.8	0.9	1.0	1.7	2.6	3.8	3.9	3.1	2.8	1.8	1.1	1.2
	PrecMax	37.6	2.9	3.1	3.0	4.6	4.3	6.7	7.3	5.1	8.0	4.5	2.6	4.3
	PrecMin	17.5	0.0	0.0	0.1	0.0	0.4	1.1	1.2	0.7	0.8	0.1	0.2	0.1
	PrecStd	4.9	0.6	0.8	0.7	1.1	0.9	1.3	1.5	1.3	1.5	1.2	0.7	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.9	94.8	91.6	82.2	70.8	61.0	58.5	64.5	71.9	81.1	89.0	94.7
		MCWB	64.4	65.9	63.3	60.0	55.0	53.5	51.1	53.3	56.6	59.5	62.3	62.9
	2%	DB	92.0	89.4	85.1	75.8	65.8	57.4	55.6	60.4	67.3	75.1	82.8	88.2
		MCWB	63.1	63.4	61.7	57.6	55.3	53.4	50.3	51.4	54.5	56.8	60.5	60.9
	5%	DB	86.3	84.1	80.5	71.6	62.4	55.6	53.9	57.3	63.8	70.8	77.3	81.6
		MCWB	62.9	62.9	60.6	57.0	55.1	52.3	50.0	50.4	53.5	55.4	59.1	59.8
	10%	DB	80.2	79.1	75.1	67.8	59.6	54.2	52.6	54.7	60.1	66.5	72.5	76.0
		MCWB	61.1	61.5	59.0	56.0	54.5	51.5	49.7	49.8	52.1	54.1	57.8	59.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	70.4	67.3	63.2	59.8	56.7	54.0	55.0	59.7	62.1	66.4	68.1
		MCDB	81.9	81.1	77.0	70.1	63.0	57.7	55.9	59.0	66.8	72.7	79.1	77.2
	2%	WB	67.4	67.6	65.0	61.2	58.1	54.7	52.2	53.2	56.8	59.4	63.3	64.9
		MCDB	81.8	79.7	75.9	67.9	60.9	55.8	53.4	57.2	63.4	69.5	75.9	76.3
	5%	WB	65.3	65.5	63.1	59.7	56.7	53.4	51.2	52.0	54.9	57.4	61.2	62.6
		MCDB	79.5	77.3	73.2	65.9	59.7	54.6	52.5	55.1	60.7	66.8	72.6	75.4
	10%	WB	63.2	63.5	61.3	58.2	55.5	52.2	50.3	50.7	53.1	55.6	59.2	60.7
		MCDB	76.0	74.4	70.8	64.3	58.4	53.6	51.9	53.5	58.0	63.3	69.5	73.0
Mean Daily Temperature Range	5% DB	MDBR	15.4	14.1	12.6	10.9	7.9	6.6	6.7	8.1	10.4	12.7	14.0	15.5
		MCDBR	28.0	24.7	22.4	17.6	11.2	8.0	7.8	12.2	16.9	21.3	24.3	28.0
		MCWBR	9.3	9.3	8.3	7.9	7.1	6.2	6.1	7.6	9.1	10.1	10.6	9.9
	5% WB	MCDBR	22.5	20.2	17.8	13.4	8.9	6.7	6.8	9.9	13.8	18.0	20.7	21.8
		MCWBR	9.9	9.6	8.8	8.1	7.0	5.9	6.1	7.2	8.7	10.1	11.1	10.9
Clear-Sky Solar Irradiance	taub	0.325	0.324	0.309	0.304	0.297	0.291	0.289	0.298	0.318	0.327	0.325	0.321	
	taud	2.609	2.624	2.667	2.661	2.656	2.656	2.657	2.618	2.554	2.532	2.570	2.603	
	Ebn at Noon	321	314	308	291	276	269	276	289	299	310	319	323	
	Edh at Noon	32	30	27	24	21	20	21	25	30	33	33	33	
All-Sky Solar Radiation	RadAvg	2384	2058	1663	1201	818	675	734	1021	1411	1832	2181	2346	
	RadStd	119	102	70	73	35	43	35	58	108	113	91	98	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.94	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.76	N/A	N/A	N/A	N/A	N/A	N/A	-176	+290	+126

Nomenclature: See separate page