

SECOND VALLEY FOREST, Australia

WMO: 948110

Lat: 35.5694S

Lon: 138.2864E

Elev: 342

StdP: 97.28

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	5.0	5.7	-1.6	3.5	20.1	0.2	4.0	17.8	11.7	8.9	10.5	9.3	3.4	270	0.579

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.5	33.1	17.5	30.6	16.8	28.2	16.3	19.8	26.6	18.7	25.7	17.8	24.4	3.9	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.0	13.5	21.0	16.8	12.5	19.5	15.8	11.7	18.6	58.1	26.2	54.6	25.4	51.4	24.4	23.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.8	10.4	9.4	DB	3.3	37.2	0.7	2.0	2.8	38.6	2.4	39.8	2.1	41.0	1.6	42.4	(4)
			WB	2.4	21.5	0.9	1.2	1.8	22.3	1.2	23.0	0.7	23.7	0.1	24.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	13.5	18.0	18.0	16.7	14.6	12.2	10.0	9.2	9.6	11.0	12.5	14.5	16.3	(6)
		DBStd	4.52	4.50	4.17	3.92	3.15	2.26	1.59	1.48	1.92	2.58	3.49	4.15	4.11	(7)
		HDD10.0	112	0	0	0	0	3	19	34	32	15	8	1	0	(8)
		HDD18.3	1952	62	53	84	120	192	251	284	272	222	185	132	94	(9)
		CDD10.0	1394	249	224	206	139	70	18	8	18	44	86	137	194	(10)
		CDD18.3	193	52	44	32	9	1	0	0	0	1	6	18	30	(11)
		CDH23.3	2085	650	467	311	48	1	0	0	0	1	41	189	379	(12)
(13)	Wind	CDH26.7	839	311	191	107	9	0	0	0	0	6	58	157		(13)
		WSAvg	4.7	6.1	5.7	5.0	4.1	3.7	3.8	3.9	4.0	4.2	4.7	5.3	5.3	(14)
	Precipitation	PrecAvg	633	21	24	25	43	67	97	100	80	70	46	29	31	(15)
		PrecMax	954	74	79	77	118	108	170	186	129	203	115	65	108	(16)
		PrecMin	444	1	0	2	0	11	28	31	19	21	3	4	2	(17)
		PrecStd	125	15	21	17	29	24	32	37	34	38	31	18	22	(18)
(20)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.2	34.9	33.1	27.9	21.6	16.1	14.7	18.0	22.2	27.3	31.7	34.8	(19)
			MCWB	18.0	18.8	17.4	15.6	12.8	12.0	10.6	11.9	13.7	15.3	16.8	17.2	(20)
		2%	DB	33.3	31.9	29.5	24.3	18.8	14.1	13.1	15.8	19.6	23.9	28.2	31.2	(21)
			MCWB	17.3	17.5	16.5	14.2	12.9	11.9	10.1	10.8	12.5	13.8	15.9	16.1	(22)
		5%	DB	30.2	28.9	27.0	22.0	16.9	13.1	12.2	14.0	17.7	21.5	25.2	27.6	(23)
			MCWB	17.2	17.2	15.9	13.9	12.8	11.3	10.0	10.2	12.0	13.0	15.1	15.4	(24)
		10%	DB	26.8	26.2	23.9	19.9	15.4	12.3	11.5	12.6	15.6	19.2	22.5	24.5	(25)
			MCWB	16.2	16.4	15.0	13.3	12.5	10.8	9.8	9.9	11.2	12.3	14.3	15.1	(26)
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.3	19.6	17.3	15.4	13.7	12.2	12.8	15.4	16.7	19.1	20.0	(27)
			MCDB	27.7	27.3	25.0	21.1	17.2	14.3	13.3	15.0	19.3	22.6	26.2	25.1	(28)
		2%	WB	19.7	19.8	18.4	16.2	14.5	12.6	11.2	11.8	13.8	15.2	17.4	18.3	(29)
			MCDB	27.7	26.5	24.4	19.9	16.1	13.2	11.9	14.0	17.4	20.8	24.4	24.6	(30)
		5%	WB	18.5	18.6	17.3	15.4	13.7	11.9	10.7	11.1	12.7	14.1	16.2	17.0	(31)
			MCDB	26.4	25.1	22.9	18.9	15.4	12.6	11.4	12.8	15.9	19.4	22.6	24.1	(32)
		10%	WB	17.3	17.5	16.3	14.6	13.1	11.2	10.2	10.4	11.7	13.1	15.1	15.9	(33)
			MCDB	24.4	23.6	21.6	18.0	14.7	12.0	11.0	12.0	14.5	17.4	20.8	22.8	(34)
(35)	Mean Daily Temperature Range	MDBR	8.5	7.9	7.0	6.0	4.4	3.7	3.7	4.5	5.8	7.0	7.8	8.6		(35)
		5% DB	MCDBR	15.6	13.7	12.5	9.8	6.2	4.4	4.3	6.8	9.4	11.8	13.5	15.6	(36)
			MCWBR	5.2	5.1	4.6	4.4	3.9	3.5	3.4	4.2	5.0	5.6	5.9	5.5	(37)
		5% WB	MCDBR	12.5	11.2	9.9	7.4	5.0	3.7	3.8	5.5	7.7	10.0	11.5	12.1	(38)
			MCWBR	5.5	5.3	4.9	4.5	3.9	3.3	3.4	4.0	4.9	5.6	6.2	6.0	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.325	0.324	0.309	0.304	0.297	0.291	0.289	0.298	0.318	0.327	0.325	0.321		(40)
		taud	2.609	2.624	2.667	2.661	2.656	2.656	2.657	2.618	2.554	2.532	2.570	2.603		(41)
		Ebn at Noon	1011	990	971	918	870	849	870	911	944	976	1005	1018		(42)
		Edh at Noon	102	96	86	76	67	63	66	78	94	105	105	103		(43)
(44)	All-Sky Solar Radiation	RadAvg	7.52	6.49	5.24	3.79	2.58	2.13	2.31	3.22	4.45	5.78	6.88	7.40		(44)
		RadStd	0.38	0.32	0.22	0.23	0.11	0.14	0.11	0.18	0.34	0.36	0.29	0.31		(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.52	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (24 neighbors)		+0.42	N/A	N/A	N/A	N/A	N/A	N/A	-98	+161	+70

Nomenclature: See separate page