

NARACOORTE, Australia

WMO: 948200

Lat: 36.9814S

Lon: 140.7269E

Elev: 50

StdP: 100.72

Time Zone: 9.50 (AUA)

Period: 98-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	0.6	1.9	-1.6	3.3	14.0	-0.4	3.7	11.9	12.3	12.1	11.4	12.4	1.6	160	0.602

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.9	37.0	18.7	34.5	18.2	32.1	17.5	20.6	30.2	19.6	29.6	18.7	28.6	5.8	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.2	13.2	22.7	16.7	12.0	21.3	15.5	11.1	20.6	59.7	30.1	56.1	29.3	53.0	28.9	24.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.7	10.4	9.4	-1.9	41.8	1.0	2.0	-2.6	43.2	-3.3	44.4	-3.8	45.5	-4.6	47.0		
(5)			-2.0	22.5	1.2	1.1	-2.8	23.3	-3.5	24.0	-4.2	24.6	-5.0	25.4	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.4	20.0	20.0	17.7	14.8	12.3	10.0	9.6	10.0	11.5	13.4	15.9	18.0	(6)	(7)
	DBStd	5.11	4.49	4.35	4.19	3.54	2.85	2.22	2.01	2.39	2.87	3.81	4.25	4.26	(7)	(8)
	HDD10.0	118	0	0	0	2	9	27	32	29	13	7	1	0	(8)	(9)
	HDD18.3	1735	29	28	66	119	189	249	269	258	205	163	101	58	(9)	(10)
	CDD10.0	1725	311	279	238	145	79	28	21	30	58	111	177	249	(10)	(11)
	CDD18.3	301	82	73	44	12	1	0	0	0	1	9	27	49	(11)	(12)
	CDH23.3	4703	1324	1062	652	148	8	0	0	1	11	154	470	873	(12)	(13)
	CDH26.7	2300	708	537	303	41	1	0	0	0	1	55	209	446	(13)	(14)
(14) Wind	WSAvg	4.7	5.1	5.0	4.6	4.1	4.2	4.1	4.7	4.7	4.9	4.9	4.9	5.1	(14)	(15)
(15) Precipitation	PrecAvg	577	27	17	26	40	59	67	84	76	67	48	37	29	(15)	(16)
	PrecMax	884	164	64	95	106	131	136	204	158	133	142	93	96	(16)	(17)
	PrecMin	334	3	0	1	3	7	6	28	20	15	2	8	1	(17)	(18)
	PrecStd	123	28	16	23	27	30	28	36	34	29	27	23	22	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	41.3	38.4	37.1	31.1	24.1	18.2	17.1	21.0	24.9	32.0	35.2	39.4	(19)	(20)
		MCWB	19.7	19.6	18.5	16.7	13.8	12.5	12.2	13.0	15.4	16.3	18.0	18.4	(20)	(21)
	2%	DB	37.2	35.7	33.3	27.2	20.8	16.2	15.3	18.2	21.4	27.5	32.1	35.4	(21)	(22)
		MCWB	18.8	18.6	17.7	15.5	13.6	12.0	11.4	12.2	13.7	15.2	17.0	17.5	(22)	(23)
	5%	DB	34.0	33.0	30.2	24.5	18.8	15.0	14.2	15.9	18.9	24.0	28.9	31.8	(23)	(24)
		MCWB	18.1	18.5	16.9	14.7	13.2	11.8	11.0	11.6	13.2	14.2	16.7	16.9	(24)	(25)
	10%	DB	30.6	29.9	26.7	21.8	17.0	14.0	13.3	14.4	17.0	21.2	25.4	28.3	(25)	(26)
		MCWB	17.4	17.7	16.4	14.1	13.0	11.2	10.5	10.9	12.6	13.9	15.7	16.0	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.7	22.5	20.4	17.8	16.0	14.1	13.5	14.3	16.5	18.1	20.4	20.7	(27)	(28)
		MCDB	30.2	32.4	29.0	25.3	19.2	16.0	15.3	18.6	21.8	25.6	28.9	30.1	(28)	(29)
	2%	WB	20.5	20.7	18.9	16.8	14.9	13.0	12.3	12.9	14.9	16.4	18.8	19.1	(29)	(30)
		MCDB	31.3	29.7	29.2	23.4	18.3	15.1	14.3	16.3	19.4	23.6	27.4	28.8	(30)	(31)
	5%	WB	19.4	19.5	18.0	15.9	14.1	12.2	11.6	12.1	13.8	15.4	17.6	18.0	(31)	(32)
		MCDB	30.7	28.9	26.7	21.9	17.5	14.3	13.5	15.2	17.8	22.5	25.8	28.8	(32)	(33)
	10%	WB	18.2	18.4	17.1	15.0	13.4	11.5	10.9	11.2	12.8	14.3	16.4	16.9	(33)	(34)
		MCDB	29.1	27.8	25.3	20.4	16.5	13.5	12.8	14.0	16.4	20.2	24.2	26.9	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	16.9	16.2	14.8	13.0	9.4	8.2	7.5	8.8	10.1	13.0	15.0	16.1	(35)	(36)
		MCDBR	21.9	20.1	19.3	16.4	11.6	9.1	8.1	10.6	12.9	17.8	20.1	22.4	(36)	(37)
	5% WB	MCWBR	6.9	6.7	6.8	7.0	6.1	6.1	5.5	6.4	7.1	8.3	7.7	7.6	(37)	(38)
		MCWBR	17.4	16.3	16.0	13.4	9.3	7.7	7.3	9.4	11.1	15.0	16.7	17.5	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.339	0.334	0.319	0.313	0.303	0.300	0.300	0.315	0.332	0.355	0.336	0.333	(39)	(40)
		taud	2.487	2.516	2.557	2.555	2.568	2.564	2.558	2.498	2.441	2.374	2.466	2.496	(40)	(41)
	Ebn at Noon		994	977	954	899	848	821	843	881	922	944	991	1005	(41)	(42)
		Edh at Noon	115	107	95	83	71	67	71	86	104	122	116	115	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		7.55	6.60	5.19	3.63	2.43	1.99	2.14	3.01	4.16	5.54	6.62	7.39	(43)	(44)
	RadStd		0.41	0.33	0.22	0.22	0.12	0.14	0.10	0.15	0.33	0.41	0.40	0.41	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (19 neighbors)	+0.37	N/A	N/A	N/A	N/A	N/A	N/A	-92	+132	+40

Nomenclature: See separate page