

CAPE WILLOUGHBY, Australia

WMO: 948220

Lat: 35.8425S

Lon: 138.1328E

Elev: 184

StdP: 14.60

Time Zone: 9.50 (AUA)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	46.5	47.9	35.5	30.6	54.5	37.1	32.6	54.1	47.0	58.7	41.9	56.4	16.3	290	0.694

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.5	85.6	64.0	80.6	63.0	76.6	62.8	67.8	76.8	66.4	74.1	65.1	72.3	17.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.2	93.8	70.2	63.7	88.9	69.2	62.5	85.1	68.1	32.3	77.5	31.2	74.1	30.2	72.7	73.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 38.9	33.6	29.9	43.8	96.4	1.3	4.3	42.9	99.5	42.2	102.0	41.5	104.5	40.6	107.6		
(5)			41.0	70.6	1.0	1.8	40.3	71.9	39.7	72.9	39.1	73.9	38.4	75.2		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	65.7	65.9	64.7	61.8	58.8	55.5	54.0	53.9	55.8	58.1	60.9	63.1	(6)
(7)		DBStd	5.98	5.36	4.93	4.62	3.91	3.36	2.58	2.41	2.92	3.75	4.60	5.20	5.06	(7)
(8)		HDD50	5	0	0	0	0	0	0	2	2	1	0	0	0	(8)
(9)		HDD65	2168	47	35	59	114	196	284	342	345	277	222	149	98	(9)
(10)		CDD50	3590	487	445	456	354	273	166	125	122	175	253	328	406	(10)
(11)		CDD65	278	70	60	51	17	3	0	0	0	1	10	27	39	(11)
(12)		CDH74	1534	450	318	265	37	2	0	0	0	0	50	150	262	(12)
(13)		CDH80	510	179	115	79	2	0	0	0	0	0	6	35	94	(13)
(14)	Wind	WSAvg	15.8	15.7	15.5	14.7	13.9	15.5	17.3	17.8	17.0	16.2	15.7	15.6	15.2	(14)
(15)	Precipitation	PrecAvg	22.0	0.7	0.5	0.9	1.6	2.5	3.0	3.4	3.3	2.4	1.6	1.0	0.9	(15)
(16)		PrecMax	29.7	3.7	2.2	3.5	5.0	5.2	4.8	6.8	6.1	4.3	4.8	2.6	2.7	(16)
(17)		PrecMin	15.3	0.0	0.0	0.0	0.1	0.7	1.1	1.4	0.9	0.8	0.3	0.2	0.0	(17)
(18)		PrecStd	3.7	0.8	0.5	0.8	1.2	1.0	0.9	1.3	1.3	1.0	1.1	0.6	0.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.4	90.9	88.3	78.7	72.2	64.8	62.2	65.7	71.2	79.6	84.5	90.4	(19)
(20)			MCWB	65.2	66.8	64.4	61.8	58.5	56.7	55.0	55.1	57.6	59.3	61.7	63.6	(20)
(21)		2%	DB	84.4	82.9	80.6	73.7	68.4	62.1	60.3	62.2	67.7	73.8	78.4	80.7	(21)
(22)			MCWB	64.8	65.5	63.1	60.9	58.7	55.9	53.7	53.9	56.2	57.9	60.4	62.2	(22)
(23)		5%	DB	78.3	76.7	75.7	70.2	65.7	60.5	59.0	60.2	64.7	69.3	73.3	74.7	(23)
(24)			MCWB	64.0	64.9	63.4	60.8	58.6	55.1	53.3	53.6	55.6	57.4	61.0	62.4	(24)
(25)		10%	DB	72.6	72.0	71.3	67.3	63.6	59.3	57.8	58.4	62.0	65.3	68.5	69.6	(25)
(26)			MCWB	64.7	64.7	63.0	60.3	57.9	54.4	52.8	53.0	55.0	56.9	59.9	62.0	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.5	70.2	68.3	64.7	62.3	59.1	57.4	57.3	60.1	62.8	65.7	66.9	(27)
(28)			MADB	81.1	79.9	77.3	71.4	65.7	61.6	59.8	61.2	66.0	70.6	73.9	76.9	(28)
(29)		2%	WB	67.7	67.9	66.4	63.3	60.9	57.3	55.6	55.7	58.1	60.2	63.8	64.8	(29)
(30)			MADB	77.1	76.6	73.9	69.0	64.9	60.8	58.3	59.7	63.8	68.1	72.2	73.6	(30)
(31)		5%	WB	66.1	66.4	64.8	62.2	59.5	56.2	54.5	54.6	56.8	58.7	62.1	63.4	(31)
(32)			MADB	73.9	73.4	71.8	67.6	63.7	59.6	57.6	58.6	62.4	65.5	69.6	71.2	(32)
(33)		10%	WB	64.5	65.0	63.5	61.1	58.5	55.2	53.6	53.6	55.7	57.5	60.6	62.1	(33)
(34)			MADB	71.8	71.2	70.1	66.5	62.7	58.5	56.9	57.6	60.9	63.7	67.3	69.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	8.4	7.5	7.5	6.6	6.0	5.4	6.0	6.9	8.2	9.0	8.6	8.7	(35)
(36)			MCDBR	20.8	17.8	16.9	12.0	8.7	6.8	7.4	9.1	12.3	16.7	18.6	19.8	(36)
(37)			MCWBR	6.3	6.3	6.3	5.9	5.3	5.1	5.5	5.7	6.2	7.1	6.4	6.4	(37)
(38)		5% WB	MCDBR	14.3	12.8	12.7	9.3	7.8	6.3	6.9	8.2	10.7	13.2	14.1	14.2	(38)
(39)			MCWBR	6.6	6.0	6.2	5.7	5.6	5.2	5.7	6.2	6.5	7.1	6.5	6.4	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.339	0.338	0.321	0.317	0.310	0.303	0.302	0.313	0.333	0.343	0.339	0.335	(40)	
(41)		taud	2.587	2.603	2.647	2.641	2.637	2.638	2.636	2.594	2.530	2.506	2.548	2.581	(41)	
(42)		Ebn at Noon	316	310	303	286	271	264	271	283	294	304	314	318	(42)	
(43)		Edh at Noon	33	31	28	25	22	20	22	25	31	34	34	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2353	2029	1636	1174	802	660	718	1004	1396	1807	2153	2318	(44)	
(45)		RadStd	115	100	69	73	37	40	36	56	108	115	87	104	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.54	N/A	+1.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (22 neighbors)		+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-178	+284	+119

Nomenclature: See separate page