

NHILL, Australia

WMO: 948270

Lat: 36.3092S

Lon: 141.6486E

Elev: 458

StdP: 14.45

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.2	36.1	23.7	18.2	77.4	26.9	21.2	75.9	27.6	52.0	25.3	53.3	4.2	160	0.574

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	29.1	100.9	65.2	96.5	64.1	92.4	63.0	69.1	86.4	67.4	85.2	65.7	84.0	14.2	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
64.9	93.9	72.1	62.3	85.5	71.5	59.8	77.9	70.8	33.5	86.6	32.0	85.3	30.8	83.4	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.6	22.9	20.5	DB	30.9	109.0	1.9	2.7	29.5	110.9	28.4	112.5	27.3	114.0	26.0	116.0	(4)
(5)			WB	30.0	72.2	1.8	2.5	28.8	74.1	27.7	75.5	26.7	77.0	25.4	78.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.6	72.1	71.0	66.9	60.5	54.1	49.4	48.6	49.7	53.0	58.2	64.0	68.3
	DBStd	10.58	8.12	7.79	7.84	6.42	4.73	3.58	3.53	4.21	5.28	7.37	8.21	8.10
	HDD50	222	0	0	0	1	12	54	69	58	22	6	0	0
	HDD65	2839	17	23	69	166	340	468	507	476	364	240	118	51
	CDD50	3725	685	588	525	317	138	36	27	47	111	262	422	567
	CDD65	867	237	192	129	32	1	0	0	0	2	31	89	154
	CDH74	12472	3497	2548	1626	393	7	0	0	2	54	563	1411	2371
	CDH80	6233	1927	1308	744	122	0	0	0	0	7	215	674	1236
Wind	WSAvg	10.3	11.6	11.3	10.5	9.1	9.2	8.5	9.5	9.7	9.9	10.7	11.2	11.7
Precipitation	PrecAvg	16.3	0.9	0.8	0.8	1.0	1.5	1.7	1.9	1.9	1.8	1.6	1.3	0.9
	PrecMax	29.4	5.7	4.1	4.0	3.4	4.4	4.8	4.1	3.8	4.4	5.9	3.8	3.1
	PrecMin	7.6	0.1	0.0	0.0	0.0	0.2	0.3	0.4	0.3	0.3	0.2	0.1	0.0
	PrecStd	4.3	1.1	0.9	0.8	0.9	1.0	0.9	0.9	0.9	1.1	1.3	0.9	0.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.3	103.3	99.1	90.3	74.6	64.5	63.4	71.6	80.0	92.4	99.3	104.8
		MCWB	66.7	68.8	64.1	62.0	56.7	53.3	52.6	53.7	56.9	60.2	64.2	64.9
	2%	DB	102.2	97.5	93.4	83.1	69.9	60.8	59.8	65.7	73.5	86.0	93.1	98.1
		MCWB	66.1	65.5	63.5	59.4	55.5	52.6	51.3	52.4	55.4	58.4	61.9	63.6
	5%	DB	96.0	93.4	88.5	78.4	65.9	58.7	57.5	61.0	68.3	80.3	88.1	92.4
		MCWB	64.2	64.3	62.3	58.0	54.9	52.0	50.7	51.5	53.9	57.1	60.6	61.7
	10%	DB	90.6	88.3	83.0	73.4	62.8	56.8	55.4	58.0	63.9	74.5	82.4	86.8
		MCWB	63.0	62.9	61.1	56.2	53.7	51.0	49.9	50.4	52.6	55.8	59.1	60.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	72.4	68.4	63.4	60.1	56.5	54.8	56.4	59.7	64.4	67.9	69.5
		MCDB	85.5	93.7	81.9	78.3	67.0	60.2	59.9	63.9	72.2	77.4	85.8	86.2
	2%	WB	69.2	69.0	66.5	61.7	57.9	54.4	53.0	54.0	57.2	61.2	65.1	66.4
		MCDB	86.9	86.5	81.1	74.9	64.8	59.0	57.4	62.2	68.1	76.9	82.8	83.3
	5%	WB	67.3	67.1	64.7	60.1	56.4	52.9	51.7	52.3	55.2	58.9	63.4	64.5
		MCDB	87.9	84.1	82.4	73.0	63.0	57.4	56.0	59.5	66.0	76.2	80.6	84.2
	10%	WB	65.3	65.2	62.9	58.3	54.9	51.6	50.4	51.0	53.4	56.9	61.2	62.6
		MCDB	86.6	82.9	80.5	70.5	61.1	55.6	54.5	57.3	62.5	71.8	79.1	83.1
Mean Daily Temperature Range	5% DB	MDBR	29.1	28.0	25.4	22.5	17.5	15.6	14.4	17.2	20.8	25.9	27.3	28.3
		MCDBR	35.5	33.8	30.9	28.8	21.2	17.7	16.4	22.0	28.0	34.6	34.9	35.8
		MCWBR	11.1	10.5	10.4	11.7	10.8	10.9	10.1	12.0	13.1	13.5	11.3	11.5
	5% WB	MCDBR	27.5	27.0	25.6	22.9	16.1	15.3	14.3	18.8	23.2	28.2	28.7	27.0
		MCWBR	11.0	9.9	10.4	10.5	9.4	10.1	9.6	11.3	12.3	12.5	10.7	10.7
Clear-Sky Solar Irradiance	taub	0.337	0.333	0.316	0.307	0.299	0.292	0.291	0.303	0.322	0.334	0.338	0.327	
	taud	2.493	2.520	2.565	2.569	2.578	2.593	2.593	2.538	2.472	2.448	2.469	2.522	
	Ebn at Noon	316	311	304	288	272	266	273	285	297	307	314	321	
	Edh at Noon	36	34	30	26	23	21	22	26	32	36	37	36	
All-Sky Solar Radiation	RadAvg	2456	2186	1741	1241	839	676	725	1017	1400	1855	2181	2413	
	RadStd	124	106	79	67	41	48	39	61	103	128	138	113	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (24 neighbors)		+0.74	N/A	N/A	+1.49	N/A	N/A	N/A	-148	+239	+99

Nomenclature: See separate page