

PORT FAIRY, Australia

WMO: 948300

Lat: 38.3906S

Lon: 142.2347E

Elev: 33

StdP: 14.68

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.8	40.9	35.3	30.2	45.6	36.8	32.1	46.5	32.8	50.0	30.0	51.8	6.7	0	0.604

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.0	87.0	65.9	80.1	64.4	75.2	63.9	68.7	79.1	67.0	75.6	65.5	72.8	13.6	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.8	95.2	70.7	64.2	90.1	69.4	62.9	86.0	68.2	32.9	79.5	31.5	75.9	30.4	73.0	80.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.0	25.9	23.1	DB	34.2	102.2	1.7	5.0	33.0	105.8	32.0	108.8	31.1	111.6	29.9	115.3	(4)
(5)			WB	33.6	72.8	1.7	2.8	32.4	74.8	31.4	76.4	30.5	78.0	29.3	80.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.5	64.3	64.8	62.6	58.8	55.1	51.7	50.8	51.7	53.7	56.4	59.2	61.6	(6)	
	DBStd	6.48	5.22	4.88	4.81	4.45	3.62	3.11	2.79	3.15	3.78	4.79	5.03	5.23	(7)	
	HDD50	67	0	0	0	0	3	17	24	17	5	1	0	0	(8)	
	HDD65	2919	68	50	105	195	308	398	441	414	339	275	192	134	(9)	
	CDD50	2813	444	415	390	265	162	69	48	68	117	199	275	361	(10)	
	CDD65	191	48	45	31	10	1	0	0	0	1	8	17	30	(11)	
	CDH74	1445	332	277	217	89	6	0	0	0	9	101	159	255	(12)	
	CDH80	614	157	129	96	25	0	0	0	0	0	27	58	122	(13)	
(14) Wind	WSAvg	11.7	12.4	12.2	11.2	10.6	10.6	10.8	11.4	11.8	11.8	12.1	12.8	12.5	(14)	
(15) Precipitation	PrecAvg	27.6	1.5	1.4	1.8	2.0	2.6	3.3	3.5	3.5	2.9	2.2	1.9	1.6	(15)	
	PrecMax	35.0	5.2	3.0	2.9	4.2	5.1	6.3	5.2	6.7	5.0	4.8	3.9	4.4	(16)	
	PrecMin	18.9	0.3	0.2	0.7	0.4	0.6	0.8	1.5	1.3	1.2	0.5	0.7	0.4	(17)	
	PrecStd	4.3	1.3	0.8	0.6	1.1	1.3	1.2	1.0	1.6	1.0	1.1	0.8	0.9	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.4	95.2	91.0	83.3	72.8	64.4	62.1	68.0	74.6	84.4	87.6	93.2	(19)	
		MCWB	68.5	68.3	65.9	61.8	58.6	57.1	54.6	56.7	59.9	63.2	65.8	67.0	(20)	
	2%	DB	82.1	81.6	79.5	74.9	66.8	60.6	59.3	63.1	68.3	75.7	78.0	80.5	(21)	
		MCWB	66.6	66.4	63.7	60.5	57.3	55.1	53.5	54.6	57.9	60.9	64.2	64.9	(22)	
	5%	DB	75.0	74.7	72.2	68.6	63.5	58.6	57.4	60.0	64.0	69.3	71.2	72.4	(23)	
		MCWB	66.0	65.9	63.7	59.7	56.6	54.1	52.6	53.6	55.8	58.6	62.7	63.5	(24)	
	10%	DB	71.0	71.1	68.7	65.4	61.1	57.1	55.9	57.5	60.6	64.1	66.6	68.7	(25)	
		MCWB	64.2	64.7	62.3	59.0	56.0	53.0	51.7	52.3	54.5	57.5	60.7	62.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	70.9	67.9	64.8	61.1	58.3	56.5	58.3	61.7	65.1	69.0	70.2	(27)	
		MCDB	81.9	83.7	79.5	75.1	66.3	61.3	59.3	65.2	70.2	77.4	76.9	83.1	(28)	
	2%	WB	68.5	68.3	66.1	62.7	59.4	56.2	54.7	56.0	59.0	62.0	65.7	66.4	(29)	
		MCDB	78.6	77.4	73.8	68.7	63.9	59.4	57.7	61.1	66.1	72.8	74.5	75.9	(30)	
	5%	WB	66.5	66.5	64.6	61.1	58.0	54.8	53.5	54.4	56.9	59.8	63.3	64.5	(31)	
		MCDB	74.6	73.7	70.6	66.4	62.1	57.8	56.5	58.7	62.5	67.5	70.6	71.8	(32)	
	10%	WB	64.8	65.1	63.2	59.8	56.6	53.6	52.2	53.0	55.1	57.7	61.1	62.7	(33)	
		MCDB	70.9	70.8	68.2	64.7	60.4	56.5	55.3	56.9	59.8	63.5	66.6	68.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	13.1	12.0	12.3	13.2	11.6	11.0	10.8	11.9	13.3	14.3	13.1	13.5	(35)	
		MCDBR	23.6	21.6	21.3	21.4	16.6	13.6	13.1	16.7	20.2	26.2	24.6	24.4	(36)	
		MCWBR	10.5	9.8	10.0	11.1	10.4	9.6	9.1	10.5	11.9	13.6	12.2	11.1	(37)	
	5% WB	MCDBR	19.6	17.4	16.9	17.0	14.1	12.2	11.5	15.1	18.2	22.0	20.8	20.0	(38)	
		MCWBR	9.9	9.2	9.3	10.3	9.8	9.1	8.8	10.2	11.6	12.5	11.4	10.4	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.348	0.342	0.332	0.321	0.313	0.309	0.303	0.317	0.342	0.344	0.344	0.340	(40)	
	taud		2.510	2.542	2.572	2.585	2.584	2.580	2.597	2.549	2.462	2.464	2.492	2.524	(41)	
	Ebn at Noon		312	306	297	280	263	254	264	277	288	302	312	316	(42)	
	Edh at Noon		35	33	29	25	22	20	21	26	32	35	36	35	(43)	
(44) All-Sky Solar Radiation	RadAvg		2252	1927	1517	1058	705	559	616	886	1278	1712	1995	2236	(44)	
	RadStd		124	107	76	70	35	40	37	46	80	117	117	140	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.56	N/A	N/A	N/A	+0.72	+0.79	N/A	-234	+270	+58	(46)
(47)	Regional (24 neighbors)	+0.79	N/A	N/A	+1.58	+0.74	N/A	N/A	-211	+270	+72	(47)

Nomenclature: See separate page