

MOUNT WILLIAM, Australia

WMO: 948330

Lat: 37.295S

Lon: 142.604E

Elev: 3773

StdP: 12.80

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	29.2	30.4	10.8	11.0	50.6	19.2	16.6	53.1	46.3	38.5	41.3	39.6	14.0	250	0.847

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.4	83.6	58.9	79.7	58.0	76.3	56.9	62.8	74.0	61.0	72.0	59.5	70.9	11.7	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.0	88.9	64.7	57.7	81.9	63.1	55.5	75.5	62.0	30.3	73.5	28.9	71.8	27.8	71.1	70.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 39.7	34.1	30.7	DB	27.2	90.9	1.0	3.7	26.5	93.6	25.9	95.8	25.4	97.8	24.7	100.5	(4)
(5)			WB	26.8	66.5	1.1	1.8	25.9	67.8	25.3	68.9	24.6	69.9	23.8	71.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.7	59.6	58.4	55.0	49.1	42.8	38.7	37.2	37.8	41.4	46.8	51.7	55.3	(6)	
	DBStd	10.96	10.37	9.52	9.44	7.14	4.88	3.61	3.22	4.50	5.71	8.76	9.65	9.94	(7)	
	HDD50	2138	22	24	52	104	230	339	397	379	268	174	97	52	(8)	
	HDD65	6490	238	229	338	479	688	789	862	843	709	567	413	335	(9)	
	CDD50	1317	319	258	207	77	7	0	0	1	9	74	148	217	(10)	
	CDD65	193	70	43	28	2	0	0	0	0	0	2	14	34	(11)	
	CDH74	1268	608	259	131	2	0	0	0	0	0	6	55	207	(12)	
	CDH80	321	192	53	23	0	0	0	0	0	0	0	4	49	(13)	
(14) Wind	WSAvg	16.2	16.0	15.8	14.8	14.9	17.4	17.1	18.1	17.4	16.9	15.6	15.6	14.9	(14)	
(15) Precipitation	PrecAvg	25.1	1.5	1.3	1.0	1.6	2.0	3.0	2.9	3.1	2.8	2.2	2.0	1.7	(15)	
	PrecMax	36.7	6.6	3.3	2.4	4.1	4.6	5.7	4.6	6.9	7.4	4.4	4.1	4.7	(16)	
	PrecMin	15.6	0.0	0.2	0.2	0.2	0.5	1.1	1.2	0.9	1.2	0.2	0.7	0.2	(17)	
	PrecStd	5.2	1.4	0.8	0.6	1.1	0.9	1.2	0.9	1.5	1.3	1.2	0.9	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.8	86.5	83.2	71.7	58.0	49.7	48.4	55.3	63.1	74.1	79.2	86.0	(19)	
		MCWB	60.1	61.5	58.8	53.7	48.9	42.2	42.7	46.5	50.2	53.8	57.9	58.3	(20)	
	2%	DB	85.3	80.5	77.5	66.1	54.6	46.9	45.3	50.8	57.8	68.9	75.0	79.9	(21)	
		MCWB	59.8	58.7	57.2	52.9	47.5	43.1	41.2	44.0	48.0	52.1	55.6	57.0	(22)	
	5%	DB	80.6	76.9	73.2	62.3	52.4	45.0	43.3	47.2	54.2	64.8	71.2	75.1	(23)	
		MCWB	58.3	58.8	56.1	51.2	46.9	42.6	41.2	43.0	46.1	50.0	55.2	55.4	(24)	
	10%	DB	76.5	73.1	69.2	59.4	49.8	43.5	41.8	44.3	50.6	60.9	67.2	70.8	(25)	
		MCWB	56.7	57.2	55.5	50.0	46.4	42.0	40.3	41.6	44.4	48.5	53.4	54.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	65.2	66.2	61.6	56.9	51.8	46.4	45.6	47.6	51.8	57.3	61.8	63.4	(27)	
		MCDB	75.2	75.7	71.9	66.2	54.1	47.1	46.3	51.1	59.4	66.8	72.3	70.3	(28)	
	2%	WB	62.8	62.8	59.9	54.5	49.8	44.7	43.4	45.3	49.3	54.3	58.9	60.3	(29)	
		MCDB	76.1	72.5	70.2	62.3	52.0	45.7	44.1	49.1	55.4	63.8	68.9	71.5	(30)	
	5%	WB	60.9	60.8	58.3	52.8	48.5	43.5	42.0	43.6	47.3	51.9	56.8	58.1	(31)	
		MCDB	72.6	71.7	68.1	59.4	50.9	44.3	42.7	46.6	52.9	60.9	67.3	70.0	(32)	
	10%	WB	59.1	58.8	57.0	51.3	47.0	42.5	40.8	41.8	45.3	50.1	54.8	56.1	(33)	
		MCDB	71.8	70.4	66.4	57.4	49.2	43.1	41.4	43.9	49.5	59.1	64.6	67.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	18.4	17.2	14.1	10.5	6.8	5.8	5.5	7.2	10.6	14.0	15.1	16.6	(35)	
		MCDBR	21.7	20.5	17.2	13.8	9.8	8.2	7.4	11.5	15.2	18.6	18.5	19.9	(36)	
	5% WB	MCWBR	9.7	9.9	8.5	7.7	7.0	6.7	6.1	8.1	9.7	10.3	10.2	10.9	(37)	
		MCWBR	18.9	18.2	15.5	12.6	8.3	6.9	6.1	10.0	13.4	16.8	16.4	17.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.298	0.291	0.278	0.271	0.265	0.258	0.256	0.268	0.283	0.287	0.291	0.287	(40)	
		taud	2.577	2.621	2.661	2.657	2.645	2.659	2.672	2.613	2.554	2.556	2.584	2.620	(41)	
	Ebn at Noon		329	325	317	301	285	278	286	298	310	322	329	334	(42)	
		Edh at Noon	33	30	27	23	21	19	20	24	29	32	33	32	(43)	
(44) All-Sky Solar Radiation	RadAvg		2363	2069	1627	1134	758	605	658	933	1300	1723	2046	2293	(44)	
	RadStd		140	101	81	71	37	48	41	58	91	143	140	126	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	+0.83	N/A	N/A	+1.62	+0.72	N/A	N/A	-223	+293	+85

Nomenclature: See separate page