

BEN NEVIS, AustraliaWMO: **948350**Lat: **37.228S**Lon: **143.201E**Elev: **875**StdP: **91.25**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.5	0.2	-8.9	2.0	14.6	-5.2	2.7	14.2	15.1	4.1	13.4	5.3	5.9	210	0.678

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.4	30.6	15.8	28.2	15.2	26.2	14.5	18.0	24.5	17.0	24.1	16.0	23.1	4.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.2	12.8	19.3	14.8	11.7	18.7	13.5	10.7	17.8	54.4	24.2	51.0	24.0	47.8	23.2	22.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
12.9	11.3	10.1	DB	-1.3	34.9	0.8	2.7	-1.9	36.9	-2.4	38.4	-2.9	40.0	-3.5	41.9
			WB	-1.7	19.9	0.9	1.6	-2.4	21.0	-2.9	21.9	-3.4	22.8	-4.1	23.9

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	10.2	16.8	16.7	14.0	11.0	7.4	5.2	4.3	4.9	7.0	9.4	12.0	14.3	(6)
	DBStd	6.00	5.49	5.12	4.89	3.96	2.81	2.01	1.82	2.40	3.23	4.55	5.17	5.41	(7)
	HDD10.0	845	4	3	13	34	91	143	177	160	103	68	33	15	(8)
	HDD18.3	3117	98	86	152	221	339	393	436	417	340	281	201	153	(9)
	CDD10.0	925	216	192	138	64	11	0	0	1	13	49	94	147	(10)
	CDD18.3	155	51	41	19	2	0	0	0	0	0	3	12	27	(11)
	CDH23.3	1256	494	306	122	6	0	0	0	0	0	15	83	230	(12)
	CDH26.7	399	192	88	29	1	0	0	0	0	0	1	15	72	(13)
(14) Wind	WSAvg	5.4	5.4	5.3	5.2	5.0	5.4	5.6	5.7	5.6	5.8	5.6	5.5	5.4	(14)
(15) Precipitation	PrecAvg	572	37	34	26	38	47	69	65	67	65	44	44	43	(15)
	PrecMax	871	159	82	61	99	106	155	119	145	158	97	96	124	(16)
	PrecMin	367	0	1	6	2	9	22	30	17	20	1	13	3	(17)
	PrecStd	129	35	23	16	26	25	33	22	32	34	28	24	31	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	35.5	32.5	30.2	23.8	16.4	11.5	10.5	13.8	19.4	25.5	28.8	32.3	(19)
		MCWB	17.0	16.5	15.3	13.6	10.2	8.3	7.5	9.0	11.2	13.0	15.1	15.6	(20)
	2%	DB	31.3	29.1	26.5	20.6	14.5	10.0	8.7	11.5	16.2	21.9	25.7	28.6	(21)
		MCWB	16.2	15.8	14.5	12.0	9.7	7.9	6.6	7.5	10.2	12.1	13.8	14.9	(22)
	5%	DB	28.4	26.9	24.1	18.6	13.0	8.9	7.7	9.8	14.1	19.2	23.2	25.7	(23)
		MCWB	15.4	15.5	14.0	11.4	9.1	7.3	6.3	6.8	9.0	10.7	12.9	13.6	(24)
	10%	DB	25.7	24.8	21.7	16.8	11.4	8.0	6.8	8.3	12.0	17.0	20.7	23.2	(25)
		MCWB	14.6	14.8	13.2	10.9	8.6	6.9	5.8	6.0	8.4	10.1	12.4	12.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	19.5	20.0	17.1	14.7	11.7	9.6	8.8	9.8	12.4	15.0	17.3	17.8	(27)
		MCDB	26.6	25.8	23.6	21.2	14.2	10.2	9.4	12.6	16.5	21.7	23.9	25.6	(28)
	2%	WB	18.0	18.2	16.0	13.2	10.7	8.5	7.5	8.2	11.0	13.1	15.6	16.2	(29)
		MCDB	25.8	23.3	23.0	17.9	12.8	9.3	8.0	10.4	14.6	18.8	21.7	24.1	(30)
	5%	WB	16.9	17.1	15.1	12.4	9.9	7.7	6.7	7.3	9.8	11.8	14.4	15.0	(31)
		MCDB	24.8	23.5	21.3	16.7	11.8	8.4	7.2	9.0	13.4	17.5	20.2	23.1	(32)
	10%	WB	15.8	15.8	14.1	11.6	9.1	7.1	6.0	6.5	8.8	10.7	13.1	13.9	(33)
		MCDB	23.8	22.2	20.4	15.7	10.9	7.8	6.6	7.9	11.6	16.0	19.4	21.6	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.4	10.6	9.0	6.8	4.4	3.5	3.5	4.6	6.4	8.3	9.6	10.8	(35)
		MCDBR	13.7	12.2	10.6	8.8	6.1	4.7	4.6	6.7	8.8	11.0	12.0	12.6	(36)
	5% WB	MCWBR	5.6	5.0	4.7	4.2	3.8	3.6	3.5	4.4	5.2	5.6	5.7	5.6	(37)
		MCWBR	11.5	10.7	9.5	7.8	5.2	4.1	4.0	5.8	8.0	10.1	10.6	11.3	(38)
(40) Clear-Sky Solar Irradiance	taub	taub	0.311	0.304	0.293	0.285	0.274	0.267	0.268	0.277	0.299	0.303	0.307	0.302	(40)
		taud	2.534	2.576	2.599	2.599	2.608	2.623	2.615	2.577	2.493	2.499	2.524	2.560	(41)
	Ebn at Noon	Ebn at Noon	1023	1008	982	932	884	864	883	927	958	998	1021	1037	(42)
		Edh at Noon	109	100	90	79	68	62	66	79	98	107	110	107	(43)
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.48	6.56	5.19	3.63	2.43	1.92	2.10	2.96	4.14	5.51	6.50	7.30	(44)
	RadStd	RadStd	0.43	0.33	0.27	0.22	0.12	0.16	0.13	0.20	0.28	0.45	0.42	0.39	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (40 neighbors)	+1.34	+0.76	N/A	+2.23	N/A	N/A	N/A	N/A	N/A	N/A
		+0.48	N/A	N/A	+0.85	N/A	N/A	-12	-121	+167	+56

Nomenclature: See separate page