

AIREYS INLET, Australia

WMO: 948460

Lat: 38.458S

Lon: 144.088E

Elev: 312

StdP: 14.53

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	41.0	42.4	33.9	28.9	53.2	35.7	31.0	50.0	35.7	53.9	31.3	52.2	12.5	310	0.575

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	13.0	89.4	65.0	83.2	63.6	78.2	63.0	68.5	79.3	67.0	76.9	65.5	74.1	16.2	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.6	95.7	70.9	64.2	90.9	69.3	62.7	86.3	68.1	32.9	79.6	31.6	76.9	30.5	74.0	76.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 29.2	25.2	22.2	DB	37.8	101.8	2.2	4.8	36.2	105.2	34.9	108.0	33.7	110.6	32.1	114.1	(4)
(5)			WB	36.4	72.3	2.4	1.9	34.7	73.7	33.3	74.8	32.0	75.9	30.3	77.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.3	64.3	65.0	63.0	58.9	55.0	51.5	50.2	50.9	53.1	55.9	58.7	61.3
	DBStd	7.12	6.12	5.70	5.80	5.09	3.98	2.94	2.82	3.56	4.45	5.65	5.77	6.07
	HDD50	97	0	0	0	1	3	17	31	29	12	3	1	0
	HDD65	3076	83	59	108	197	311	406	460	438	360	292	210	152
	CDD50	2752	444	421	402	268	159	61	36	56	105	188	262	350
	CDD65	254	62	60	46	14	1	0	0	0	2	11	21	37
	CDH74	2150	533	428	347	91	2	0	0	0	13	139	214	383
	CDH80	888	250	182	142	21	0	0	0	0	1	40	77	175
Wind	WSAvg	10.9	10.9	10.5	10.1	9.8	10.9	11.1	12.1	12.0	11.5	11.0	10.7	10.6
Precipitation	PrecAvg	25.9	1.6	1.6	1.3	2.0	2.0	2.6	2.7	2.9	2.7	2.5	2.3	1.7
	PrecMax	35.0	5.5	4.7	3.2	6.9	3.8	5.0	4.9	4.7	5.7	4.8	5.0	4.1
	PrecMin	17.6	0.2	0.4	0.4	0.5	0.5	0.9	1.1	1.2	1.4	0.7	0.8	0.4
	PrecStd	4.1	1.3	0.9	0.7	1.3	0.9	0.9	0.9	1.0	1.0	1.2	1.0	0.9
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	99.2	94.6	93.2	82.7	71.1	63.2	61.7	67.7	75.3	85.2	88.2	95.7
		MCWB	67.1	66.5	64.8	61.1	57.1	55.6	52.9	55.0	58.6	60.5	64.5	65.9
	2%	DB	86.6	85.6	82.9	75.7	66.8	59.7	58.4	62.4	68.8	77.3	80.2	84.0
		MCWB	65.5	65.5	63.8	59.4	56.7	53.9	51.6	52.8	56.3	58.8	62.2	63.1
	5%	DB	79.0	78.2	76.2	70.3	63.7	57.6	56.4	59.2	64.6	71.4	73.5	76.2
		MCWB	65.1	64.9	63.4	58.7	55.5	52.9	50.7	51.6	54.3	57.3	60.7	62.8
	10%	DB	73.1	73.4	71.2	66.3	61.1	56.1	54.8	56.7	60.9	65.7	68.0	70.1
		MCWB	64.5	64.9	62.1	58.1	55.2	51.9	50.1	50.6	53.0	55.9	59.7	61.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	70.4	68.6	63.9	61.4	57.8	54.8	56.7	60.3	62.9	67.4	68.3
		MCDB	83.3	80.4	79.3	73.9	65.3	60.1	58.2	64.1	70.2	75.4	78.6	83.0
	2%	WB	68.6	68.3	66.4	62.1	58.7	55.3	53.1	54.3	57.5	60.4	64.4	65.8
		MCDB	80.3	77.6	76.3	68.7	63.0	58.1	56.3	60.1	66.2	72.3	73.9	77.7
	5%	WB	66.6	66.9	64.7	60.7	57.1	53.7	51.8	52.6	55.5	58.5	62.2	63.9
		MCDB	76.9	75.0	72.4	66.5	61.9	56.8	55.1	57.4	62.6	68.7	71.2	74.2
	10%	WB	64.7	65.5	63.3	59.2	55.6	52.4	50.7	51.3	53.8	56.6	60.2	62.1
		MCDB	72.4	72.2	69.8	65.1	60.0	55.5	54.0	55.7	60.0	64.5	67.2	69.3
Mean Daily Temperature Range	5% DB	MDBR	14.1	13.0	12.6	11.7	10.0	8.6	9.1	10.6	12.8	14.4	13.8	14.6
		MCDBR	27.0	24.2	23.5	19.4	13.8	10.6	10.9	14.4	19.5	25.5	25.5	27.4
		MCWBR	10.0	9.2	9.3	8.2	7.8	6.9	6.8	7.8	10.0	10.9	10.7	10.6
	5% WB	MCDBR	20.5	17.1	17.3	14.6	11.5	9.4	9.7	12.4	16.5	20.9	20.1	21.5
		MCWBR	9.7	8.2	8.3	7.8	7.8	6.8	6.7	7.6	9.4	10.3	9.8	10.1
Clear-Sky Solar Irradiance	taub	0.348	0.348	0.331	0.323	0.311	0.302	0.301	0.313	0.331	0.335	0.343	0.339	
	taud	2.528	2.535	2.585	2.583	2.593	2.604	2.602	2.563	2.509	2.510	2.513	2.546	
	Ebn at Noon	312	304	297	279	264	257	265	279	292	305	312	317	
	Edh at Noon	35	33	29	25	22	20	21	25	31	34	35	35	
All-Sky Solar Radiation	RadAvg	2223	1938	1509	1054	705	558	622	877	1258	1689	1968	2217	
	RadStd	133	84	84	57	31	41	33	44	73	123	115	139	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.83	N/A	N/A	N/A	N/A	N/A	N/A	-274	+324	+72
(47) Regional (35 neighbors)		+0.90	N/A	N/A	+1.53	N/A	N/A	-27	-232	+311	+97

Nomenclature: See separate page