

POINT WILSON, Australia

WMO: 948470

Lat: 38.096S

Lon: 144.536E

Elev: 59

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 94-08

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	42.7	44.2	35.6	30.6	52.8	37.0	32.4	51.4	35.3	51.7	33.0	54.0	11.3	290	0.673

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.8	86.1	66.4	81.5	65.6	77.8	64.8	70.0	78.7	68.2	76.8	66.8	74.8	18.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
67.4	101.0	73.6	65.3	93.8	71.8	63.8	89.0	70.7	34.0	78.7	32.5	76.7	31.4	75.4	85.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.1	30.2	27.3	39.8	95.3	1.4	3.9	38.8	98.1	38.0	100.4	37.2	102.6	36.2	105.5		
(5)			38.4	73.1	1.2	5.1	37.5	76.8	36.8	79.8	36.2	82.6	35.3	86.3		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	58.7	66.5	67.3	64.5	59.7	56.1	52.4	50.7	52.0	54.8	57.2	60.7	63.2	(6)
(7)		DBStd	7.19	5.46	5.75	4.84	4.34	3.68	3.34	2.84	3.42	4.12	4.96	5.50	5.85	(7)
(8)		HDD50	59	0	0	0	0	1	12	26	16	3	1	0	0	(8)
(9)		HDD65	2636	44	33	67	169	276	377	444	404	309	250	156	107	(9)
(10)		CDD50	3237	511	484	451	293	191	85	46	77	146	223	320	410	(10)
(11)		CDD65	337	90	96	53	11	1	0	0	0	1	8	25	52	(11)
(12)		CDH74	1809	491	504	225	41	0	0	0	0	5	54	147	342	(12)
(13)		CDH80	564	170	154	62	6	0	0	0	0	0	14	42	116	(13)
(14)	Wind	WSAvg	14.4	16.0	14.6	14.2	13.0	12.8	13.4	13.6	13.9	14.9	15.7	15.7	15.2	(14)
(15)	Precipitation	PrecAvg	20.9	1.5	1.6	1.4	1.7	1.7	1.9	1.8	2.0	1.9	2.0	1.6	(15)	
(16)		PrecMax	29.0	4.4	5.4	4.1	5.6	3.9	3.9	3.7	3.3	3.7	4.3	4.8	3.8	(16)
(17)		PrecMin	12.4	0.0	0.2	0.5	0.3	0.6	0.8	0.6	0.7	0.6	0.2	0.6	0.2	(17)
(18)		PrecStd	4.4	1.1	1.2	0.7	1.1	0.8	0.8	0.8	0.7	0.9	1.1	1.1	1.0	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.3	90.9	87.7	79.8	69.0	63.7	60.9	65.4	72.8	79.9	85.4	89.9	(19)
(20)			MCWB	68.6	68.0	67.0	60.3	56.2	56.2	52.3	54.4	57.4	59.8	66.7	64.3	(20)
(21)		2%	DB	84.4	84.5	79.7	72.8	65.7	60.9	58.2	61.9	67.4	73.7	77.8	82.2	(21)
(22)			MCWB	66.9	67.1	64.8	60.0	56.6	55.6	51.9	53.6	57.2	59.4	63.5	63.9	(22)
(23)		5%	DB	78.9	80.2	75.1	68.9	63.0	59.2	56.6	59.4	64.2	68.6	72.5	76.8	(23)
(24)			MCWB	66.1	66.9	64.6	60.0	55.7	54.6	51.2	52.6	55.9	58.8	62.8	63.9	(24)
(25)		10%	DB	74.7	75.9	71.1	65.7	61.4	57.6	55.2	57.4	61.5	65.2	68.7	71.4	(25)
(26)			MCWB	65.6	66.1	63.0	58.9	55.4	53.3	50.6	51.7	54.7	57.4	61.7	62.4	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.6	72.4	68.8	63.4	59.4	58.4	56.0	57.6	61.1	66.1	72.1	67.5	(27)
(28)			MCDWB	80.6	80.8	79.7	71.1	63.6	60.9	58.6	62.3	65.9	74.0	80.8	79.1	(28)
(29)		2%	WB	69.8	70.2	67.0	62.0	58.1	57.1	54.0	55.3	59.2	62.3	67.7	66.1	(29)
(30)			MCDWB	78.8	79.1	75.1	68.9	62.3	59.7	56.3	59.5	64.1	68.3	72.3	77.3	(30)
(31)		5%	WB	67.9	68.3	65.4	60.8	57.1	55.5	52.6	53.8	57.5	59.9	64.6	64.6	(31)
(32)			MCDWB	76.8	76.8	72.5	67.3	61.3	58.9	55.4	57.8	62.3	66.2	69.4	74.4	(32)
(33)		10%	WB	66.0	66.9	63.9	59.5	56.1	53.7	51.1	52.2	55.7	57.7	62.0	63.1	(33)
(34)			MCDWB	73.6	74.9	70.5	65.6	60.5	57.2	54.4	56.4	60.9	64.3	68.4	71.7	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	10.3	9.8	9.4	8.7	7.9	7.1	7.3	8.4	9.6	10.4	9.8	10.6	(35)
(36)			MCDBR	20.0	19.1	18.2	14.7	10.0	8.9	9.0	11.5	14.5	18.4	18.3	21.9	(36)
(37)			MCWBR	7.3	6.9	7.0	6.6	5.4	5.0	5.2	5.6	7.2	7.5	8.0	7.5	(37)
(38)		5% WB	MCDWB	16.2	15.1	14.3	12.4	8.4	7.5	7.5	10.8	11.8	13.7	14.3	17.5	(38)
(39)			MCWBR	8.1	6.9	6.7	6.7	5.2	4.9	5.3	6.0	7.0	7.1	7.9	7.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.352	0.356	0.334	0.327	0.314	0.302	0.303	0.313	0.334	0.340	0.347	0.344	(40)	
(41)		taud	2.506	2.503	2.566	2.558	2.576	2.599	2.584	2.550	2.485	2.483	2.491	2.517	(41)	
(42)		Ebn at Noon	311	302	296	278	263	258	264	279	291	304	310	315	(42)	
(43)		Edh at Noon	36	34	30	26	22	20	22	26	31	35	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2252	1970	1554	1084	725	568	637	896	1283	1708	1988	2236	(44)	
(45)		RadStd	137	91	89	58	36	41	35	51	81	125	115	128	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (37 neighbors)	+0.90	N/A	N/A	+1.57	N/A	-31	-234	+315	+104

Nomenclature: See separate page