

BENDIGO, AustraliaWMO: **948550**Lat: **36.7394S**Lon: **144.3267E**Elev: **684**StdP: **14.34**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	30.8	32.8	25.5	20.0	66.8	28.4	23.0	58.7	20.7	53.2	18.8	52.0	1.6	150	0.524

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.8	97.7	65.2	93.3	64.2	89.4	63.4	69.9	82.9	67.9	83.8	66.2	82.2	11.9	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	100.4	73.0	63.6	90.3	71.7	61.0	82.1	70.7	34.4	81.7	32.6	84.1	31.3	82.3	92.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.4	18.4	16.5	DB	26.9	104.9	1.8	3.4	25.6	107.3	24.5	109.4	23.5	111.3	22.1	113.8	(4)
(5)			WB	27.5	73.6	2.4	4.6	25.8	76.9	24.4	79.6	23.1	82.1	21.3	85.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	58.0	71.6	71.1	65.9	58.3	51.7	47.4	45.8	47.1	51.0	56.6	63.2	67.2	(6)	
	DBStd	10.87	7.55	6.99	6.86	5.72	4.53	3.89	3.60	3.96	5.01	6.30	7.30	7.31	(7)	
	HDD50	432	0	0	0	4	33	97	138	108	43	8	1	0	(8)	
	HDD65	3288	21	21	72	212	411	529	596	554	419	274	120	59	(9)	
	CDD50	3352	669	591	492	252	87	18	7	19	74	213	397	533	(10)	
	CDD65	734	225	192	99	11	0	0	0	0	1	13	66	127	(11)	
	CDH74	9576	2960	2220	1110	150	1	0	0	0	22	288	983	1842	(12)	
	CDH80	4360	1534	1043	421	24	0	0	0	0	3	86	395	854	(13)	
(14) Wind	WSAvg	8.0	9.8	9.2	8.5	7.2	6.4	6.3	6.4	7.0	7.8	8.6	9.2	9.7	(14)	
(15) Precipitation	PrecAvg	22.9	1.4	1.1	1.4	1.9	2.5	2.1	2.4	2.7	2.4	2.1	1.4	1.6	(15)	
	PrecMax	40.0	4.6	8.2	4.1	4.9	5.8	6.2	4.8	5.5	5.9	8.1	3.9	4.1	(16)	
	PrecMin	8.3	0.0	0.0	0.1	0.2	0.1	0.4	0.5	0.4	0.6	0.2	0.2	0.0	(17)	
	PrecStd	6.4	1.2	1.7	1.1	1.3	1.6	1.5	1.1	1.3	1.4	1.7	1.0	1.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	105.3	101.0	95.4	83.3	71.0	61.9	60.0	66.5	76.8	88.6	95.2	100.9	(19)	
		MCWB	66.1	66.5	64.7	60.5	56.5	52.5	51.5	54.6	55.8	59.2	62.2	64.3	(20)	
	2%	DB	98.8	94.7	89.1	78.1	66.6	58.9	57.2	62.0	70.5	81.6	89.4	94.4	(21)	
		MCWB	65.9	65.3	63.4	58.9	55.3	51.8	50.2	51.8	55.5	57.8	61.8	63.0	(22)	
	5%	DB	93.6	90.5	84.5	74.5	63.6	56.9	55.1	59.0	65.9	76.0	84.4	89.3	(23)	
		MCWB	64.6	64.8	62.5	57.7	54.1	50.7	49.3	50.5	54.0	56.9	60.4	61.8	(24)	
	10%	DB	88.6	86.6	80.1	70.8	60.9	55.0	53.4	56.5	62.3	71.3	79.6	84.4	(25)	
		MCWB	63.7	63.7	61.0	56.7	53.2	49.7	48.3	49.2	52.6	55.3	59.4	60.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.2	73.0	69.1	63.4	60.0	56.1	54.4	55.9	60.7	63.7	68.2	70.2	(27)	
		MCDB	83.4	88.8	82.2	74.5	64.6	58.1	56.5	62.8	69.2	75.9	81.7	79.0	(28)	
	2%	WB	70.0	69.9	66.8	61.4	57.6	53.3	51.8	53.5	57.6	61.0	65.2	66.9	(29)	
		MCDB	84.7	82.1	80.4	70.5	62.3	56.7	55.2	59.8	66.2	72.0	78.2	80.9	(30)	
	5%	WB	67.8	67.7	64.9	59.7	55.7	52.0	50.3	51.6	55.4	58.9	63.2	64.8	(31)	
		MCDB	86.5	83.0	78.6	70.2	61.4	55.3	53.7	57.5	64.0	71.0	77.0	81.3	(32)	
	10%	WB	65.8	65.9	63.0	57.9	54.2	50.6	49.0	49.8	53.2	56.7	61.3	62.9	(33)	
		MCDB	84.0	81.9	76.4	69.1	59.8	54.0	52.4	55.4	61.0	69.4	75.4	80.7	(34)	
(35) Mean Daily Temperature Range	MDBR		26.8	25.4	23.4	22.1	18.4	15.7	15.5	18.4	20.9	23.9	24.9	26.8	(35)	
	5% DB	MCDBR	34.3	31.0	29.6	27.5	22.4	17.9	18.1	23.0	27.4	32.8	33.0	34.4	(36)	
		MCWBR	10.5	9.6	10.4	11.7	12.2	11.2	11.6	13.6	14.1	13.6	11.3	10.9	(37)	
	5% WB	MCDBR	26.8	25.0	23.2	21.7	17.8	14.2	15.3	20.0	22.8	25.3	25.2	25.8	(38)	
		MCWBR	10.6	9.8	9.8	10.5	10.8	9.9	10.5	12.7	13.0	12.5	10.5	11.0	(39)	
(40) Clear-Sky Solar Irradiance	taub		0.337	0.334	0.317	0.307	0.296	0.289	0.288	0.296	0.319	0.327	0.338	0.329	(40)	
	taud		2.503	2.525	2.563	2.563	2.573	2.586	2.585	2.545	2.471	2.465	2.473	2.518	(41)	
	Ebn at Noon		316	310	303	287	272	266	273	287	298	309	314	320	(42)	
	Edh at Noon		36	34	30	26	23	21	22	26	32	35	37	36	(43)	
(44) All-Sky Solar Radiation	RadAvg		2426	2149	1731	1231	833	642	699	992	1399	1857	2160	2410	(44)	
	RadStd		130	107	84	60	47	60	40	70	103	139	118	119	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.97	+1.04	N/A	+1.80	N/A	N/A	N/A	-184	+374	+216
(47) Regional (37 neighbors)		+0.92	N/A	N/A	+1.58	N/A	N/A	-34	-220	+317	+121

Nomenclature: See separate page