

REDESDALE, Australia

WMO: 948590

Lat: 37.0194S

Lon: 144.5203E

Elev: 290

StdP: 97.89

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-0.4	0.5	-2.9	3.1	16.0	-1.5	3.4	11.2	11.1	10.3	9.4	9.6	2.6	200	0.551

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	15.5	35.7	18.1	33.2	17.7	31.1	17.3	20.7	27.8	19.6	28.0	18.7	27.5	4.6	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
18.9	14.2	22.1	17.2	12.7	21.6	15.8	11.7	20.9	61.0	27.2	57.1	28.1	54.1	27.7	26.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	9.7	8.5	-2.4	39.8	1.0	2.2	-3.2	41.4	-3.8	42.7	-4.4	43.9	-5.1	45.4
			-2.7	22.6	1.1	1.5	-3.5	23.7	-4.2	24.6	-4.8	25.4	-5.6	26.5
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	13.7	21.1	20.8	18.0	13.9	10.4	8.2	7.4	8.0	10.0	12.4	15.9	18.3	(6)
	DBStd	5.76	4.15	3.86	3.75	3.10	2.39	2.02	1.84	2.00	2.57	3.30	3.86	4.07	(7)
	HDD10.0	281	0	0	0	4	24	61	82	67	30	11	1	0	(8)
	HDD18.3	2018	18	18	52	136	246	306	339	319	251	187	95	52	(9)
	CDD10.0	1616	345	301	249	121	37	6	2	6	30	86	177	257	(10)
	CDD18.3	311	104	86	43	3	0	0	0	0	3	21	50	50	(11)
	CDH23.3	4398	1426	1052	529	56	0	0	0	0	5	92	377	861	(12)
(13)	CDH26.7	1961	727	477	196	8	0	0	0	0	0	23	138	393	(13)
(14) Wind	WSAvg	3.8	4.8	4.5	4.1	3.5	3.1	3.2	3.1	3.3	3.5	4.0	4.4	4.4	(14)
(15) Precipitation	PrecAvg	631	38	44	31	36	52	73	74	66	67	50	55	45	(15)
	PrecMax	1056	198	140	92	93	126	156	128	115	155	141	170	123	(16)
	PrecMin	384	0	2	3	4	3	21	19	8	13	3	17	1	(17)
	PrecStd	171	37	37	22	24	32	37	29	32	37	37	35	33	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	40.1	37.9	34.6	27.7	20.7	16.1	14.7	18.1	23.3	29.6	33.8	37.8	(19)
		MCWB	18.5	19.2	17.6	15.4	12.8	11.0	10.6	12.3	13.6	14.9	17.6	17.7	(20)
	2%	DB	36.3	34.1	31.4	24.8	18.5	14.5	13.2	15.7	20.2	26.0	30.4	33.9	(21)
		MCWB	18.5	18.3	17.2	14.6	12.6	10.8	9.9	10.9	13.0	14.4	16.2	17.2	(22)
	5%	DB	33.3	31.8	28.7	22.9	17.0	13.4	12.2	14.1	18.0	23.0	27.6	31.0	(23)
		MCWB	17.9	17.9	16.7	14.1	12.2	10.3	9.3	10.1	12.4	13.7	16.0	16.4	(24)
	10%	DB	30.7	29.6	26.2	21.0	15.5	12.3	11.3	12.8	16.1	20.3	24.9	28.3	(25)
		MCWB	17.4	17.3	16.0	13.5	11.5	9.8	8.8	9.3	11.5	12.9	15.4	15.7	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.2	22.7	20.3	17.2	15.1	13.2	11.9	13.0	15.5	17.5	19.9	20.6	(27)
		MCDB	28.8	30.5	27.4	23.2	17.4	13.9	12.9	16.7	19.7	23.8	27.3	26.7	(28)
	2%	WB	20.6	20.9	19.0	16.0	13.9	11.7	10.7	11.6	14.1	16.0	18.3	19.0	(29)
		MCDB	28.5	27.5	26.3	21.0	16.3	13.2	12.2	14.6	18.4	21.4	25.8	27.6	(30)
	5%	WB	19.5	19.5	18.0	15.1	12.8	10.9	9.9	10.6	12.9	14.7	17.2	17.9	(31)
		MCDB	29.4	27.5	25.3	20.8	15.8	12.5	11.5	13.4	17.3	20.7	24.6	27.3	(32)
	10%	WB	18.5	18.5	16.9	14.1	12.0	10.1	9.2	9.6	11.7	13.6	16.0	16.8	(33)
		MCDB	28.4	27.0	24.4	19.9	15.0	11.9	10.8	12.3	15.7	19.6	22.9	26.1	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	15.5	14.7	13.5	12.3	9.9	8.3	7.8	9.5	11.5	13.3	14.3	15.8	(35)
		MCDBR	19.9	18.3	17.3	15.6	12.2	10.1	9.5	12.0	14.7	18.2	19.2	20.7	(36)
		MCWBR	6.4	6.2	6.4	7.0	7.0	6.7	6.4	7.5	8.3	8.5	7.6	7.1	(37)
	5% WB	MCDBR	15.7	14.6	13.8	12.6	9.9	8.3	7.8	10.6	12.8	14.8	15.3	16.1	(38)
		MCWBR	6.1	6.2	6.1	6.3	6.3	6.0	5.7	7.1	7.8	7.9	7.1	6.7	(39)
(40) Clear-Sky Solar Irradiance	taub		0.336	0.335	0.316	0.307	0.294	0.287	0.287	0.296	0.320	0.326	0.337	0.328	(40)
	taud		2.512	2.521	2.572	2.569	2.583	2.592	2.590	2.547	2.471	2.474	2.478	2.522	(41)
	Ebn at Noon		998	975	957	906	860	838	860	904	936	974	991	1010	(42)
	Edh at Noon		112	106	93	82	70	65	68	82	101	110	115	112	(43)
(44) All-Sky Solar Radiation	RadAvg		7.49	6.59	5.31	3.74	2.52	1.94	2.13	3.03	4.29	5.68	6.62	7.41	(44)
	RadStd		0.44	0.34	0.28	0.20	0.15	0.17	0.13	0.21	0.32	0.43	0.38	0.38	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (37 neighbors)	+0.52	N/A	N/A	+0.92	N/A	N/A	-18	-128	+177	+63

Nomenclature: See separate page