

YARRAWONGA, Australia

WMO: 948620

Lat: 36.0294S

Lon: 146.0306E

Elev: 424

StdP: 14.47

Time Zone: 10.00 (AUS)

Period: 02-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.8	33.7	26.0	20.2	69.6	28.8	23.1	58.9	22.8	53.4	20.8	52.9	3.2	240	0.504

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	28.7	101.6	66.8	97.0	66.0	93.1	65.2	72.0	84.8	70.2	84.5	68.7	84.3	11.0	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
69.1	108.5	76.1	66.5	99.3	74.8	63.9	90.5	73.4	36.0	83.6	34.4	84.2	33.1	83.6	80.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.6	19.8	17.5	DB	28.2	108.0	2.1	2.7	26.7	110.0	25.4	111.6	24.2	113.1	22.6	115.1	(4)
(5)			WB	27.7	74.7	2.1	2.6	26.2	76.6	24.9	78.0	23.7	79.5	22.2	81.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	60.7	76.3	74.3	69.2	61.3	53.6	48.5	47.5	48.5	52.5	59.2	66.7	71.3
	DBStd	11.75	7.46	6.75	6.66	5.70	4.57	4.00	3.69	4.00	4.96	6.44	7.38	7.06
	HDD50	291	0	0	0	1	15	75	95	78	25	2	0	0
	HDD65	2749	4	7	32	138	354	496	543	512	375	205	64	19
	CDD50	4186	814	682	596	340	126	29	17	31	101	287	502	661
	CDD65	1169	353	269	163	27	0	0	0	1	24	116	216	
	CDH74	15437	4833	3164	1874	314	5	0	0	0	41	512	1738	2956
	CDH80	7563	2733	1584	767	58	0	0	0	0	7	166	794	1454
Wind	WSAvg	7.9	9.2	8.5	8.0	6.9	6.8	6.4	7.1	7.3	8.1	8.3	9.1	9.4
Precipitation	PrecAvg	21.2	1.5	1.2	1.3	1.6	2.2	1.7	2.1	2.3	2.0	1.9	1.5	1.7
	PrecMax	42.0	6.2	6.4	4.5	5.7	6.3	4.8	5.0	5.2	4.6	7.4	4.9	6.2
	PrecMin	9.4	0.0	0.0	0.0	0.2	0.1	0.2	0.2	0.4	0.3	0.4	0.1	0.0
	PrecStd	7.4	1.4	1.6	1.1	1.3	1.5	1.1	1.3	1.2	1.1	1.7	1.1	1.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	107.8	105.2	97.7	85.9	73.1	64.2	62.7	67.8	79.5	91.8	98.6	103.8
		MCWB	68.2	70.2	66.3	62.9	57.8	54.8	54.6	55.7	57.4	61.1	64.4	65.7
	2%	DB	103.2	98.3	92.3	81.0	69.1	61.1	59.1	63.4	72.4	84.3	93.3	97.6
		MCWB	67.7	67.0	65.6	61.1	56.9	52.8	52.7	53.6	57.4	59.9	63.6	65.2
	5%	DB	98.2	93.4	87.9	77.5	66.0	58.7	56.8	60.3	68.1	79.7	88.9	92.6
		MCWB	67.3	66.4	64.7	59.9	55.9	52.1	51.5	52.0	55.1	59.3	62.4	63.8
	10%	DB	93.4	89.4	84.0	74.2	63.2	56.6	54.7	57.5	64.7	75.0	84.1	88.3
		MCWB	65.7	65.0	62.9	58.8	54.6	51.3	50.2	50.8	53.9	57.8	61.1	63.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.4	75.2	72.5	66.0	62.0	57.1	57.3	57.3	62.1	66.6	70.3	73.5
		MCDB	88.8	90.9	83.2	76.5	66.4	59.6	59.2	63.2	71.1	78.4	87.3	83.0
	2%	WB	71.7	71.8	69.3	63.9	59.1	55.0	54.0	55.0	59.3	63.7	67.4	69.8
		MCDB	87.9	82.4	82.3	74.3	65.2	58.3	57.1	61.4	68.0	75.8	80.6	80.9
	5%	WB	70.0	70.0	67.3	62.1	57.3	53.5	52.2	53.1	57.0	61.7	65.4	67.3
		MCDB	87.2	82.7	81.2	72.3	63.4	57.3	55.6	58.7	65.4	73.6	79.1	83.1
	10%	WB	68.5	68.0	65.4	60.5	55.7	52.0	50.6	51.4	54.9	59.6	63.6	65.5
		MCDB	87.2	83.1	79.7	71.2	61.7	55.6	54.1	56.8	63.0	72.1	77.9	83.0
Mean Daily Temperature Range	5% DB	MDBR	28.7	26.3	25.2	23.3	19.9	17.3	15.5	19.0	23.4	27.1	27.9	27.9
		MCDBR	34.2	31.5	29.6	27.8	23.3	20.3	18.0	23.5	29.5	34.6	34.3	34.0
		MCWBR	9.7	10.1	10.2	11.6	12.5	13.0	11.9	14.5	15.5	14.4	11.2	10.5
	5% WB	MCDBR	26.6	22.8	23.6	22.2	18.7	16.7	15.5	20.0	25.3	27.1	26.0	24.8
		MCWBR	9.7	8.8	9.9	10.3	10.9	11.6	11.0	13.2	15.0	13.7	10.2	10.0
Clear-Sky Solar Irradiance	taub	0.347	0.345	0.321	0.312	0.301	0.295	0.289	0.297	0.326	0.327	0.344	0.339	
	taud	2.470	2.495	2.557	2.546	2.554	2.571	2.587	2.542	2.446	2.470	2.463	2.486	
	Ebn at Noon	313	307	303	286	272	265	274	288	296	309	312	317	
	Edh at Noon	37	35	30	27	23	21	22	26	33	35	37	37	
All-Sky Solar Radiation	RadAvg	2451	2154	1791	1288	890	684	741	1034	1464	1922	2221	2458	
	RadStd	137	124	89	61	57	74	42	80	129	151	117	102	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (25 neighbors)	+0.79	N/A	N/A	+1.89	N/A	N/A	N/A	N/A	+250	+162

Nomenclature: See separate page