

EILDON FIRE TOWER, Australia

WMO: 948810

Lat: 37.209S

Lon: 145.842E

Elev: 2090

StdP: 13.62

Time Zone: 10.00 (AUS)

Period: 96-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	34.7	36.1	28.0	23.7	56.4	30.2	26.3	49.5	31.0	42.1	27.1	42.7	11.2	260	0.603

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.7	90.7	63.1	86.8	62.3	83.4	61.3	67.1	79.7	65.4	78.8	64.0	77.5	11.0	50

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.8	95.8	69.5	61.3	87.6	69.0	59.3	81.5	68.0	32.8	79.5	31.4	78.5	30.3	77.8	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.8	23.3	20.7	DB	32.2	97.5	1.0	3.4	31.4	99.9	30.8	101.9	30.2	103.8	29.5	106.3	(4)
(5)			WB	31.2	69.7	1.0	2.2	30.5	71.2	29.9	72.5	29.4	73.7	28.7	75.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	55.0	67.9	67.4	63.0	56.2	49.5	45.1	43.6	44.7	48.6	53.3	58.8	62.9	(6)
(7)		DBStd	10.61	8.31	7.68	7.52	6.16	4.78	3.61	3.23	3.96	5.04	6.67	7.90	8.14	(7)
(8)		HDD50	749	0	0	2	16	68	151	201	173	85	38	11	4	(8)
(9)		HDD65	4118	63	59	130	270	481	596	665	631	492	370	221	140	(9)
(10)		CDD50	2574	556	488	404	200	52	5	1	7	43	139	275	404	(10)
(11)		CDD65	469	154	126	68	5	0	0	0	0	0	6	35	75	(11)
(12)		CDH74	4614	1726	1181	544	19	0	0	0	0	0	39	306	799	(12)
(13)		CDH80	1617	713	410	147	1	0	0	0	0	0	3	72	271	(13)
(14)	Wind	WSAvg	10.6	11.4	10.5	10.3	9.6	9.7	9.7	10.4	10.7	11.4	11.2	11.3	11.1	(14)
(15)	Precipitation	PrecAvg	31.1	1.9	2.0	1.9	2.1	2.4	3.8	3.5	3.4	3.1	2.6	2.4	1.9	(15)
(16)		PrecMax	49.6	4.9	6.1	5.2	4.4	5.3	6.8	6.5	6.3	6.4	5.6	5.4	4.8	(16)
(17)		PrecMin	15.4	0.0	0.0	0.5	0.6	0.0	1.3	0.9	0.7	0.7	0.3	0.7	0.1	(17)
(18)		PrecStd	7.2	1.5	1.7	1.1	1.1	1.4	1.5	1.4	1.7	1.5	1.3	1.2	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.3	94.1	89.7	76.7	65.5	57.4	54.8	60.2	68.8	79.4	86.4	93.3	(19)
(20)			MCWB	63.9	65.0	61.3	57.3	53.8	50.8	48.6	51.4	54.2	58.2	60.8	62.2	(20)
(21)		2%	DB	92.0	88.5	84.1	72.3	61.4	54.4	51.9	56.2	63.7	73.6	81.5	87.1	(21)
(22)			MCWB	64.1	63.2	61.0	56.9	52.9	49.3	47.4	49.7	53.5	56.4	60.0	60.9	(22)
(23)		5%	DB	87.1	85.0	79.9	69.3	58.9	52.4	49.9	53.4	60.4	69.4	77.2	82.2	(23)
(24)			MCWB	62.6	62.7	60.1	55.8	52.1	48.2	46.3	47.6	52.1	55.1	58.6	60.0	(24)
(25)		10%	DB	83.2	81.5	76.1	66.3	56.6	50.6	48.4	51.1	57.4	65.4	73.1	78.0	(25)
(26)			MCWB	61.7	61.6	59.1	54.6	50.8	46.9	45.3	46.3	50.4	54.1	57.4	58.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.4	70.0	66.5	61.5	57.3	52.9	50.6	53.1	57.7	62.1	65.9	66.5	(27)
(28)			MCDWB	81.4	80.7	77.8	70.2	60.3	54.8	52.2	57.8	63.0	72.6	76.8	78.0	(28)
(29)		2%	WB	67.2	67.0	64.1	58.8	54.6	50.5	48.5	50.4	55.2	58.8	62.8	64.2	(29)
(30)			MCDWB	81.0	79.2	75.6	67.9	58.7	53.1	50.6	54.7	61.6	67.5	74.9	76.6	(30)
(31)		5%	WB	65.5	65.3	62.5	57.2	53.1	48.8	46.9	48.4	53.0	57.1	61.0	62.3	(31)
(32)			MCDWB	80.7	78.1	74.4	65.4	57.5	51.3	49.1	52.4	59.2	65.3	72.9	76.2	(32)
(33)		10%	WB	63.8	63.8	60.8	55.9	51.5	47.5	45.6	46.7	51.0	55.2	59.1	60.7	(33)
(34)			MCDWB	79.4	76.7	72.3	64.2	55.9	49.9	47.8	50.6	56.8	63.7	69.9	74.5	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	22.7	21.3	18.6	14.6	10.0	8.0	7.7	9.5	12.7	16.1	19.2	21.2	(35)
(36)			MCDBR	26.5	24.7	22.5	18.2	12.9	10.7	9.9	12.9	16.4	21.1	23.6	25.9	(36)
(37)			MCWBR	8.6	8.0	7.8	8.0	7.6	7.5	6.9	8.4	9.8	10.6	9.6	8.7	(37)
(38)		5% WB	MCDWB	23.1	21.2	18.8	15.6	11.1	8.9	8.5	11.5	14.6	18.2	20.3	21.4	(38)
(39)			MCWBR	8.9	8.8	8.2	7.8	7.3	6.8	6.4	8.0	9.6	10.7	10.2	9.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.324	0.325	0.304	0.297	0.283	0.275	0.273	0.282	0.306	0.308	0.319	0.319	(40)	
(41)		taud	2.548	2.553	2.613	2.597	2.619	2.635	2.642	2.605	2.522	2.548	2.543	2.555	(41)	
(42)		Ebn at Noon	320	313	308	291	278	271	279	292	302	315	320	324	(42)	
(43)		Edh at Noon	34	33	28	25	21	19	21	24	30	32	34	34	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2316	2020	1643	1152	764	585	640	907	1295	1737	2049	2286	(44)	
(45)		RadStd	142	122	92	70	53	63	39	72	114	155	122	122	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (41 neighbors)		+0.90	N/A	N/A	+1.58	N/A	N/A	-32	-225	+313	+119

Nomenclature: See separate page