

POUND CREEK, Australia

WMO: 948860

Lat: 38.6297S

Lon: 145.8108E

Elev: 4

StdP: 101.28

Time Zone: 10.00 (AUS)

Period: 07-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.8	3.0	0.9	4.0	3.4	2.0	4.4	5.4	13.0	10.5	11.5	10.9	0.8	0	0.541

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	11.3	32.9	20.6	29.9	19.9	27.4	19.4	22.1	28.9	21.1	27.4	20.2	25.7	4.9	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
20.2	14.8	24.0	19.1	13.9	23.3	18.2	13.1	22.3	65.0	29.4	61.2	27.4	57.9	25.6	28.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.2	9.9	8.9	-0.7	39.3	1.1	2.3	-1.5	40.9	-2.1	42.2	-2.8	43.5	-3.6	45.1		
(5)			-0.9	25.1	1.2	1.7	-1.7	26.4	-2.4	27.4	-3.1	28.3	-4.0	29.6	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	18.5	18.7	17.5	14.8	12.3	10.2	9.9	10.3	11.8	13.1	15.1	16.6	(6)	(7)
	DBStd	4.22	3.88	3.20	3.45	2.80	2.32	1.99	1.92	1.90	2.29	2.97	3.32	3.50	(7)	(8)
	HDD10.0	77	0	0	0	1	4	21	24	18	6	3	0	0	(8)	(9)
	HDD18.3	1734	44	31	58	111	186	243	260	249	196	165	111	80	(9)	(10)
	CDD10.0	1557	263	244	234	146	77	28	23	28	59	100	152	203	(10)	(11)
	CDD18.3	172	49	41	33	6	1	0	0	0	4	13	25	25	(11)	(12)
	CDH23.3	1832	554	374	321	60	2	0	0	0	4	63	150	303	(12)	(13)
	CDH26.7	713	264	132	121	12	0	0	0	0	13	43	129	129	(13)	(14)
(14) Wind	WSAvg	4.0	4.3	4.4	4.0	3.5	3.8	3.3	4.1	4.2	4.2	4.2	4.3	4.2	(14)	(15)
(15) Precipitation	PrecAvg	913	44	38	59	77	98	93	103	104	92	88	67	64	(15)	(16)
	PrecMax	1185	100	188	187	166	254	190	193	168	196	166	137	138	(16)	(17)
	PrecMin	562	2	1	6	14	21	37	32	29	18	26	18	10	(17)	(18)
	PrecStd	154	22	39	37	39	45	41	47	34	38	40	29	36	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.3	34.3	34.8	28.2	22.6	17.3	17.4	19.1	23.6	28.5	30.5	34.8	(19)	(20)
		MCWB	21.7	21.1	20.4	17.9	15.0	13.0	12.0	12.6	15.8	17.5	20.1	21.3	(20)	(21)
	2%	DB	33.2	30.2	29.9	25.0	19.9	16.0	15.7	17.1	20.9	24.9	27.5	30.7	(21)	(22)
		MCWB	20.9	20.1	19.4	18.0	14.3	12.7	11.7	12.2	14.1	16.9	19.6	20.4	(22)	(23)
	5%	DB	29.1	27.8	26.7	22.4	18.1	15.0	14.4	15.3	18.5	22.3	24.5	26.5	(23)	(24)
		MCWB	20.4	19.9	18.6	16.5	13.7	12.3	10.9	11.2	13.4	15.9	18.7	19.5	(24)	(25)
	10%	DB	25.7	25.3	24.0	20.1	16.5	14.0	13.4	13.8	16.6	19.6	21.6	23.2	(25)	(26)
		MCWB	19.6	19.1	18.0	15.8	13.2	11.5	10.5	10.6	12.4	15.0	17.5	18.4	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.1	22.6	22.2	19.8	16.1	14.5	13.9	14.1	16.5	19.4	22.1	23.1	(27)	(28)
		MCDB	30.0	29.4	28.6	24.9	19.7	15.6	15.8	18.1	22.5	23.7	28.3	30.1	(28)	(29)
	2%	WB	22.3	21.5	20.4	18.1	15.1	13.3	12.3	12.7	14.8	17.9	20.3	21.2	(29)	(30)
		MCDB	30.1	27.2	26.2	22.1	18.3	15.2	14.4	15.7	19.4	23.4	25.5	27.2	(30)	(31)
	5%	WB	21.0	20.5	19.4	17.1	14.3	12.5	11.5	11.7	13.8	16.5	19.0	19.9	(31)	(32)
		MCDB	28.3	25.6	25.1	20.8	17.2	14.5	13.5	14.3	17.7	21.6	23.7	25.8	(32)	(33)
	10%	WB	19.8	19.6	18.4	16.2	13.5	11.8	10.8	11.0	12.9	15.1	17.7	18.6	(33)	(34)
		MCDB	25.6	24.2	23.5	19.3	16.0	13.6	12.8	13.3	16.0	19.1	21.4	23.1	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.3	10.9	10.7	9.7	7.7	7.4	6.8	6.9	8.1	9.8	9.7	10.4	(35)	(36)
		MCDBR	18.2	16.0	16.0	13.7	10.5	9.4	8.5	9.6	12.2	15.5	15.9	17.6	(36)	(37)
	5% WB	MCWBR	8.0	7.3	7.6	7.2	6.4	6.8	5.7	5.7	6.9	8.8	8.9	8.8	(37)	(38)
		MCWBR	16.6	13.1	13.9	11.4	9.3	8.7	7.2	8.4	10.8	14.3	14.5	14.8	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub		0.362	0.362	0.343	0.335	0.318	0.311	0.309	0.322	0.349	0.345	0.351	0.347	(39)	(40)
		taud	2.476	2.490	2.541	2.542	2.569	2.575	2.574	2.529	2.448	2.477	2.484	2.514	(40)	(41)
	Ebn at Noon		969	945	923	865	819	795	822	866	900	951	974	989	(41)	(42)
		Edh at Noon	115	109	95	83	70	64	68	82	103	109	114	112	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg		6.97	6.05	4.77	3.32	2.20	1.76	1.98	2.81	4.00	5.36	6.29	6.99	(43)	(44)
	RadStd		0.43	0.32	0.27	0.17	0.11	0.12	0.09	0.13	0.25	0.35	0.35	0.40	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (29 neighbors)	+0.51	N/A	N/A	+0.83	+0.41	N/A	-16	-140	+180	+59

Nomenclature: See separate page