

WILSONS PROMONTORY LH, AustraliaWMO: **948930**Lat: **39.130S**Lon: **146.424E**Elev: **318**StdP: **14.53**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	45.6	46.7	32.7	27.5	55.0	34.6	29.7	52.9	55.9	50.8	50.5	50.1	23.8	270	0.871

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.6	83.8	63.8	78.1	62.5	73.7	61.9	68.0	73.7	66.7	71.7	65.5	70.0	15.8	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	99.2	68.7	65.3	94.7	67.9	64.0	90.3	67.0	32.6	73.9	31.5	71.8	30.5	70.2	74.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 50.1	44.6	40.2	DB	42.4	95.0	1.6	5.1	41.2	98.7	40.3	101.6	39.4	104.5	38.2	108.2	(4)
(5)			WB	39.6	70.7	1.2	2.0	38.7	72.1	38.0	73.3	37.4	74.4	36.5	75.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.8	64.0	64.6	62.8	59.8	56.5	53.3	51.8	51.9	53.7	55.9	58.3	60.9
	DBStd	6.11	5.28	4.67	4.61	4.12	3.40	2.67	2.52	3.25	4.02	4.85	4.96	5.06
	HDD50	31	0	0	0	0	0	3	9	13	5	1	0	0
	HDD65	2830	81	56	99	167	265	352	408	405	339	290	216	152
	CDD50	2864	433	410	398	294	202	101	66	73	117	183	248	339
	CDD65	187	49	46	32	10	1	0	0	0	2	7	14	26
	CDH74	995	322	174	137	37	0	0	0	0	6	60	93	166
	CDH80	352	144	56	47	3	0	0	0	0	0	14	29	59
Wind	WSAvg	19.8	20.6	21.2	20.3	19.0	19.3	18.7	19.0	19.0	19.9	19.9	20.1	21.2
Precipitation	PrecAvg	42.8	2.2	1.7	2.5	3.3	5.2	4.5	5.5	5.1	4.2	3.5	2.7	2.4
	PrecMax	58.7	7.0	6.6	6.4	7.7	13.7	9.4	13.3	13.9	8.7	8.7	6.3	5.3
	PrecMin	25.9	0.2	0.1	0.3	0.5	1.4	1.6	0.9	1.4	0.2	1.0	0.4	0.2
	PrecStd	8.0	1.5	1.3	1.6	1.7	2.8	1.7	2.6	2.4	1.7	1.7	1.2	1.3
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.7	87.5	86.0	78.8	71.1	63.9	62.7	67.9	73.6	81.5	84.1	88.2
		MCWB	66.1	65.7	64.3	61.2	55.2	54.8	50.5	54.1	57.3	59.2	63.0	64.4
	2%	DB	82.5	79.4	76.5	73.1	67.4	60.4	59.2	62.2	68.2	73.5	74.6	78.7
		MCWB	64.8	64.0	62.6	58.6	55.5	53.8	50.7	51.2	54.2	56.9	59.9	61.6
	5%	DB	74.8	73.3	71.5	68.0	63.8	58.4	57.0	59.1	63.2	67.3	68.7	71.7
		MCWB	64.5	65.2	64.0	58.7	55.4	52.9	50.2	50.8	53.5	55.8	59.1	62.1
	10%	DB	69.8	69.8	68.3	64.5	61.2	56.9	55.4	56.5	59.0	62.1	64.0	66.9
		MCWB	64.1	65.2	63.2	59.4	55.5	52.2	50.1	50.3	52.5	55.5	59.2	61.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.1	70.1	68.4	64.1	60.0	57.8	54.4	55.3	59.2	61.8	65.9	67.5
		MCDB	80.3	73.6	73.2	67.8	62.0	59.4	56.6	59.9	68.4	72.0	74.3	75.7
	2%	WB	67.6	68.2	66.6	62.4	58.6	55.8	53.3	53.8	56.4	59.3	62.9	64.9
		MCDB	75.8	72.0	70.9	66.2	61.5	58.4	55.4	58.1	62.8	66.7	69.2	71.3
	5%	WB	66.0	67.0	65.2	61.0	57.5	54.3	52.3	52.6	54.7	57.7	61.1	63.4
		MCDB	72.3	70.5	69.2	64.9	61.3	57.0	54.9	56.5	59.9	63.5	65.6	68.3
	10%	WB	64.6	65.8	63.8	59.8	56.4	53.1	51.3	51.3	53.3	56.2	59.6	61.9
		MCDB	69.3	69.1	67.8	63.8	60.5	56.0	54.4	55.1	58.1	61.3	63.7	66.4
Mean Daily Temperature Range	5% DB	MDBR	8.7	7.6	6.9	6.1	5.1	4.4	4.8	5.9	7.1	8.2	8.0	8.4
		MCDBR	20.1	16.1	14.6	13.1	9.0	6.5	7.2	10.6	14.9	18.1	17.7	18.6
		MCWBR	7.8	7.5	7.4	6.1	4.9	4.7	4.2	5.3	6.9	7.9	8.2	8.1
	5% WB	MCDBR	14.1	11.1	10.9	8.9	6.4	4.9	4.9	8.1	11.2	13.7	12.8	13.6
		MCWBR	7.6	6.7	6.6	5.6	4.9	4.6	4.4	5.2	6.5	7.6	7.2	7.5
Clear-Sky Solar Irradiance	taub	0.358	0.357	0.337	0.329	0.312	0.305	0.304	0.316	0.342	0.339	0.343	0.344	
	taud	2.511	2.531	2.583	2.583	2.607	2.612	2.615	2.579	2.500	2.528	2.539	2.547	
	Ebn at Noon	308	301	294	276	262	254	262	277	287	304	312	314	
	Edh at Noon	35	33	29	25	21	19	21	25	31	33	34	34	
All-Sky Solar Radiation	RadAvg	2212	1917	1497	1039	691	551	621	891	1279	1711	2025	2247	
	RadStd	139	95	81	54	33	39	28	41	84	107	116	130	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.86	N/A	+1.21	N/A	+0.72	+0.83	N/A	N/A	N/A	N/A
(47) Regional (18 neighbors)		+0.90	N/A	N/A	+1.28	+0.77	N/A	-23	-229	+299	+101

Nomenclature: See separate page