

WILSONS PROMONTORY LH, AustraliaWMO: **948930**Lat: **39.130S**Lon: **146.424E**Elev: **97**StdP: **100.17**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	7.5	8.2	0.4	3.9	12.8	1.5	4.2	11.6	25.0	10.4	22.6	10.1	10.6	270	0.871

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.2	28.8	17.6	25.6	17.0	23.2	16.6	20.0	23.2	19.3	22.0	18.6	21.1	7.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
19.2	14.2	20.4	18.5	13.5	19.9	17.8	12.9	19.5	57.8	23.3	55.3	22.1	53.1	21.2	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.4	19.9	18.0	DB	5.8	35.0	0.9	2.8	5.1	37.0	4.6	38.7	4.1	40.3	3.4	42.3	(4)
(5)			WB	4.2	21.5	0.7	1.1	3.7	22.3	3.4	22.9	3.0	23.5	2.5	24.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.3	17.8	18.1	17.1	15.4	13.6	11.8	11.0	11.1	12.1	13.3	14.6	16.1	(6)	
	DBStd	3.40	2.93	2.59	2.56	2.29	1.89	1.48	1.40	1.80	2.24	2.70	2.75	2.81	(7)	
	HDD10.0	17	0	0	0	0	0	2	5	7	3	1	0	0	(8)	
	HDD18.3	1572	45	31	55	93	147	196	227	225	188	161	120	84	(9)	
	CDD10.0	1591	241	228	221	163	112	56	37	41	65	102	138	188	(10)	
	CDD18.3	104	27	26	18	6	1	0	0	0	1	4	8	14	(11)	
	CDH23.3	553	179	97	76	21	0	0	0	0	3	33	52	92	(12)	
(13)	CDH26.7	196	80	31	26	2	0	0	0	0	0	8	16	33	(13)	
(14)	Wind	WSAvg	8.9	9.2	9.5	9.1	8.5	8.6	8.3	8.5	8.5	8.9	8.9	9.0	9.5	(14)
(15) Precipitation	PrecAvg	1088	57	42	64	83	133	115	139	129	106	90	68	61	(15)	
	PrecMax	1490	177	167	162	196	349	238	339	354	220	221	159	135	(16)	
	PrecMin	659	4	2	8	12	36	40	22	36	6	25	10	5	(17)	
	PrecStd	204	37	32	41	44	70	42	65	61	44	44	30	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.7	30.8	30.0	26.0	21.7	17.7	17.1	19.9	23.1	27.5	29.0	31.2	(19)	
		MCWB	19.0	18.7	17.9	16.2	12.9	12.6	10.3	12.3	14.1	15.1	17.2	18.0	(20)	
	2%	DB	28.0	26.3	24.7	22.8	19.7	15.8	15.1	16.8	20.1	23.0	23.7	25.9	(21)	
		MCWB	18.2	17.8	17.0	14.8	13.1	12.1	10.4	10.7	12.3	13.8	15.5	16.5	(22)	
	5%	DB	23.8	22.9	22.0	20.0	17.7	14.7	13.9	15.0	17.3	19.6	20.4	22.0	(23)	
		MCWB	18.1	18.4	17.8	14.8	13.0	11.6	10.1	10.4	11.9	13.2	15.1	16.7	(24)	
	10%	DB	21.0	21.0	20.2	18.1	16.2	13.8	13.0	13.6	15.0	16.7	17.8	19.4	(25)	
		MCWB	17.8	18.5	17.3	15.2	13.1	11.2	10.1	10.2	11.4	13.1	15.1	16.4	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.2	21.2	20.2	17.8	15.6	14.3	12.4	13.0	15.1	16.5	18.8	19.7	(27)	
		MCDB	26.8	23.1	22.9	19.9	16.7	15.2	13.7	15.5	20.2	22.2	23.5	24.3	(28)	
	2%	WB	19.8	20.1	19.2	16.9	14.8	13.2	11.8	12.1	13.6	15.2	17.2	18.3	(29)	
		MCDB	24.4	22.2	21.6	19.0	16.4	14.6	13.0	14.5	17.1	19.3	20.7	21.9	(30)	
	5%	WB	18.9	19.4	18.4	16.1	14.2	12.4	11.3	11.4	12.6	14.3	16.2	17.4	(31)	
		MCDB	22.4	21.4	20.7	18.3	16.3	13.9	12.7	13.6	15.5	17.5	18.7	20.2	(32)	
	10%	WB	18.1	18.8	17.6	15.4	13.5	11.7	10.7	10.7	11.8	13.4	15.3	16.6	(33)	
		MCDB	20.7	20.6	19.9	17.7	15.8	13.3	12.4	12.8	14.5	16.3	17.6	19.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	4.8	4.2	3.9	3.4	2.8	2.4	2.7	3.3	3.9	4.5	4.4	4.6	(35)	
		MCDBR	11.2	8.9	8.1	7.3	5.0	3.6	4.0	5.9	8.3	10.1	9.9	10.4	(36)	
	5% WB	MCWBR	4.3	4.2	4.1	3.4	2.7	2.6	2.4	2.9	3.8	4.4	4.5	4.5	(37)	
		MCWBR	7.8	6.2	6.0	4.9	3.6	2.7	2.7	4.5	6.2	7.6	7.1	7.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.358	0.357	0.337	0.329	0.312	0.305	0.304	0.316	0.342	0.339	0.343	0.344	(40)	
		taud	2.511	2.531	2.583	2.583	2.607	2.612	2.615	2.579	2.500	2.528	2.539	2.547	(41)	
	Ebn at Noon		972	949	928	871	826	801	827	873	906	957	982	991	(42)	
		Edh at Noon	111	104	91	79	67	61	65	78	97	103	107	108	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.97	6.04	4.72	3.27	2.18	1.74	1.96	2.81	4.03	5.39	6.38	7.08	(44)	
	RadStd		0.44	0.30	0.26	0.17	0.10	0.12	0.09	0.13	0.26	0.34	0.36	0.41	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.48	N/A	+0.67	N/A	+0.40	+0.46	N/A	N/A	N/A	N/A
(47)	Regional (18 neighbors)	+0.50	N/A	N/A	+0.71	+0.43	N/A	-13	-127	+166	+56

Nomenclature: See separate page