

CERBERUS, Australia

WMO: 948980

Lat: 38.3647S

Lon: 145.1786E

Elev: 45

StdP: 14.67

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	35.9	38.2	33.1	27.7	45.4	35.0	29.9	46.5	24.9	53.7	22.7	53.0	1.8	0	0.514

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	16.8	91.4	66.1	86.2	65.4	81.2	64.6	69.9	81.5	68.2	79.1	66.7	77.0	12.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.6	98.1	72.7	64.8	92.1	71.6	63.2	86.8	70.5	33.9	81.0	32.5	79.3	31.3	76.9	77.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.1	19.6	17.6	DB	31.5	101.5	2.0	4.8	30.0	105.0	28.9	107.8	27.7	110.5	26.3	114.1	(4)
(5)			WB	30.8	73.3	2.0	1.7	29.3	74.5	28.2	75.4	27.0	76.4	25.5	77.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.4	65.8	66.5	63.5	58.4	54.2	50.5	49.7	50.7	53.1	56.0	59.4	62.1		
	DBStd	7.74	6.70	6.10	5.94	4.98	4.07	3.81	3.51	3.78	4.40	5.24	5.86	6.41		
	HDD50	148	0	0	0	1	8	39	47	35	14	4	0	0		
	HDD65	3088	68	48	102	209	335	434	473	443	360	286	192	138		
	CDD50	2863	491	461	419	252	138	55	39	57	105	189	281	376		
	CDD65	330	93	90	56	10	0	0	0	0	1	7	23	50		
	CDH74	3178	888	746	485	89	1	0	0	0	11	124	273	561		
	CDH80	1303	426	304	181	17	0	0	0	0	0	30	88	257		
(14) Wind	WSAvg	8.1	8.8	8.4	7.9	7.0	7.2	7.3	8.3	8.4	8.4	8.3	8.3	8.6		
(15) Precipitation	PrecAvg	30.6	1.7	1.9	1.9	2.8	2.8	3.0	3.0	3.1	3.0	2.7	2.7	2.0		
	PrecMax	39.0	4.9	6.0	3.1	7.7	6.3	5.8	5.9	5.4	5.7	4.6	5.4	4.7		
	PrecMin	20.5	0.2	0.3	0.7	0.8	1.1	0.6	1.5	0.8	1.1	0.6	1.0	0.1		
	PrecStd	5.2	1.2	1.3	0.7	1.6	1.3	1.3	1.1	1.2	1.3	1.2	1.1	1.1		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.3	95.5	92.5	82.1	71.4	63.5	62.5	68.2	75.2	84.3	88.4	95.6		
		MCWB	68.5	67.2	65.3	60.9	57.4	54.9	52.3	55.0	58.0	61.1	64.8	66.1		
	2%	DB	90.8	88.9	85.0	76.0	67.2	60.6	59.3	63.6	69.3	77.0	81.8	87.8		
		MCWB	66.7	66.7	64.4	59.5	56.5	54.1	51.6	52.8	55.7	59.1	63.5	64.5		
	5%	DB	83.5	83.1	79.2	71.5	64.4	58.5	57.3	60.4	65.7	71.7	75.8	79.7		
		MCWB	66.5	66.5	63.8	59.5	55.7	53.1	50.8	51.8	54.8	58.4	62.4	64.0		
	10%	DB	77.1	77.6	73.9	67.3	61.5	56.9	55.7	57.7	62.1	66.5	70.2	73.4		
		MCWB	65.9	65.8	63.2	58.7	54.9	51.9	50.2	50.6	53.4	56.7	61.0	63.5		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.6	72.3	69.6	64.0	60.3	57.7	54.9	56.7	60.6	63.9	68.7	69.3		
		MCDB	83.7	83.9	82.1	74.2	65.7	60.5	59.0	63.6	68.9	74.9	80.5	83.9		
	2%	WB	70.1	69.8	67.1	62.2	58.4	55.2	53.1	54.3	57.8	61.4	65.6	67.1		
		MCDB	81.4	80.6	77.1	69.8	63.4	58.9	56.9	60.8	66.3	72.3	76.8	79.3		
	5%	WB	68.2	68.1	65.4	60.8	57.0	53.8	51.9	52.7	55.9	59.3	63.4	65.3		
		MCDB	79.9	77.6	74.7	67.9	62.4	57.5	55.7	58.3	63.3	68.9	72.9	76.8		
	10%	WB	66.3	66.5	63.8	59.4	55.7	52.6	50.8	51.4	54.1	57.4	61.4	63.4		
		MCDB	76.6	75.6	72.6	66.0	60.6	56.2	54.7	56.4	60.6	65.3	69.2	73.3		
(35) Mean Daily Temperature Range	5% DB	MDBR	17.1	16.8	16.8	16.0	13.2	11.9	11.4	12.8	14.7	16.3	16.1	17.4		
		MCDBR	31.4	28.4	27.6	23.8	18.1	13.9	13.2	17.8	22.0	27.2	28.2	31.4		
		MCWBR	10.5	10.3	10.3	10.8	10.1	9.1	8.1	9.6	10.8	12.2	12.5	12.3		
	5% WB	MCDBR	24.3	21.5	22.1	19.6	15.7	12.6	11.9	15.4	18.6	23.3	23.3	25.3		
		MCWBR	10.6	9.8	10.1	10.6	9.9	8.9	8.3	9.4	10.4	12.3	11.9	11.8		
(40) Clear-Sky Solar Irradiance	taub		0.358	0.358	0.336	0.333	0.319	0.308	0.310	0.322	0.343	0.344	0.350	0.346		
	taud		2.505	2.515	2.579	2.561	2.578	2.598	2.583	2.543	2.480	2.495	2.505	2.532		
	Ebn at Noon		309	301	295	276	260	254	261	275	288	302	310	314		
	Edh at Noon		36	34	29	26	22	20	22	26	32	34	35	35		
(44) All-Sky Solar Radiation	RadAvg		2234	1952	1538	1069	707	559	629	889	1273	1707	2000	2233		
	RadStd		134	96	85	56	36	40	28	48	79	120	109	125		

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		+1.13	N/A	N/A	N/A	N/A	N/A	-50	-358	+409	+90	(46)
(47) Regional (33 neighbors)		+0.90	N/A	N/A	+1.42	N/A	N/A	-31	-238	+313	+103	(47)

Nomenclature: See separate page