

FALLS CREEK, Australia

WMO: 949030

Lat: 36.8708S

Lon: 147.2756E

Elev: 5810

StdP: 11.86

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.1	22.6	-0.7	6.6	38.1	7.1	9.8	37.5	43.4	33.9	38.5	33.7	13.6	170	0.797

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	14.7	71.9	56.5	68.9	55.2	66.5	54.4	59.9	66.6	58.3	64.6	56.7	63.0	12.4	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
57.7	88.5	61.6	56.0	83.1	60.4	54.4	78.3	58.9	29.1	66.4	27.9	64.7	26.8	63.2	66.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 35.1	30.9	27.5	DB	18.1	76.0	1.5	3.2	17.0	78.4	16.1	80.2	15.2	82.0	14.1	84.4	(4)
(5)			WB	17.6	62.5	1.7	2.2	16.4	64.1	15.4	65.4	14.4	66.7	13.2	68.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	42.4	55.5	54.5	50.1	43.2	37.5	33.0	30.2	31.0	35.3	41.0	47.1	50.8		
	DBStd	10.79	7.76	7.10	7.03	6.24	5.43	4.61	3.64	4.74	5.64	7.23	7.85	7.43		
	HDD50	3431	38	36	86	213	388	510	614	588	441	290	144	83		
	HDD65	8276	303	298	463	655	853	960	1079	1053	891	742	536	443		
	CDD50	646	210	162	89	9	0	0	0	0	0	12	58	106		
	CDD65	16	10	4	1	0	0	0	0	0	0	0	0	1		
	CDH74	32	21	10	0	0	0	0	0	0	0	0	0	1		
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0		
	WSAvg	12.5	12.2	11.0	11.5	11.7	12.8	13.3	13.9	13.0	14.2	12.4	11.7	11.6		
	PrecAvg	44.1	2.9	2.9	2.6	2.4	3.3	5.1	4.8	4.9	4.9	4.2	3.7	3.0		
(15) Precipitation	PrecMax	59.6	8.7	10.9	7.0	6.3	8.8	10.0	8.9	11.1	10.9	8.7	7.4	7.6		
	PrecMin	20.0	0.0	0.0	0.1	0.0	0.4	1.8	0.0	1.1	0.7	0.4	1.1	0.4		
	PrecStd	9.2	2.0	2.4	1.6	1.5	2.2	2.1	2.0	2.4	2.1	2.4	1.7	1.6		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.9	75.7	70.3	60.4	53.1	48.1	42.6	46.7	53.0	62.3	69.3	71.9		
		MCWB	58.3	59.1	54.4	50.4	43.3	37.2	35.8	37.8	44.0	49.2	53.7	55.3		
	2%	DB	73.0	70.2	66.2	56.5	49.4	44.2	39.1	43.4	49.1	58.0	65.4	68.1		
		MCWB	57.2	56.6	53.4	48.1	42.4	36.9	33.9	37.0	41.6	47.6	52.4	54.6		
	5%	DB	69.8	67.4	63.1	53.9	47.1	41.7	37.2	40.5	46.4	54.9	61.9	64.8		
		MCWB	55.6	55.5	52.1	46.8	41.7	36.2	33.7	36.1	41.4	46.1	50.6	52.8		
	10%	DB	67.1	64.7	60.1	51.5	44.9	39.5	35.4	38.1	43.9	51.9	58.9	62.0		
		MCWB	54.8	54.5	51.3	45.8	40.8	35.5	33.3	34.9	39.7	45.0	49.4	51.8		
	0.4%	WB	62.4	62.2	58.7	53.0	48.5	43.1	39.8	42.4	46.5	53.0	57.6	59.0		
		MCDB	70.3	68.8	63.4	56.5	49.1	43.7	40.2	43.5	48.7	57.0	63.4	64.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	60.2	59.9	56.4	50.2	45.6	40.2	36.9	39.3	44.1	50.1	54.9	56.8		
		MCDB	68.1	65.7	61.1	54.2	47.0	41.5	37.6	40.8	47.0	54.4	60.8	63.7		
	5%	WB	58.6	58.2	54.7	48.4	43.8	38.4	35.3	37.3	42.2	48.1	53.0	55.0		
		MCDB	65.9	63.6	59.4	51.9	45.5	39.5	35.9	38.9	44.9	52.6	58.7	61.7		
	10%	WB	57.0	56.5	53.0	46.9	41.9	36.7	33.9	35.5	40.3	46.2	51.2	53.2		
		MCDB	64.1	61.9	58.0	50.4	43.8	38.0	34.7	37.3	42.9	50.6	56.7	59.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	14.7	13.8	12.7	10.3	8.0	6.6	5.9	7.0	9.2	12.2	13.4	14.4		
		MCDBR	15.6	15.2	15.0	12.3	10.6	9.7	8.4	10.0	11.8	14.5	15.0	15.3		
		MCWBR	9.3	9.6	9.5	8.8	9.2	8.7	7.4	8.4	9.4	10.0	10.2	9.8		
		MCDBR	13.8	12.7	12.0	10.2	8.8	7.7	6.6	8.4	10.7	12.9	13.1	13.8		
	5% WB	MCWBR	9.5	9.5	8.8	8.0	8.1	7.5	6.5	7.9	9.0	10.1	9.8	9.7		
(40) Clear-Sky Solar Irradiance	taub		0.330	0.292	0.264	0.259	0.246	0.238	0.237	0.244	0.262	0.269	0.279	0.294		
	taud		2.454	2.622	2.744	2.701	2.721	2.752	2.757	2.724	2.647	2.656	2.654	2.588		
	Ebn at Noon		318	325	323	307	295	290	296	309	318	329	333	332		
	Edh at Noon		37	30	25	23	19	17	18	22	27	29	30	33		
(44) All-Sky Solar Radiation	RadAvg		2292	1982	1652	1192	813	623	683	953	1361	1798	2070	2306		
	RadStd		147	149	116	77	56	64	43	76	138	159	137	122		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	+0.70	N/A	N/A	N/A	N/A	N/A	N/A	-121	+230	+101

Nomenclature: See separate page