

MOUNT HOTHAM AP, Australia

WMO: 949050

Lat: 37.0492S

Lon: 147.3347E

Elev: 4241

StdP: 12.58

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.3	27.0	11.5	11.6	40.7	16.5	14.8	39.7	32.9	39.1	29.5	38.0	4.3	320	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	22.1	80.7	59.5	77.3	58.0	74.2	56.9	62.3	73.2	60.8	71.3	59.3	69.5	12.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
59.3	88.4	64.5	57.5	82.5	63.7	55.7	77.4	61.8	30.1	73.8	28.9	71.7	27.8	69.6	68.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
25.5	21.6	18.7	DB	20.9	86.2	1.2	2.8	20.1	88.2	19.4	89.8	18.8	91.3	17.9	93.3
			WB	19.8	65.3	1.2	1.5	19.0	66.4	18.3	67.3	17.6	68.1	16.8	69.2

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	47.5	59.7	57.9	54.8	48.3	42.3	37.7	36.2	37.4	41.8	47.0	52.0	55.1
	DBStd	10.01	7.35	6.97	6.63	5.68	4.74	3.89	3.50	4.43	5.47	6.95	7.29	6.93
	HDD50	2067	10	13	28	97	242	369	429	390	254	143	63	29
	HDD65	6465	195	215	321	502	703	819	894	854	697	559	392	314
	CDD50	1139	310	234	178	45	4	0	0	0	7	49	124	188
	CDD65	63	30	16	6	0	0	0	0	0	0	0	3	8
	CDH74	722	358	181	53	0	0	0	0	0	0	0	32	98
	CDH80	127	72	37	2	0	0	0	0	0	0	0	2	14
(14) Wind	WSAvg	7.8	7.3	6.6	6.7	6.5	7.5	7.3	8.9	9.3	9.3	8.5	8.0	7.7
(15) Precipitation	PrecAvg	30.0	2.0	2.6	2.2	2.1	1.8	3.0	2.6	2.6	2.8	3.0	3.1	2.2
	PrecMax	41.9	6.1	6.6	5.7	4.8	3.4	6.3	6.0	5.2	4.7	5.9	5.8	4.6
	PrecMin	13.7	0.1	0.0	0.2	1.1	0.0	0.9	0.9	0.7	1.0	0.4	0.8	0.3
	PrecStd	7.2	1.3	2.1	1.4	1.0	0.9	1.5	1.2	1.3	0.9	1.6	1.3	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.9	85.3	78.8	69.2	60.5	54.3	50.2	57.5	63.4	71.7	78.2	82.4
		MCWB	60.3	61.3	58.0	54.3	47.1	43.0	40.8	41.8	46.9	51.8	55.8	59.1
	2%	DB	81.7	79.0	75.0	64.8	56.6	50.0	46.8	51.9	59.0	67.4	73.0	76.8
		MCWB	60.2	58.7	56.3	51.8	45.9	42.0	39.8	40.8	45.9	50.9	55.5	57.5
	5%	DB	77.9	75.3	71.3	62.0	53.8	47.4	44.6	48.5	55.5	63.7	69.8	72.9
		MCWB	58.6	57.8	55.4	50.4	45.4	41.6	38.9	40.5	44.2	49.3	54.1	55.9
	10%	DB	74.4	71.7	67.7	59.3	51.3	44.9	42.7	45.7	52.5	60.6	66.5	69.6
		MCWB	57.7	56.6	53.8	49.3	44.4	40.4	38.1	39.4	43.2	48.0	52.7	55.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.6	65.1	61.6	56.9	51.7	46.3	44.8	45.7	49.9	55.5	60.8	62.1
		MCDB	75.1	76.8	69.2	64.0	53.5	49.4	47.5	50.9	55.5	63.4	67.8	70.6
	2%	WB	62.6	62.3	59.4	53.9	48.2	44.1	41.9	43.1	47.6	53.0	58.2	59.7
		MCDB	75.1	72.2	68.2	61.6	53.7	47.6	44.6	49.0	55.9	61.6	67.8	70.6
	5%	WB	61.1	60.3	57.7	52.0	46.6	42.3	40.0	41.5	46.0	51.3	56.2	58.0
		MCDB	72.9	69.7	66.7	58.6	51.9	46.0	43.2	47.3	53.6	60.7	65.3	68.7
	10%	WB	59.6	58.5	56.0	50.4	44.9	40.9	38.5	39.7	44.1	49.6	54.4	56.5
		MCDB	71.1	67.0	64.4	57.4	50.0	44.5	41.9	44.9	51.5	58.6	63.5	66.7
(35) Mean Daily Temperature Range	5% DB	MDBR	22.1	21.3	19.8	17.6	14.5	12.1	11.2	13.2	16.5	19.2	20.2	21.1
		MCDBR	26.0	25.7	24.1	21.3	18.9	17.1	15.0	19.1	21.2	23.0	23.6	25.6
		MCWBR	11.5	11.2	11.1	11.3	11.8	11.4	10.4	11.6	12.4	11.9	11.5	12.6
	5% WB	MCDBR	22.1	19.4	18.9	17.3	14.7	13.9	11.8	15.9	18.0	19.5	19.4	21.1
		MCWBR	11.1	10.0	10.3	10.1	10.2	10.1	9.2	10.8	11.5	11.5	11.2	11.6
(40) Clear-Sky Solar Irradiance	taub		0.360	0.313	0.281	0.275	0.260	0.251	0.249	0.258	0.281	0.286	0.298	0.321
	taud		2.386	2.575	2.691	2.663	2.683	2.716	2.721	2.678	2.594	2.610	2.607	2.517
	Ebn at Noon		309	317	316	300	288	283	290	302	311	322	327	323
	Edh at Noon		40	32	26	23	20	18	19	23	28	30	32	36
(44) All-Sky Solar Radiation	RadAvg		2245	1939	1619	1171	807	623	691	960	1358	1777	2033	2268
	RadStd		150	149	118	79	51	58	41	70	130	149	142	128

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	-151	+239	+94

Nomenclature: See separate page