

MOUNT HOTHAM AP, Australia

WMO: 949050

Lat: 37.0492S

Lon: 147.3347E

Elev: 1293

StdP: 86.73

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-3.7	-2.8	-11.4	1.7	4.9	-8.6	2.1	4.3	14.7	3.9	13.2	3.3	1.9	320	0.617

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.3	27.1	15.3	25.1	14.5	23.5	13.8	16.8	22.9	16.0	21.9	15.2	20.8	5.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.2	12.6	18.0	14.1	11.8	17.6	13.2	11.1	16.6	52.1	23.2	49.4	22.0	46.8	20.9	20.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.4	9.7	8.4	-6.2	30.1	0.6	1.5	-6.6	31.2	-7.0	32.1	-7.4	33.0	-7.8	34.1
			-6.8	18.5	0.7	0.8	-7.2	19.1	-7.6	19.6	-8.0	20.1	-8.5	20.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	8.6	15.4	14.4	12.7	9.0	5.7	3.2	2.3	3.0	5.4	8.3	11.1	12.9
	DBStd	5.56	4.08	3.87	3.68	3.16	2.63	2.16	1.94	2.46	3.04	3.86	4.05	3.85
	HDD10.0	1148	6	7	16	54	134	205	238	217	141	79	35	16
	HDD18.3	3592	108	119	178	279	391	455	497	474	387	311	218	174
	CDD10.0	633	172	130	99	25	2	0	0	0	4	27	69	104
	CDD18.3	35	17	9	3	0	0	0	0	0	0	0	2	4
	CDH23.3	401	199	101	29	0	0	0	0	0	0	0	18	54
	CDH26.7	71	40	21	1	0	0	0	0	0	0	0	1	8
Wind	WSAvg	3.5	3.3	3.0	3.0	2.9	3.4	3.3	4.0	4.2	4.1	3.8	3.6	3.4
Precipitation	PrecAvg	763	52	66	56	53	46	75	65	66	72	76	78	55
	PrecMax	1065	154	167	146	123	87	161	152	133	119	151	148	116
	PrecMin	348	2	0	6	27	0	23	22	19	25	11	20	7
	PrecStd	182	33	53	35	25	24	38	30	32	22	41	33	31
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.9	29.6	26.0	20.7	15.8	12.4	10.1	14.2	17.4	22.1	25.7	28.0
		MCWB	15.7	16.3	14.4	12.4	8.4	6.1	4.9	5.5	8.3	11.0	13.2	15.1
	2%	DB	27.6	26.1	23.9	18.2	13.6	10.0	8.2	11.1	15.0	19.7	22.8	24.9
		MCWB	15.6	14.8	13.5	11.0	7.7	5.6	4.3	4.9	7.7	10.5	13.1	14.2
	5%	DB	25.5	24.0	21.8	16.7	12.1	8.5	7.0	9.2	13.1	17.6	21.0	22.7
		MCWB	14.8	14.3	13.0	10.2	7.5	5.3	3.8	4.7	6.8	9.6	12.3	13.3
	10%	DB	23.5	22.0	19.9	15.1	10.7	7.2	5.9	7.6	11.4	15.9	19.2	20.9
		MCWB	14.3	13.7	12.1	9.6	6.9	4.7	3.4	4.1	6.2	8.9	11.5	12.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	18.1	18.4	16.5	13.8	10.9	7.9	7.1	7.6	10.0	13.0	16.0	16.7
		MCDB	23.9	24.9	20.7	17.8	12.0	9.7	8.6	10.5	13.1	17.4	19.9	21.4
	2%	WB	17.0	16.8	15.2	12.2	9.0	6.7	5.5	6.2	8.7	11.7	14.5	15.4
		MCDB	23.9	22.4	20.1	16.4	12.1	8.7	7.0	9.5	13.3	16.5	19.9	21.4
	5%	WB	16.2	15.7	14.3	11.1	8.1	5.7	4.5	5.3	7.8	10.7	13.5	14.5
		MCDB	22.7	20.9	19.3	14.8	11.0	7.8	6.2	8.5	12.0	15.9	18.5	20.4
	10%	WB	15.3	14.7	13.4	10.2	7.2	4.9	3.6	4.3	6.7	9.8	12.4	13.6
		MCDB	21.7	19.4	18.0	14.1	10.0	6.9	5.5	7.2	10.8	14.8	17.5	19.3
Mean Daily Temperature Range	5% DB	MDBR	12.3	11.8	11.0	9.8	8.1	6.7	6.2	7.3	9.1	10.7	11.2	11.7
		MCDBR	14.4	14.3	13.4	11.8	10.5	9.5	8.3	10.6	11.8	12.8	13.1	14.2
	5% WB	MCWBR	6.4	6.2	6.2	6.3	6.5	6.3	5.8	6.5	6.9	6.6	6.4	7.0
		MCDBR	12.3	10.8	10.5	9.6	8.2	7.7	6.6	8.8	10.0	10.8	10.8	11.7
		MCWBR	6.2	5.5	5.7	5.6	5.6	5.6	5.1	6.0	6.4	6.4	6.2	6.5
Clear-Sky Solar Irradiance	taub	0.360	0.313	0.281	0.275	0.260	0.251	0.249	0.258	0.281	0.286	0.298	0.321	0.321
	taud	2.386	2.575	2.691	2.663	2.683	2.716	2.721	2.678	2.594	2.610	2.607	2.517	2.517
	Ebn at Noon	973	1000	997	946	908	893	914	953	980	1016	1031	1017	1017
	Edh at Noon	127	100	83	74	63	57	60	72	89	96	101	101	112
All-Sky Solar Radiation	RadAvg	7.08	6.11	5.11	3.69	2.54	1.96	2.18	3.03	4.28	5.60	6.41	7.15	7.15
	RadStd	0.47	0.47	0.37	0.25	0.16	0.18	0.13	0.22	0.41	0.47	0.45	0.40	0.40

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days		
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (30 neighbors)		+0.40	N/A	N/A	N/A	N/A	N/A	-84	+133	+52

Nomenclature: See separate page