

MOUNT HOTHAM SUMMIT, AustraliaWMO: **949060**Lat: **36.9767S**Lon: **147.1342E**Elev: **6066**StdP: **11.75**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	19.8	21.3	-9.3	4.2	35.3	0.3	7.0	35.9	48.3	34.3	43.6	32.4	8.4	310	0.900

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	70.1	54.0	67.2	53.0	64.6	52.4	58.3	63.7	56.4	62.5	54.7	61.0	16.1	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
56.6	85.6	60.1	54.4	79.0	57.9	52.5	73.5	56.3	28.1	63.9	26.7	62.6	25.5	61.0	66.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 44.2	38.9	33.7	DB	16.9	74.5	1.2	2.8	16.0	76.5	15.3	78.1	14.6	79.7	13.7	81.7	(4)
(5)			WB	16.3	60.0	1.2	1.9	15.4	61.4	14.7	62.6	14.1	63.6	13.2	65.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	40.6	53.9	52.9	48.4	41.9	35.9	31.1	28.4	29.2	33.2	38.9	45.0	49.2	
	DBStd	10.87	7.75	7.15	7.13	6.39	5.20	4.42	3.54	4.39	5.56	7.09	7.88	7.73	
	HDD50	3936	49	48	114	251	438	568	671	646	504	350	188	109	
	HDD65	8920	350	340	515	694	903	1018	1136	1111	954	809	599	491	
	CDD50	499	171	130	64	7	0	0	0	0	0	6	38	83	
	CDD65	9	6	2	0	0	0	0	0	0	0	0	0	1	
	CDH74	15	10	4	0	0	0	0	0	0	0	0	0	1	
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0	
Wind	WSAvg	14.5	15.2	14.2	15.1	15.7	16.8	12.8	9.8	11.8	16.3	15.7	15.7	15.6	
Precipitation	PrecAvg	50.0	3.1	3.0	2.9	3.3	3.9	5.9	5.2	5.7	5.0	4.6	3.9	3.3	
	PrecMax	69.9	8.0	13.4	7.4	6.9	10.4	11.4	10.3	12.9	12.1	10.6	8.1	8.1	
	PrecMin	20.6	0.1	0.0	0.0	0.6	0.1	1.7	0.0	1.1	0.8	0.2	1.4	0.2	
	PrecStd	11.1	2.0	2.9	1.9	1.7	2.8	2.3	2.3	2.9	2.4	3.0	2.0	1.8	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	75.2	73.0	68.3	58.6	50.3	44.6	39.7	44.1	50.4	59.4	67.1	71.3	
		MCWB	56.3	55.3	53.4	50.0	39.7	37.7	35.0	34.6	41.6	46.6	51.6	52.9	
	2%	DB	71.1	68.3	64.6	55.1	46.9	41.8	36.7	40.8	46.7	55.3	63.1	66.9	
		MCWB	54.3	54.2	52.6	47.5	39.3	35.3	33.5	35.0	40.5	44.7	49.8	52.6	
	5%	DB	68.0	65.3	61.3	52.4	44.7	39.7	34.9	37.9	44.3	52.0	59.6	63.5	
		MCWB	53.0	53.4	50.8	45.9	38.3	34.8	32.3	33.7	39.4	43.3	47.8	50.7	
	10%	DB	65.2	62.8	58.2	50.1	42.9	37.8	33.5	35.7	41.7	49.3	56.6	60.4	
		MCWB	52.5	52.3	49.4	44.3	38.0	33.7	31.0	32.3	37.5	42.1	46.7	49.7	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	60.0	61.2	61.8	53.6	44.9	41.7	38.0	39.5	44.7	50.2	55.8	57.5
			MCDB	66.2	67.0	64.7	55.8	46.0	41.9	38.3	41.6	46.2	54.1	61.5	63.7
2%		WB	57.6	58.3	56.3	50.4	42.7	39.0	35.1	36.8	42.5	47.2	52.7	54.8	
		MCDB	64.8	63.1	59.5	52.5	43.8	39.8	35.5	38.5	45.4	51.7	58.7	61.6	
5%		WB	56.1	56.4	53.1	47.5	41.1	36.9	33.5	35.0	40.4	45.4	50.4	53.2	
		MCDB	63.2	62.1	57.5	50.1	42.9	38.0	34.0	36.8	43.3	49.8	56.0	60.1	
10%		WB	54.5	54.5	51.1	45.5	39.4	35.1	32.1	33.1	38.4	43.5	48.5	51.4	
		MCDB	61.6	60.3	55.5	48.4	41.4	36.3	32.8	34.8	41.1	47.9	53.6	58.1	
Mean Daily Temperature Range	5% DB	MDBR	13.6	12.4	11.4	8.9	6.8	5.6	5.2	6.1	8.2	11.1	12.1	13.3	
		MCDBR	14.8	13.6	12.9	10.3	8.4	8.2	6.6	8.4	10.6	12.8	14.0	14.4	
		MCWBR	8.4	8.2	7.9	8.2	7.6	6.6	6.0	7.6	8.6	8.7	9.3	9.3	
	5% WB	MCDBR	12.2	11.4	10.7	8.3	7.3	6.3	5.5	7.3	9.4	11.3	12.3	12.9	
		MCWBR	8.6	8.3	8.2	7.3	7.1	6.1	5.6	7.2	8.5	9.1	9.1	9.5	
Clear-Sky Solar Irradiance	taub	0.319	0.288	0.262	0.258	0.244	0.236	0.235	0.242	0.261	0.267	0.277	0.295		
	taud	2.492	2.632	2.747	2.707	2.728	2.759	2.762	2.728	2.648	2.665	2.660	2.579		
	Ebn at Noon	322	325	324	307	295	290	297	309	318	330	334	331		
	Edh at Noon	36	30	25	23	19	17	18	22	27	29	30	33		
All-Sky Solar Radiation	RadAvg	2280	1972	1641	1181	807	620	682	952	1355	1786	2058	2294		
	RadStd	149	147	113	77	54	63	43	73	133	155	137	124		

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (34 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	-166	+248	+103	

Nomenclature: See separate page