

MOUNT HOTHAM SUMMIT, Australia

WMO: 949060

Lat: 36.9767S

Lon: 147.1342E

Elev: 1849

StdP: 81.00

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-6.8	-6.0	-22.9	0.6	1.8	-17.6	1.0	2.2	21.6	1.3	19.5	0.2	3.8	310	0.900

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.6	21.2	12.2	19.5	11.7	18.1	11.3	14.6	17.6	13.6	17.0	12.6	16.1	7.2	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
13.6	12.2	15.6	12.4	11.3	14.4	11.4	10.5	13.5	47.5	17.7	44.3	17.0	41.5	16.1	19.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 19.8	17.4	15.1	DB	-8.4	23.6	0.7	1.5	-8.9	24.7	-9.3	25.6	-9.7	26.5	-10.2	27.6	(4)
(5)			WB	-8.7	15.6	0.7	1.1	-9.2	16.3	-9.6	17.0	-10.0	17.6	-10.4	18.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	4.8	12.2	11.6	9.1	5.5	2.2	-0.5	-2.0	-1.6	0.7	3.8	7.2	9.5	(6)	
	DBStd	6.04	4.30	3.97	3.96	3.55	2.89	2.46	1.96	2.44	3.09	3.94	4.38	4.30	(7)	
	HDD10.0	2187	27	27	63	139	243	316	373	359	280	194	104	61	(8)	
	HDD18.3	4956	194	189	286	386	502	566	631	617	530	449	333	273	(9)	
	CDD10.0	277	95	72	36	4	0	0	0	0	0	3	21	46	(10)	
	CDD18.3	5	3	1	0	0	0	0	0	0	0	0	0	1	(11)	
	CDH23.3	8	6	2	0	0	0	0	0	0	0	0	0	1	(12)	
	CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)	
	Wind	WSAvg	6.5	6.8	6.4	6.7	7.0	7.5	5.7	4.4	5.3	7.3	7.0	7.0	(14)	
(15) Precipitation	PrecAvg	1269	80	77	73	84	100	151	132	146	127	118	98	83	(15)	
	PrecMax	1775	202	340	188	175	263	290	261	327	308	269	205	206	(16)	
	PrecMin	522	3	0	0	14	2	44	0	29	20	5	36	5	(17)	
	PrecStd	282	50	73	48	43	71	58	59	74	60	76	50	46	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.0	22.8	20.2	14.8	10.2	7.0	4.3	6.7	10.2	15.2	19.5	21.8	(19)	
		MCWB	13.5	13.0	11.9	10.0	4.3	3.2	1.7	1.4	5.4	8.1	10.9	11.6	(20)	
	2%	DB	21.7	20.2	18.1	12.8	8.3	5.4	2.6	4.9	8.1	12.9	17.3	19.4	(21)	
		MCWB	12.4	12.3	11.4	8.6	4.0	1.8	0.8	1.7	4.7	7.1	9.9	11.5	(22)	
	5%	DB	20.0	18.5	16.3	11.3	7.1	4.3	1.6	3.3	6.8	11.1	15.4	17.5	(23)	
		MCWB	11.7	11.9	10.5	7.7	3.5	1.5	0.1	0.9	4.1	6.3	8.8	10.4	(24)	
	10%	DB	18.4	17.1	14.5	10.1	6.0	3.2	0.8	2.1	5.4	9.6	13.7	15.8	(25)	
		MCWB	11.4	11.3	9.7	6.8	3.3	0.9	-0.5	0.2	3.1	5.6	8.2	9.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	16.2	16.6	12.0	7.2	5.4	3.3	4.1	7.0	10.1	13.2	14.2	(27)	
		MCDB	19.0	19.5	18.2	13.2	7.8	5.5	3.5	5.3	7.9	12.3	16.4	17.6	(28)	
	2%	WB	14.2	14.6	13.5	10.2	6.0	3.9	1.7	2.7	5.8	8.4	11.5	12.7	(29)	
		MCDB	18.2	17.3	15.3	11.4	6.6	4.3	2.0	3.6	7.4	10.9	14.9	16.4	(30)	
	5%	WB	13.4	13.6	11.7	8.6	5.1	2.7	0.8	1.7	4.7	7.4	10.2	11.8	(31)	
		MCDB	17.4	16.7	14.2	10.0	6.1	3.3	1.1	2.7	6.3	9.9	13.3	15.6	(32)	
	10%	WB	12.5	12.5	10.6	7.5	4.1	1.7	0.0	0.6	3.5	6.4	9.2	10.8	(33)	
		MCDB	16.5	15.7	13.1	9.1	5.2	2.4	0.4	1.5	5.0	8.8	12.0	14.5	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	7.6	6.9	6.3	5.0	3.8	3.1	2.9	3.4	4.6	6.2	6.7	7.4	(35)	
		MCDBR	8.2	7.6	7.2	5.7	4.7	4.5	3.7	4.7	5.9	7.1	7.8	8.0	(36)	
	5% WB	MCWBR	4.7	4.6	4.4	4.5	4.2	3.7	3.4	4.2	4.8	4.8	5.2	5.2	(37)	
		MCWBR	6.8	6.3	6.0	4.6	4.0	3.5	3.1	4.1	5.2	6.3	6.8	7.2	(38)	
(40) Clear-Sky Solar Irradiance	taub	taub	0.319	0.288	0.262	0.258	0.244	0.236	0.235	0.242	0.261	0.267	0.277	0.295	(40)	
		taud	2.492	2.632	2.747	2.707	2.728	2.759	2.762	2.728	2.648	2.665	2.660	2.579	(41)	
	Ebn at Noon	Ebn at Noon	1015	1026	1020	969	931	915	936	975	1004	1039	1054	1045	(42)	
		Edh at Noon	114	95	78	71	60	54	57	68	84	91	96	105	(43)	
(44) All-Sky Solar Radiation	RadAvg	RadAvg	7.19	6.22	5.17	3.72	2.54	1.96	2.15	3.00	4.27	5.63	6.49	7.23	(44)	
	RadStd	RadStd	0.47	0.46	0.36	0.24	0.17	0.20	0.13	0.23	0.42	0.49	0.43	0.39	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (34 neighbors)	+0.41	N/A	N/A	N/A	N/A	N/A	N/A	-92	+138	+57

Nomenclature: See separate page