

OMEQ, Australia

WMO: 949080

Lat: 37.1017S

Lon: 147.6008E

Elev: 2265

StdP: 13.53

Time Zone: 10.00 (AUS)

Period: 04-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	26.8	28.7	25.0	20.7	33.2	26.7	22.4	34.6	23.2	49.6	21.2	48.6	2.6	340	0.570

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.6	89.8	63.6	85.7	63.0	82.1	62.1	67.3	81.0	65.7	78.5	64.3	76.3	12.5	350

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	95.8	70.0	61.9	90.1	69.1	60.2	84.5	68.2	33.0	81.0	31.8	78.9	30.6	76.5	73.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.5	18.2	16.3	DB	22.9	96.5	1.7	3.3	21.7	98.8	20.7	100.8	19.8	102.6	18.5	105.0	(4)
(5)			WB	22.3	70.4	1.7	1.7	21.1	71.6	20.2	72.6	19.2	73.6	18.0	74.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	53.2	65.8	63.6	60.5	53.6	47.2	42.7	42.1	43.5	47.9	52.7	57.9	61.1
	DBStd	9.76	6.82	6.26	6.05	5.08	4.47	3.65	3.66	3.89	4.86	5.97	6.33	6.27
	HDD50	955	0	1	2	21	109	220	248	205	99	39	8	3
	HDD65	4545	73	92	166	343	551	668	711	666	514	382	226	153
	CDD50	2108	492	381	327	129	24	1	1	4	35	124	244	346
	CDD65	225	100	52	26	1	0	0	0	0	0	2	12	32
	CDH74	3566	1452	703	401	26	0	0	0	0	1	64	301	618
	CDH80	1252	628	232	110	2	0	0	0	0	0	9	69	202
Wind	WSAvg	7.5	7.9	7.3	6.8	6.5	7.0	6.4	8.2	8.0	8.0	8.0	7.9	7.9
Precipitation	PrecAvg	26.8	2.2	1.8	2.0	1.8	2.0	2.0	2.1	2.4	2.4	2.8	2.9	2.5
	PrecMax	44.1	6.2	5.8	5.5	4.9	7.0	6.7	4.4	5.2	4.4	5.5	7.1	8.0
	PrecMin	16.4	0.2	0.1	0.2	0.2	0.2	0.4	0.4	0.4	0.8	0.6	0.4	0.1
	PrecStd	6.0	1.5	1.3	1.1	1.1	1.5	1.3	1.1	1.1	0.9	1.3	1.5	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.3	92.8	88.1	77.6	65.4	57.2	57.2	62.0	69.9	81.1	87.0	92.2
		MCWB	65.7	65.8	63.2	59.3	53.2	49.2	49.1	50.8	53.0	56.6	61.5	63.2
	2%	DB	91.6	86.2	83.2	72.2	61.9	54.4	53.8	57.8	65.9	74.8	81.4	85.8
		MCWB	64.5	63.2	61.9	57.4	52.6	47.9	46.6	48.3	52.0	56.9	59.9	62.4
	5%	DB	87.1	82.1	78.4	68.7	59.1	52.3	51.5	54.9	62.4	71.1	77.3	81.1
		MCWB	63.8	62.9	60.7	55.9	51.1	46.8	45.5	46.7	50.9	55.9	59.4	61.1
	10%	DB	82.4	78.1	74.0	65.1	56.6	50.3	49.4	52.2	59.2	67.1	73.0	76.4
		MCWB	63.3	61.9	59.8	54.6	49.8	45.8	44.2	45.4	49.5	54.1	59.1	60.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.5	69.6	67.1	62.0	56.5	51.5	50.8	51.7	55.8	61.3	66.3	67.0
		MCDB	86.2	83.3	79.9	72.0	60.3	55.6	54.6	59.0	63.8	70.7	77.0	78.7
	2%	WB	67.5	66.8	64.5	59.0	53.7	49.3	48.0	49.3	53.8	58.8	63.6	64.8
		MCDB	83.2	78.5	75.1	69.0	60.4	52.6	51.7	56.6	62.9	69.2	75.3	77.4
	5%	WB	66.0	65.1	62.9	57.2	51.8	47.6	46.2	47.6	52.1	57.0	61.6	63.0
		MCDB	80.3	75.9	73.3	65.1	57.8	51.1	50.2	53.4	60.7	68.0	72.1	76.0
	10%	WB	64.6	63.3	61.2	55.6	50.1	46.2	44.7	45.8	50.2	55.3	59.8	61.4
		MCDB	78.1	73.8	71.0	63.2	55.5	49.7	48.7	51.4	58.0	65.2	70.0	74.0
Mean Daily Temperature Range	5% DB	MDBR	26.6	24.3	23.3	22.0	18.5	15.9	15.1	17.2	20.8	24.0	24.6	25.6
		MCDBR	36.0	32.8	31.8	28.6	22.8	19.4	18.1	21.9	25.7	31.3	33.4	34.6
		MCWBR	13.0	13.0	13.2	14.8	14.1	13.3	12.0	13.6	14.3	15.8	14.7	14.6
	5% WB	MCDBR	28.6	24.9	25.1	23.3	20.1	17.3	15.3	20.4	23.2	27.1	25.8	27.2
		MCWBR	11.9	11.1	11.9	12.7	12.9	12.3	10.6	13.3	13.8	14.9	13.3	12.8
Clear-Sky Solar Irradiance	taub	0.401	0.343	0.304	0.295	0.281	0.268	0.266	0.277	0.303	0.310	0.321	0.349	
	taud	2.298	2.515	2.637	2.625	2.633	2.675	2.684	2.634	2.547	2.559	2.560	2.468	
	Ebn at Noon	296	307	308	292	279	275	283	295	303	314	319	314	
	Edh at Noon	44	34	28	24	21	19	20	24	30	32	34	37	
All-Sky Solar Radiation	RadAvg	2209	1905	1597	1161	810	627	702	972	1365	1770	2012	2244	
	RadStd	152	150	122	82	48	54	41	67	125	142	146	132	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)	+0.67	N/A	N/A	N/A	N/A	N/A	N/A	-146	+230	+94

Nomenclature: See separate page