

GELANTIPY, Australia

WMO: 949130

Lat: 37.2200S

Lon: 148.2625E

Elev: 2480

StdP: 13.43

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	31.9	33.5	23.7	19.6	44.6	26.2	22.1	42.3	27.7	46.8	24.2	47.6	6.8	20	0.577

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	20.9	86.9	64.4	82.8	63.4	79.1	62.2	68.3	78.0	66.1	76.6	64.3	74.6	11.0	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	103.9	71.1	63.0	94.3	68.9	61.0	87.8	67.2	34.1	78.0	32.2	76.5	30.8	74.6	91.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min		Max		Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
22.4	19.6	17.4		28.7	94.0	1.4	3.5	27.8	96.5	26.9	98.6	26.2	100.5	25.2	103.1
				27.8	73.2	1.1	7.1	27.0	78.3	26.3	82.4	25.7	86.4	24.8	91.5
				DB											
				WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	52.6	63.4	62.8	59.1	53.0	47.9	43.8	42.6	44.1	47.8	51.9	55.8	59.4	(6)
(7)		DBStd	9.37	7.72	7.24	6.82	5.67	4.68	3.86	3.65	4.38	5.45	6.54	7.31	7.39	(7)
(8)		HDD50	942	1	1	5	32	98	190	232	190	106	55	24	8	(8)
(9)		HDD65	4740	125	118	209	362	529	636	695	647	517	409	288	205	(9)
(10)		CDD50	1885	418	360	287	121	34	4	2	8	39	113	199	300	(10)
(11)		CDD65	207	77	57	26	1	0	0	0	0	2	12	32		(11)
(12)		CDH74	2189	835	538	231	17	0	0	0	1	28	141	398		(12)
(13)		CDH80	668	311	163	53	1	0	0	0	0	1	25	114		(13)
(14)	Wind	WSAvg	8.3	8.1	7.8	7.7	7.4	8.0	8.3	9.0	9.2	9.2	8.7	8.2	8.1	(14)
(15)	Precipitation	PrecAvg	30.0	2.6	2.8	2.3	2.2	1.7	2.9	2.0	2.2	2.4	2.9	3.1	2.7	(15)
(16)		PrecMax	38.9	6.5	6.1	6.6	5.5	3.7	8.3	5.5	4.6	5.7	5.5	7.2	6.1	(16)
(17)		PrecMin	18.7	0.6	0.2	0.4	0.4	0.6	0.6	0.5	0.7	1.2	0.5	0.6	0.9	(17)
(18)		PrecStd	4.9	1.4	1.9	1.5	1.4	0.9	2.1	1.4	0.9	1.1	1.3	1.6	1.3	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	93.7	90.5	85.8	76.5	65.0	58.7	57.3	62.8	69.3	77.8	83.4	89.2	(19)
(20)		0.4%	MCWB	65.8	65.3	62.1	58.3	53.5	50.4	47.9	52.3	53.8	57.6	62.2	62.8	(20)
(21)		2%	DB	87.6	84.8	80.4	69.7	61.2	55.3	53.8	57.9	64.9	72.5	77.9	83.3	(21)
(22)		2%	MCWB	64.2	65.1	61.6	57.1	52.5	48.0	45.6	48.3	51.8	56.7	60.5	62.9	(22)
(23)		5%	DB	83.0	80.4	75.4	66.3	58.6	52.7	51.5	54.8	61.8	68.4	73.7	78.3	(23)
(24)		5%	MCWB	63.6	64.1	60.6	55.5	50.8	46.4	44.6	46.5	50.6	55.1	59.3	61.8	(24)
(25)		10%	DB	78.3	76.4	71.0	62.9	56.0	50.4	49.2	52.2	58.3	64.6	69.4	73.7	(25)
(26)		10%	MCWB	63.2	62.9	60.0	54.1	49.5	44.9	43.3	44.7	49.1	53.8	58.6	60.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.5	79.1	68.7	62.6	56.7	52.6	49.9	54.7	57.0	62.6	67.0	68.9	(27)
(28)		0.4%	MCDWB	80.6	80.1	75.0	67.9	59.2	56.4	53.8	60.5	63.0	70.1	72.7	76.7	(28)
(29)		2%	WB	67.5	68.6	64.8	58.9	53.8	49.3	46.9	49.6	53.7	59.1	63.6	64.9	(29)
(30)		2%	MCDWB	80.1	77.5	72.8	65.6	59.5	54.0	50.9	55.5	62.8	67.4	72.4	76.9	(30)
(31)		5%	WB	65.6	66.0	62.8	56.8	52.0	47.5	45.4	47.5	51.7	56.7	61.3	63.0	(31)
(32)		5%	MCDWB	77.9	75.8	70.8	62.6	57.3	51.3	49.6	53.4	59.7	65.3	70.1	74.0	(32)
(33)		10%	WB	63.9	64.0	60.9	55.1	50.2	45.9	44.1	45.5	49.8	54.5	59.3	61.2	(33)
(34)		10%	MCDWB	75.4	72.8	69.0	60.5	55.0	49.4	48.2	51.1	57.0	63.1	67.5	71.5	(34)
(35)	Mean Daily Temperature Range		MDBR	20.9	19.4	17.4	15.6	12.7	10.8	11.4	13.2	15.5	17.9	18.5	20.2	(35)
(36)		5% DB	MCDBR	28.9	26.7	24.4	20.8	16.3	13.6	14.2	17.3	21.1	24.3	25.8	28.1	(36)
(37)		5% DB	MCWBR	11.1	10.9	10.0	10.3	9.7	9.0	9.2	10.3	11.2	12.2	12.1	12.6	(37)
(38)		5% WB	MCDBR	24.8	21.8	20.0	17.7	14.3	12.1	12.5	16.1	19.4	21.0	21.6	23.3	(38)
(39)		5% WB	MCWBR	12.2	11.8	11.1	10.6	9.6	8.6	8.7	10.4	11.2	12.1	12.1	12.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.404	0.351	0.307	0.297	0.278	0.268	0.263	0.273	0.299	0.310	0.320	0.339	(40)	
(41)		taud	2.286	2.488	2.621	2.619	2.653	2.684	2.705	2.662	2.567	2.561	2.565	2.508	(41)	
(42)		Ebn at Noon	295	304	307	291	280	275	284	297	305	314	319	317	(42)	
(43)		Edh at Noon	44	35	28	25	21	19	19	23	29	32	33	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2139	1836	1547	1134	812	632	722	993	1375	1753	1974	2192	(44)	
(45)		RadStd	152	141	125	88	42	49	44	61	107	122	149	144	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+216	+59
(47)	Regional (29 neighbors)	+0.65	N/A	N/A	N/A	N/A	N/A	N/A	-146	+230	+94

Nomenclature: See separate page