

PERISHER VALLEY, Australia

WMO: 949150

Lat: 36.4069S

Lon: 148.4056E

Elev: 5702

StdP: 11.91

Time Zone: 10.00 (AUS)

Period: 10-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 18.4	(c) 20.8	(d) -3.7	(e) 5.6	(f) 36.7	(g) 2.0	(h) 7.5	(i) 35.4	(j) 36.3	(k) 32.6	(l) 32.0	(m) 30.9	(n) 2.5	(o) 230	(p) 0.663

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 1	(b) 20.0	(c) 74.6	(d) 56.6	(e) 71.2	(f) 55.0	(g) 68.2	(h) 54.0	(i) 59.3	(j) 67.8	(k) 57.7	(l) 65.9	(m) 56.4	(n) 64.3	(o) 7.9	(p) 280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
56.6	84.7	60.8	55.0	79.7	60.2	53.3	74.8	59.5	28.7	67.3	27.6	66.0	26.5	64.4	63.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a) 27.3	(b) 22.9	(c) 19.5	(e) 11.5	(f) 79.5	(g) 2.8	(h) 3.4	(i) 9.5	(j) 82.0	(k) 7.8	(l) 84.0	(m) 6.3	(n) 85.9	(o) 4.3	(p) 88.4		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	42.6	55.9	53.1	49.5	43.5	37.1	33.0	31.1	31.2	36.4	42.6	47.2	51.3
	DBStd	10.15	6.74	5.30	5.87	5.31	4.96	4.15	3.90	4.49	5.37	6.73	6.95	6.65
	HDD50	3260	25	25	81	203	399	510	587	582	409	243	133	63
	HDD65	8185	289	334	480	644	864	960	1052	1047	858	694	536	427
	CDD50	558	207	112	66	8	0	0	0	0	1	14	48	102
	CDD65	10	6	1	0	0	0	0	0	0	0	0	1	2
	CDH74	119	89	13	1	0	0	0	0	0	0	0	4	12
	CDH80	6	6	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	7.5	6.4	5.6	6.5	6.1	8.7	7.5	9.5	8.9	8.4	7.7	7.4	6.8
Precipitation	PrecAvg	42.7	3.2	3.2	2.6	2.7	2.9	4.0	3.5	4.3	4.1	4.2	4.2	3.7
	PrecMax	68.4	9.6	13.0	12.1	7.8	7.2	14.1	8.5	10.6	7.7	9.6	8.9	7.2
	PrecMin	21.9	0.2	0.2	0.0	0.0	0.0	1.3	1.0	1.1	0.6	0.9	1.2	1.3
	PrecStd	9.4	1.9	2.6	2.3	1.7	1.8	2.6	1.8	2.2	1.7	2.2	1.9	1.7
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.6	76.0	71.5	63.0	55.6	51.8	45.0	47.6	55.6	65.3	71.6	75.6
		MCWB	58.5	56.6	54.7	51.4	41.7	38.7	35.1	36.8	42.7	46.8	52.9	55.6
	2%	DB	76.4	71.5	67.6	59.3	52.3	46.7	42.6	43.7	51.3	61.1	66.4	71.4
		MCWB	57.4	55.2	54.4	47.9	41.8	34.6	34.9	34.8	41.0	46.5	51.8	54.3
	5%	DB	72.6	68.1	63.6	56.8	49.6	43.3	40.3	41.5	47.9	57.9	63.6	67.7
		MCWB	56.1	54.5	52.0	46.4	39.9	36.3	33.5	34.4	39.6	45.2	50.0	52.8
	10%	DB	69.3	65.1	60.5	54.0	46.5	40.5	38.1	39.3	45.5	55.2	60.3	64.5
		MCWB	54.7	53.2	50.8	45.5	38.5	35.0	33.1	32.9	38.1	44.2	48.9	51.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.4	61.1	57.9	54.0	49.5	43.1	41.3	40.2	44.8	51.9	57.2	59.3
		MCDB	72.5	66.4	65.0	59.7	51.4	43.9	42.8	43.6	49.9	58.2	62.5	63.5
	2%	WB	59.9	58.7	56.0	50.7	44.9	40.1	38.3	37.8	43.0	49.7	54.6	56.3
		MCDB	70.2	65.2	62.9	56.1	49.9	42.7	39.5	41.3	49.1	55.7	61.9	64.6
	5%	WB	58.4	57.0	54.4	48.6	42.2	38.0	36.3	36.0	41.3	47.9	52.6	55.0
		MCDB	68.1	63.4	60.8	53.9	46.0	40.3	38.0	38.9	47.1	54.4	60.2	64.4
	10%	WB	57.1	55.4	52.8	47.1	40.5	36.4	34.2	34.4	39.3	46.1	50.6	53.5
		MCDB	66.3	61.9	58.2	52.1	43.7	39.0	36.2	37.4	43.9	52.7	58.1	62.5
Mean Daily Temperature Range	5% DB	MDBR	20.0	19.7	17.1	16.9	13.3	12.3	10.5	11.2	12.5	17.0	18.3	19.7
		MCDBR	25.0	24.8	23.1	22.5	21.1	19.8	16.2	15.4	16.6	22.1	23.0	24.8
		MCWBR	12.6	12.8	13.2	13.7	13.3	12.8	11.0	10.6	11.1	13.0	12.9	12.8
	5% WB	MCDBR	20.1	17.5	17.9	17.5	13.5	13.2	9.7	11.3	14.0	18.6	17.6	20.3
		MCWBR	11.6	11.1	10.9	11.8	10.6	10.4	8.7	9.2	10.4	12.6	11.3	11.4
Clear-Sky Solar Irradiance	taub		0.333	0.293	0.268	0.259	0.247	0.237	0.234	0.241	0.262	0.273	0.283	0.287
	taud		2.452	2.628	2.722	2.703	2.700	2.746	2.763	2.727	2.635	2.626	2.633	2.627
	Ebn at Noon		318	324	322	307	295	291	298	310	318	327	332	334
	Edh at Noon		38	30	25	23	20	17	18	22	27	30	31	32
All-Sky Solar Radiation	RadAvg		2291	1949	1656	1214	864	660	730	1009	1432	1846	2088	2325
	RadStd		166	173	138	92	40	52	41	62	121	148	153	127

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (33 neighbors)	+0.76	N/A	N/A	+1.76	N/A	N/A	N/A	N/A	+218	+103

Nomenclature: See separate page