

KHANCOBAN, AustraliaWMO: **949190**Lat: **36.2303S**Lon: **148.1406E**Elev: **340**StdP: **97.31**Time Zone: **10.00 (AUS)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-1.3	-0.4	-2.1	3.3	3.9	-1.2	3.6	3.8	8.3	10.5	7.3	10.3	0.5	170	0.441

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	16.7	35.3	19.1	33.1	18.5	31.3	18.0	21.6	27.8	20.6	27.4	19.9	26.9	3.8	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.3	15.6	22.2	19.1	14.4	21.7	17.9	13.4	21.1	64.5	27.3	61.1	27.5	58.3	26.9	25.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.4	6.3	5.3	-2.7	38.9	0.5	2.2	-3.0	40.4	-3.3	41.7	-3.6	42.9	-4.0	44.5		
(5)			-2.8	23.2	0.5	1.2	-3.1	24.1	-3.4	24.8	-3.7	25.5	-4.0	26.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	22.4	21.6	18.8	14.3	10.1	7.2	6.8	7.9	10.6	13.3	17.0	19.5
	DBStd	6.11	3.46	3.16	3.16	2.74	2.45	2.26	2.13	2.00	2.42	2.96	3.39	3.24
	HDD10.0	319	0	0	0	3	30	88	102	71	21	4	1	0
	HDD18.3	1926	8	7	33	123	257	334	358	323	232	158	66	25
	CDD10.0	1805	384	326	274	132	32	3	2	6	38	106	209	293
	CDD18.3	369	133	99	48	2	0	0	0	0	0	2	24	60
	CDH23.3	4924	1723	1177	634	51	0	0	0	0	1	72	390	875
	CDH26.7	2115	873	533	221	7	0	0	0	0	0	12	120	349
Wind	WSAvg	1.6	2.0	1.9	1.8	1.2	1.1	1.1	1.3	1.5	1.7	1.7	1.8	1.9
Precipitation	PrecAvg	961	63	45	57	62	85	87	101	114	99	99	80	73
	PrecMax	1422	193	125	189	199	227	224	263	218	219	239	164	178
	PrecMin	390	1	0	3	2	2	15	17	22	23	10	4	5
	PrecStd	225	46	35	42	43	50	43	56	50	42	53	42	46
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.8	37.4	34.0	27.6	20.6	15.8	15.8	18.3	22.8	28.2	32.4	36.2
		MCWB	20.0	19.4	17.9	15.9	13.6	11.5	11.5	12.2	14.7	16.8	17.2	18.7
	2%	DB	36.1	34.2	31.2	24.6	18.4	13.8	13.4	15.8	20.5	25.4	29.9	32.8
		MCWB	19.5	18.9	17.6	15.4	12.9	10.5	10.1	10.8	14.1	16.0	17.8	18.4
	5%	DB	33.8	32.0	29.1	22.7	16.6	12.6	11.9	14.1	18.6	22.9	27.7	30.5
		MCWB	19.0	18.3	16.9	14.7	12.1	10.0	9.2	9.9	12.8	14.8	17.0	17.5
	10%	DB	31.5	30.1	27.1	20.9	14.8	11.3	10.7	12.5	16.7	20.8	25.4	28.2
		MCWB	18.4	17.9	16.3	13.9	11.4	9.5	8.5	9.1	11.8	14.3	16.6	17.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.7	22.9	21.1	18.3	15.7	12.8	12.6	13.2	16.0	18.7	21.3	21.7
		MCDB	29.3	27.0	26.3	22.6	17.4	14.2	14.2	16.6	20.6	24.1	26.2	27.1
	2%	WB	21.6	21.5	19.7	16.9	13.9	11.4	10.7	11.6	14.7	17.2	19.7	20.4
		MCDB	29.6	26.2	25.3	21.4	16.8	12.7	12.7	14.6	18.8	22.4	25.8	26.2
	5%	WB	20.7	20.4	18.8	15.9	12.8	10.6	9.6	10.5	13.6	16.1	18.6	19.3
		MCDB	29.1	26.6	24.4	20.1	15.4	11.9	11.2	13.0	17.3	21.0	24.4	26.3
	10%	WB	19.9	19.4	17.8	15.0	11.9	9.7	8.7	9.5	12.4	15.0	17.5	18.4
		MCDB	28.1	26.5	23.7	19.4	14.3	11.0	10.2	11.9	15.9	19.6	23.0	25.6
Mean Daily Temperature Range	5% DB	MDBR	16.7	15.5	14.8	13.6	10.7	8.7	8.4	9.8	11.7	13.5	14.7	15.7
		MCDBR	19.9	18.5	17.9	16.0	13.3	10.6	10.1	13.1	14.9	17.6	18.4	19.4
		MCWBR	6.0	5.8	6.3	7.5	7.6	7.1	6.8	7.9	8.6	9.0	7.5	6.7
		MCDDBR	16.1	13.9	13.5	13.0	11.1	8.7	8.6	11.1	13.7	14.6	14.6	15.0
	5% WB	MCWBR	5.9	5.3	5.9	6.7	6.9	6.2	6.1	7.1	8.2	8.2	7.0	6.6
Clear-Sky Solar Irradiance	taub	0.415	0.359	0.323	0.313	0.300	0.282	0.280	0.291	0.324	0.335	0.350	0.356	
	taud	2.283	2.493	2.582	2.568	2.564	2.626	2.629	2.584	2.483	2.477	2.477	2.469	
	Ebn at Noon	920	953	952	902	857	852	876	915	935	966	978	983	
	Edh at Noon	141	110	93	83	72	63	67	80	101	110	115	118	
All-Sky Solar Radiation	RadAvg	7.34	6.29	5.32	3.90	2.73	2.08	2.28	3.15	4.50	5.86	6.67	7.42	
	RadStd	0.49	0.52	0.42	0.27	0.15	0.19	0.13	0.23	0.42	0.50	0.47	0.39	