

COOMA SNOWY MOUNTAINS, Australia

WMO: 949210

Lat: 36.2939S

Lon: 148.9725E

Elev: 3054

StdP: 13.14

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.4	23.8	14.8	13.0	46.3	18.2	15.4	38.8	28.5	45.6	25.7	44.5	2.4	10	0.623

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.3	88.8	61.6	84.9	60.6	81.2	59.5	66.3	77.8	64.6	75.7	63.0	74.0	13.9	270

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.4	98.0	68.7	61.2	90.6	67.1	59.5	85.2	65.8	32.7	78.5	31.3	75.0	30.0	74.1	78.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 25.1	22.3	19.9	DB	16.4	95.1	1.7	3.5	15.1	97.7	14.1	99.7	13.1	101.7	11.8	104.3	(4)
(5)			WB	15.5	69.8	1.7	3.1	14.2	72.0	13.2	73.8	12.3	75.5	11.0	77.8	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	51.6	65.3	63.4	58.7	51.5	45.0	40.6	39.1	41.1	46.3	51.2	56.6	61.2	(6)	
	DBStd	10.55	6.60	6.24	5.91	5.38	4.82	4.31	4.08	4.58	5.52	6.36	6.86	6.55	(7)	
	HDD50	1344	0	1	5	43	167	282	340	279	140	63	20	4	(8)	
	HDD65	5092	79	96	208	406	619	731	804	741	562	430	263	153	(9)	
	CDD50	1922	473	375	274	87	13	1	1	3	29	99	217	350	(10)	
	CDD65	192	86	49	12	0	0	0	0	0	0	1	10	34	(11)	
	CDH74	3167	1268	685	231	17	0	0	0	0	1	49	268	648	(12)	
	CDH80	1047	510	221	45	0	0	0	0	0	0	2	61	208	(13)	
(14) Wind	WSAvg	9.2	10.0	9.2	8.6	7.8	8.1	8.5	8.9	9.4	9.9	9.9	10.0	9.9	(14)	
(15) Precipitation	PrecAvg	21.4	2.6	2.4	1.5	1.3	0.9	2.0	1.2	1.4	1.7	1.8	2.2	2.3	(15)	
	PrecMax	28.7	6.5	7.8	4.8	5.0	2.6	7.4	4.9	4.0	4.0	5.0	5.4	5.8	(16)	
	PrecMin	13.5	0.1	0.4	0.0	0.0	0.1	0.4	0.2	0.0	0.5	0.2	0.2	0.5	(17)	
	PrecStd	4.6	1.8	2.0	1.3	1.2	0.7	1.8	1.0	0.8	0.8	1.1	1.3	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.5	91.5	85.2	76.4	66.5	58.8	57.1	63.7	70.4	78.8	86.1	91.4	(19)	
		MCWB	63.8	62.2	59.5	55.3	51.4	48.7	45.0	48.3	51.1	53.5	59.1	61.2	(20)	
	2%	DB	90.0	86.3	79.9	71.0	62.1	54.9	53.7	58.5	66.4	74.7	80.9	85.6	(21)	
		MCWB	62.3	62.0	58.2	54.2	49.9	46.3	43.9	45.8	49.8	53.9	57.2	60.1	(22)	
	5%	DB	86.0	82.1	75.9	67.5	59.0	52.3	51.1	55.1	62.8	70.4	76.5	81.1	(23)	
		MCWB	61.5	60.4	57.9	53.4	49.0	45.4	42.9	44.5	48.7	52.8	56.3	58.8	(24)	
	10%	DB	81.3	77.8	72.1	63.8	55.8	49.8	48.6	52.0	59.3	66.3	72.2	76.7	(25)	
		MCWB	60.6	60.1	57.5	52.3	47.6	43.9	41.6	43.1	47.9	51.5	55.8	57.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.1	68.4	65.7	59.8	56.0	51.7	48.5	51.4	55.4	59.9	63.8	67.3	(27)	
		MCDB	80.8	79.0	73.5	68.2	59.3	54.8	53.1	58.5	63.3	68.8	73.7	76.7	(28)	
	2%	WB	66.7	65.9	63.0	57.3	52.5	48.5	45.9	48.1	53.0	57.1	61.3	63.8	(29)	
		MCDB	78.7	76.9	71.4	64.9	58.8	52.9	50.4	54.6	61.2	66.8	72.6	75.4	(30)	
	5%	WB	64.7	64.2	61.1	55.4	50.5	46.5	44.0	45.8	50.9	55.0	59.4	61.9	(31)	
		MCDB	76.8	74.9	69.7	63.3	56.5	50.3	48.9	53.1	59.8	65.3	70.6	74.1	(32)	
	10%	WB	63.1	62.5	59.3	53.7	48.6	44.7	42.5	43.9	48.7	53.0	57.5	60.3	(33)	
		MCDB	75.3	72.2	67.4	61.3	54.2	48.6	47.4	50.5	57.4	63.5	67.6	72.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	26.3	24.3	23.6	23.6	22.0	18.5	19.8	21.6	23.1	24.9	24.8	26.1	(35)	
		MCDBR	34.5	31.7	29.8	29.6	27.4	23.0	24.1	27.6	29.6	32.0	32.6	33.4	(36)	
	5% WB	MCWBR	11.6	10.8	11.8	14.3	16.5	15.3	15.7	16.3	15.4	14.5	12.8	12.1	(37)	
		MCWBR	27.2	24.3	23.1	23.6	22.1	18.9	19.5	22.8	24.0	25.5	25.0	26.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.381	0.331	0.301	0.287	0.270	0.259	0.255	0.265	0.290	0.309	0.320	0.322	(40)	
		taud	2.349	2.547	2.626	2.629	2.640	2.682	2.693	2.648	2.559	2.522	2.535	2.542	(41)	
	Ebn at Noon		302	312	310	296	285	281	289	301	308	315	320	323	(42)	
		Edh at Noon	42	33	28	25	21	19	20	23	30	33	35	35	(43)	
(44) All-Sky Solar Radiation	RadAvg		2204	1880	1602	1204	889	684	777	1055	1466	1832	2036	2249	(44)	
	RadStd		173	164	134	96	41	50	51	60	115	137	154	137	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (30 neighbors)	+0.74	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+211	+94

Nomenclature: See separate page