

CANBERRA AP, Australia

WMO: 949260

Lat: 35.3089S

Lon: 149.2003E

Elev: 1895

StdP: 13.72

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.5	27.7	21.3	17.1	43.9	23.6	19.1	40.7	26.9	49.7	24.5	48.5	1.7	0	0.531

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	26.0	94.1	64.5	90.0	63.7	86.3	62.5	68.7	82.4	67.2	80.2	65.8	78.4	13.2	280

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
65.5	101.0	71.6	63.4	93.8	70.2	61.7	88.1	69.4	34.0	81.8	32.7	79.9	31.6	78.4	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	21.1	19.0	21.6	100.1	2.1	3.4	20.1	102.6	18.9	104.6	17.7	106.5	16.3	109.0
			20.9	71.5	2.1	1.8	19.4	72.7	18.2	73.8	17.1	74.8	15.6	76.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	56.5	70.6	68.9	64.2	56.7	49.5	44.8	43.2	45.1	50.6	56.1	62.2	67.1	(6)
(7)		DBStd	10.87	6.24	5.73	5.31	5.11	4.79	4.13	4.03	4.06	4.58	5.60	6.69	5.93	(7)
(8)		HDD50	672	0	0	0	7	69	162	215	160	47	10	2	0	(8)
(9)		HDD65	3646	20	23	80	254	482	606	677	617	432	279	130	46	(9)
(10)		CDD50	3050	639	530	440	207	52	7	3	8	65	200	368	531	(10)
(11)		CDD65	548	194	133	55	4	0	0	0	0	4	46	112		(11)
(12)		CDH74	6707	2237	1375	630	85	0	0	0	6	185	742	1447		(12)
(13)		CDH80	2759	1106	564	186	13	0	0	0	1	35	268	586		(13)
(14)	Wind	WSAvg	7.9	8.3	7.8	7.2	6.3	6.5	7.0	7.6	8.7	8.9	8.7	8.6	8.6	(14)
(15)	Precipitation	PrecAvg	24.2	2.3	2.2	2.0	1.7	1.5	1.5	1.7	1.9	2.2	2.2	2.6	2.3	(15)
(16)		PrecMax	38.5	8.6	8.5	9.6	7.4	5.3	5.7	4.8	6.1	5.9	6.3	5.4	6.3	(16)
(17)		PrecMin	10.3	0.0	0.0	0.1	0.0	0.0	0.1	0.2	0.1	0.1	0.0	0.0	0.0	(17)
(18)		PrecStd	5.9	1.8	1.9	1.8	1.6	1.1	1.3	1.2	1.1	1.3	1.5	1.4	1.6	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.2	97.2	90.4	81.9	70.1	61.7	60.2	66.3	73.9	84.5	93.0	96.5	(19)
(20)		0.4%	MCWB	65.2	66.7	62.8	59.5	55.1	52.2	50.7	51.9	55.2	58.3	61.4	63.1	(20)
(21)		2%	DB	95.3	91.3	85.1	75.8	66.4	58.7	56.9	61.5	70.1	79.1	87.3	90.6	(21)
(22)		2%	MCWB	65.3	64.8	61.8	58.0	54.2	50.3	48.2	49.7	53.9	57.6	60.9	63.0	(22)
(23)		5%	DB	91.1	86.7	80.8	72.3	63.5	56.4	54.9	58.7	66.6	74.9	82.2	86.4	(23)
(24)		5%	MCWB	64.6	63.8	61.3	57.0	52.8	49.0	47.1	48.3	52.4	56.3	59.9	61.8	(24)
(25)		10%	DB	86.2	82.6	76.8	68.7	60.6	54.3	52.8	55.8	63.3	70.5	77.4	82.3	(25)
(26)		10%	MCWB	63.5	63.3	60.8	55.6	51.7	48.0	45.7	46.7	51.3	55.4	58.9	60.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.8	71.5	68.1	63.2	59.5	54.7	53.8	54.6	58.5	63.0	67.0	68.5	(27)
(28)		0.4%	MCDWB	86.3	85.8	77.5	73.6	63.7	57.8	56.2	61.0	68.1	73.8	79.8	80.7	(28)
(29)		2%	WB	68.9	68.7	65.9	60.6	56.5	52.4	50.3	51.5	56.5	60.5	64.5	66.3	(29)
(30)		2%	MCDWB	85.0	80.3	75.5	69.9	62.5	56.1	54.5	59.3	65.7	71.2	78.3	79.3	(30)
(31)		5%	WB	67.4	67.0	64.1	58.9	54.4	50.4	48.2	49.4	54.5	58.7	62.7	64.7	(31)
(32)		5%	MCDWB	82.2	78.9	74.3	67.5	61.5	54.7	52.8	56.9	63.5	69.5	75.4	78.7	(32)
(33)		10%	WB	65.8	65.4	62.5	57.4	52.6	48.9	46.6	47.6	52.4	56.8	60.9	63.2	(33)
(34)		10%	MCDWB	79.7	77.4	72.5	66.0	59.4	53.3	51.5	54.8	61.3	67.4	73.4	76.2	(34)
(35)	Mean Daily Temperature Range		MDBR	26.0	23.9	23.5	24.0	22.9	19.6	20.1	22.0	23.5	24.9	25.2	25.9	(35)
(36)		5% DB	MCDBR	34.9	31.4	30.4	29.1	26.8	22.8	23.3	26.7	30.5	33.4	34.2	33.7	(36)
(37)		5% DB	MCWBR	10.7	10.0	11.3	13.6	15.6	14.9	15.4	15.9	16.4	15.1	12.7	11.3	(37)
(38)		5% WB	MCDBR	27.8	24.7	23.4	24.2	22.3	18.5	19.2	23.8	26.2	26.1	27.1	26.6	(38)
(39)		5% WB	MCWBR	10.1	9.6	10.2	12.3	13.6	13.0	13.5	15.2	15.3	13.3	11.7	10.7	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.384	0.346	0.317	0.297	0.288	0.273	0.268	0.280	0.306	0.325	0.337	0.340	(40)	
(41)		taud	2.374	2.528	2.589	2.615	2.580	2.647	2.657	2.601	2.520	2.484	2.495	2.503	(41)	
(42)		Ebn at Noon	302	307	305	294	279	277	285	296	304	310	315	317	(42)	
(43)		Edh at Noon	41	34	30	25	23	20	21	25	31	35	36	36	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2247	1924	1636	1257	943	720	816	1099	1521	1884	2075	2296	(44)	
(45)		RadStd	170	171	138	103	48	58	56	73	124	158	171	151	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.77	N/A	N/A	+2.45	+1.15	+1.19	N/A	N/A	N/A	N/A
(47)	Regional (29 neighbors)	+0.72	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+214	+104

Nomenclature: See separate page