

BRAIDWOOD, Australia

WMO: 949270

Lat: 35.4253S

Lon: 149.7836E

Elev: 666

StdP: 93.58

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	-4.1	-2.7	-6.2	2.4	4.0	-4.9	2.7	3.1	14.0	8.8	12.3	8.3	0.3	140	0.554

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	13.6	32.9	17.8	30.2	17.2	28.0	16.9	20.2	26.7	19.2	25.4	18.5	24.3	5.4	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.5	14.5	21.7	17.5	13.6	21.0	16.7	12.9	20.1	60.9	26.9	57.7	25.3	55.0	24.0	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 11.4	9.7	8.4	-6.7	36.7	1.1	2.0	-7.6	38.1	-8.2	39.3	-8.9	40.4	-9.7	41.8		
(5)			-7.0	22.1	1.1	0.9	-7.8	22.7	-8.5	23.2	-9.1	23.7	-9.9	24.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.4	19.1	18.4	16.2	12.5	9.1	6.7	5.9	6.9	9.7	12.2	14.8	17.3		
	DBStd	5.48	3.66	3.34	3.07	2.97	2.63	2.22	2.19	2.52	2.88	3.35	3.79	3.67		
	HDD10.0	448	0	0	0	9	49	101	128	101	40	14	4	1		
	HDD18.3	2334	36	37	81	176	287	349	384	353	259	192	117	64		
	CDD10.0	1313	282	236	192	84	21	2	2	6	31	83	149	227		
	CDD18.3	158	59	39	14	1	0	0	0	0	2	11	32			
	CDH23.3	2024	712	407	170	25	0	0	0	0	1	56	221	433		
(13)	CDH26.7	773	326	159	44	3	0	0	0	0	8	71	163			
(14)	Wind	WSAvg	3.2	3.2	3.1	2.9	2.5	2.7	3.1	3.2	3.6	3.6	3.5	3.3		
(15) Precipitation	PrecAvg	722	74	86	52	43	44	92	41	59	49	54	65	62		
	PrecMax	895	182	218	176	130	160	273	135	231	103	173	136	153		
	PrecMin	476	2	6	2	0	8	23	1	2	1	2	12	12		
	PrecStd	125	44	54	42	33	40	77	33	60	25	39	39	42		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	36.1	34.4	30.9	26.6	20.6	16.2	15.5	19.1	22.6	27.9	32.5	34.4		
		MCWB	18.2	18.4	17.0	14.7	12.4	10.7	9.1	10.9	12.7	13.9	16.0	16.7		
	2%	DB	33.4	31.0	27.5	23.0	18.3	14.1	13.5	16.2	20.4	24.8	28.5	30.9		
		MCWB	18.1	17.8	16.5	14.1	11.6	9.7	8.3	9.3	11.7	13.9	15.7	16.5		
	5%	DB	30.4	28.2	24.9	20.8	16.6	12.8	12.2	14.4	18.4	22.4	25.7	28.1		
		MCWB	17.8	17.8	16.2	13.4	11.1	9.0	7.8	8.5	10.9	13.3	15.2	16.4		
	10%	DB	27.4	25.3	22.4	18.7	14.8	11.5	11.0	12.7	16.3	19.7	23.0	25.3		
		MCWB	17.7	17.6	15.7	12.9	10.6	8.4	7.2	7.8	10.3	12.4	14.8	15.8		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	21.5	19.6	16.9	14.7	12.5	11.2	12.6	14.4	17.0	19.0	20.1		
		MCDB	27.5	28.0	24.9	21.5	17.0	14.2	13.1	16.1	19.1	23.1	25.6	26.3		
	2%	WB	20.3	20.1	18.3	15.4	13.4	10.9	9.6	10.6	13.1	15.3	17.6	18.8		
		MCDB	27.3	26.2	23.3	19.9	15.8	12.9	11.9	14.8	17.8	21.0	24.3	25.3		
	5%	WB	19.3	19.2	17.4	14.5	12.1	9.8	8.5	9.3	12.0	14.2	16.5	17.8		
		MCDB	26.1	24.4	21.8	18.4	15.2	11.9	10.9	13.1	16.4	19.7	22.8	24.2		
	10%	WB	18.5	18.3	16.5	13.7	11.1	8.9	7.6	8.3	11.0	13.2	15.5	16.9		
		MCDB	24.8	23.2	20.7	17.3	14.2	10.9	10.2	11.7	15.2	18.2	21.3	22.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	13.6	12.0	11.5	12.4	12.0	10.2	10.8	11.7	12.3	12.8	12.8	13.2		
		MCDBR	19.7	17.3	16.1	15.8	14.7	12.6	12.6	14.4	15.8	17.4	18.4	18.5		
		MCWBR	6.6	6.4	6.6	7.8	8.7	8.4	8.0	8.3	8.3	7.9	7.5	6.5		
	5% WB	MCDBR	15.2	13.6	12.3	12.5	11.6	9.7	9.9	12.2	12.8	13.8	14.9	14.7		
		MCWBR	6.5	5.9	6.0	6.7	7.3	6.9	7.0	7.6	7.4	7.2	7.1	6.4		
(40) Clear-Sky Solar Irradiance	taub		0.379	0.343	0.319	0.297	0.283	0.271	0.266	0.274	0.300	0.321	0.338	0.340		
	taud		2.401	2.549	2.597	2.638	2.621	2.669	2.684	2.648	2.556	2.516	2.503	2.517		
	Ebn at Noon		956	970	959	927	885	874	901	940	963	982	991	999		
	Edh at Noon		125	104	92	78	69	62	64	75	94	106	112	113		
(44) All-Sky Solar Radiation	RadAvg		6.70	5.74	4.91	3.83	2.98	2.30	2.67	3.56	4.83	5.81	6.28	6.88		
	RadStd		0.56	0.52	0.40	0.33	0.14	0.18	0.20	0.20	0.34	0.46	0.53	0.49		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.51	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (28 neighbors)	+0.40	N/A	N/A	N/A	N/A	N/A	N/A	-71	+120	+56

Nomenclature: See separate page