

MOUNT NOWA NOWA, AustraliaWMO: **949300**Lat: **37.6925S**Lon: **148.0908E**Elev: **1148**StdP: **14.10**Time Zone: **10.00 (AUS)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	38.7	40.0	26.5	21.3	55.8	29.3	24.3	52.7	21.6	52.9	18.9	51.5	9.0	270	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	17.8	91.3	65.3	86.5	64.6	82.4	64.0	69.4	81.7	67.7	79.9	66.1	77.7	7.7	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
65.7	99.1	72.6	64.1	93.5	70.7	62.5	88.3	69.6	34.2	82.0	32.7	80.3	31.5	77.9	75.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.1	15.8	14.0	DB	36.3	102.2	1.1	4.3	35.5	105.2	34.9	107.8	34.3	110.2	33.5	113.3	(4)
(5)			WB	34.0	72.5	1.0	2.1	33.3	74.0	32.7	75.2	32.2	76.4	31.4	77.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.5	66.6	65.9	63.7	58.6	53.8	49.9	49.0	50.1	53.4	56.0	59.9	63.0	(6)	
	DBStd	8.69	8.10	7.05	6.98	5.73	4.87	3.94	3.74	4.52	5.66	6.65	7.57	7.66	(7)	
	HDD50	222	0	0	0	3	16	48	64	53	22	13	3	0	(8)	
	HDD65	3188	74	66	112	207	347	454	495	461	351	293	195	133	(9)	
	CDD50	2941	515	446	424	261	134	44	34	57	125	199	299	403	(10)	
	CDD65	433	124	93	71	15	1	0	0	0	3	14	41	71	(11)	
	CDH74	3791	1240	747	477	72	1	0	0	0	21	145	371	717	(12)	
	CDH80	1455	551	281	157	14	0	0	0	0	3	34	125	290	(13)	
(14) Wind	WSAvg	6.8	6.0	5.7	6.3	6.4	7.4	7.2	8.0	7.7	7.5	7.0	6.3	6.2	(14)	
(15) Precipitation	PrecAvg	31.3	2.4	2.6	2.2	2.8	1.9	3.8	2.4	2.2	2.8	2.9	3.0	2.8	(15)	
	PrecMax	41.5	5.7	6.3	6.6	7.3	5.4	12.5	5.6	4.6	6.7	5.9	7.6	6.3	(16)	
	PrecMin	21.6	0.6	0.5	0.6	0.4	0.7	0.7	0.6	0.5	1.2	0.6	0.6	0.7	(17)	
	PrecStd	5.4	1.3	1.5	1.2	1.9	1.1	3.1	1.5	1.1	1.4	1.4	1.5	1.3	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	101.3	95.0	91.0	81.0	70.5	64.1	62.9	68.2	76.9	84.9	90.7	95.4	(19)	
		MCWB	68.2	66.9	64.8	61.3	56.4	52.8	51.0	53.5	56.3	60.0	62.1	65.7	(20)	
	2%	DB	91.4	87.7	84.3	75.3	66.7	60.7	60.0	63.6	71.3	78.0	83.1	87.9	(21)	
		MCWB	66.5	65.7	64.0	59.9	55.4	51.1	49.6	51.2	55.0	58.2	62.0	64.0	(22)	
	5%	DB	85.6	82.6	79.1	70.9	64.2	58.0	57.5	60.5	67.3	72.6	77.7	82.1	(23)	
		MCWB	65.3	65.6	63.2	58.5	54.4	49.8	48.4	49.6	53.7	56.9	61.3	63.5	(24)	
	10%	DB	80.7	78.0	74.6	67.2	61.4	55.9	55.0	57.8	63.4	68.1	72.7	76.5	(25)	
		MCWB	65.1	64.5	62.3	57.2	52.8	48.8	47.1	48.4	52.6	55.1	59.3	61.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.4	71.3	69.0	63.8	59.3	55.2	53.3	55.3	59.4	63.2	67.7	69.5	(27)	
		MCDB	86.8	82.6	79.3	75.8	66.3	61.1	60.0	63.7	70.4	76.0	80.7	84.4	(28)	
	2%	WB	69.7	69.1	66.7	61.6	57.1	52.9	51.2	52.7	57.2	60.6	64.4	67.0	(29)	
		MCDB	82.8	80.4	77.1	70.8	64.2	58.1	56.5	60.7	68.5	72.0	76.9	81.3	(30)	
	5%	WB	67.8	67.4	65.0	60.0	55.3	51.2	49.7	50.9	55.1	58.3	62.6	64.9	(31)	
		MCDB	80.3	78.2	74.6	67.6	61.8	56.0	54.9	58.2	65.4	69.4	73.9	77.7	(32)	
	10%	WB	65.9	65.6	63.4	58.5	53.8	49.9	48.3	49.3	53.1	56.4	60.7	63.0	(33)	
		MCDB	77.9	75.3	72.2	65.0	59.8	54.4	53.6	56.0	61.6	66.3	70.5	74.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	17.8	16.8	15.5	13.8	11.1	9.7	10.6	12.4	15.0	16.8	16.7	17.7	(35)	
		MCDBR	26.9	25.1	22.5	19.3	14.2	12.2	13.3	15.7	20.9	24.7	24.5	27.0	(36)	
	5% WB	MCWBR	9.3	9.2	8.7	8.9	8.1	7.6	7.9	8.7	9.8	10.3	10.1	10.6	(37)	
		MCWBR	22.8	20.7	18.6	16.2	12.7	10.4	11.6	14.2	18.7	21.0	20.6	22.6	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.392	0.356	0.325	0.315	0.294	0.283	0.279	0.291	0.312	0.325	0.334	0.358	(40)	
		taud	2.375	2.517	2.600	2.599	2.636	2.662	2.676	2.627	2.562	2.546	2.554	2.481	(41)	
	Ebn at Noon		298	302	300	284	272	267	276	289	299	309	315	311	(42)	
		Edh at Noon	41	34	29	25	21	19	20	24	29	32	34	37	(43)	
(44) All-Sky Solar Radiation	RadAvg		2106	1814	1515	1102	787	618	716	986	1358	1730	1953	2167	(44)	
	RadStd		144	126	114	82	40	45	43	55	98	109	142	145	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.58	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (27 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-157	+227	+85

Nomenclature: See separate page