

MOUNT NOWA NOWA, AustraliaWMO: **949300**Lat: **37.6925S**Lon: **148.0908E**Elev: **350**StdP: **97.19**Time Zone: **10.00 (AUS)**Period: **98-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.7	4.5	-3.0	3.0	13.2	-1.5	3.5	11.5	9.7	11.6	8.4	10.8	4.0	270	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.9	33.0	18.5	30.3	18.1	28.0	17.8	20.8	27.6	19.8	26.6	19.0	25.4	3.5	320

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
18.7	14.2	22.6	17.8	13.4	21.5	17.0	12.6	20.9	61.6	27.8	58.2	26.9	55.3	25.5	24.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.1	7.1	6.3	DB	2.4	39.0	0.6	2.4	2.0	40.7	1.6	42.1	1.3	43.4	0.8	45.2	(4)
(5)			WB	1.1	22.5	0.6	1.2	0.7	23.3	0.4	24.0	0.1	24.7	-0.3	25.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.1	19.2	18.9	17.6	14.8	12.1	9.9	9.5	10.1	11.9	13.3	15.5	17.2	(6)	
	DBStd	4.83	4.50	3.91	3.88	3.18	2.71	2.19	2.08	2.51	3.15	3.70	4.21	4.25	(7)	
	HDD10.0	123	0	0	0	2	9	27	36	29	12	7	2	0	(8)	
	HDD18.3	1771	41	37	62	115	193	252	275	256	195	163	108	74	(9)	
	CDD10.0	1634	286	248	236	145	74	24	19	32	69	111	166	224	(10)	
	CDD18.3	241	69	52	39	8	1	0	0	0	2	8	23	39	(11)	
	CDH23.3	2106	689	415	265	40	1	0	0	0	12	81	206	398	(12)	
(13)	CDH26.7	808	306	156	87	8	0	0	0	0	2	19	69	161	(13)	
(14)	Wind	WSAvg	3.0	2.7	2.6	2.8	2.9	3.3	3.2	3.6	3.4	3.3	3.1	2.8	2.8	(14)
(15) Precipitation	PrecAvg	796	62	65	56	70	47	97	60	55	71	73	77	71	(15)	
	PrecMax	1053	146	159	168	185	137	317	142	117	170	149	193	159	(16)	
	PrecMin	548	14	12	16	11	19	19	16	13	31	16	15	17	(17)	
	PrecStd	136	32	39	31	48	29	80	37	27	36	35	39	33	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	38.5	35.0	32.8	27.2	21.4	17.9	17.2	20.1	24.9	29.4	32.6	35.2	(19)	
		MCWB	20.1	19.4	18.2	16.3	13.6	11.5	10.5	12.0	13.5	15.5	16.7	18.7	(20)	
	2%	DB	33.0	30.9	29.1	24.1	19.3	15.9	15.6	17.6	21.9	25.5	28.4	31.1	(21)	
		MCWB	19.2	18.7	17.8	15.5	13.0	10.6	9.8	10.7	12.8	14.6	16.6	17.8	(22)	
	5%	DB	29.8	28.1	26.2	21.6	17.9	14.4	14.2	15.8	19.6	22.5	25.4	27.8	(23)	
		MCWB	18.5	18.6	17.3	14.7	12.5	9.9	9.1	9.8	12.1	13.8	16.3	17.5	(24)	
(25) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	10%	DB	27.0	25.5	23.6	19.6	16.3	13.3	12.8	14.3	17.5	20.0	22.6	24.7	(25)	
		MCWB	18.4	18.1	16.8	14.0	11.5	9.3	8.4	9.1	11.4	12.9	15.2	16.6	(26)	
	0.4%	WB	22.4	21.8	20.6	17.6	15.2	12.9	11.8	13.0	15.2	17.3	19.8	20.9	(27)	
		MCDB	30.5	28.1	26.3	24.3	19.0	16.2	15.5	17.6	21.3	24.4	27.0	29.1	(28)	
	2%	WB	21.0	20.6	19.3	16.4	14.0	11.6	10.7	11.5	14.0	15.9	18.0	19.4	(29)	
		MCDB	28.2	26.9	25.1	21.6	17.9	14.5	13.6	16.0	20.3	22.2	24.9	27.4	(30)	
(31) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	5%	WB	19.9	19.7	18.3	15.5	13.0	10.7	9.8	10.5	12.9	14.6	17.0	18.3	(31)	
		MCDB	26.9	25.7	23.7	19.8	16.6	13.3	12.7	14.5	18.5	20.8	23.3	25.4	(32)	
	10%	WB	18.8	18.7	17.4	14.7	12.1	9.9	9.1	9.6	11.7	13.6	15.9	17.2	(33)	
		MCDB	25.5	24.1	22.3	18.4	15.4	12.5	12.0	13.3	16.5	19.0	21.4	23.4	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	9.9	9.3	8.6	7.7	6.2	5.4	5.9	6.9	8.4	9.3	9.3	9.9	(35)	
		MCDBR	14.9	14.0	12.5	10.7	7.9	6.8	7.4	8.7	11.6	13.7	13.6	15.0	(36)	
	5% WB	MCWBR	5.2	5.1	4.8	4.9	4.5	4.2	4.4	4.8	5.4	5.7	5.6	5.9	(37)	
		MCWBR	12.6	11.5	10.3	9.0	7.0	5.8	6.4	7.9	10.4	11.6	11.4	12.5	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.392	0.356	0.325	0.315	0.294	0.283	0.279	0.291	0.312	0.325	0.334	0.358	(40)	
		taud	2.375	2.517	2.600	2.599	2.636	2.662	2.676	2.627	2.562	2.546	2.554	2.481	(41)	
	Ebn at Noon		941	953	946	895	859	843	871	910	944	974	992	979	(42)	
		Edh at Noon	128	106	90	79	66	60	62	75	92	102	106	116	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.64	5.72	4.78	3.48	2.48	1.95	2.26	3.11	4.28	5.45	6.16	6.83	(44)	
	RadStd		0.45	0.40	0.36	0.26	0.13	0.14	0.13	0.17	0.31	0.34	0.45	0.46	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.32	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (27 neighbors)	+0.35	N/A	N/A	N/A	N/A	N/A	N/A	-87	+126	+47

Nomenclature: See separate page