

GABO ISLAND, AustraliaWMO: **949330**Lat: **37.568S**Lon: **149.916E**Elev: **49**StdP: **14.67**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	45.5	46.7	33.0	27.6	53.1	35.6	30.6	52.9	43.6	53.2	40.0	52.1	14.0	290	0.693

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.8	75.8	67.9	74.0	67.3	72.6	66.6	70.1	73.5	69.0	72.3	68.0	71.1	19.3	30

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
68.7	105.7	72.0	67.6	101.7	71.1	66.6	98.2	70.2	34.1	73.9	33.2	72.3	32.3	71.3	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 40.5	36.1	32.8	DB	43.4	83.1	0.9	4.9	42.8	86.7	42.3	89.5	41.8	92.3	41.1	95.9	(4)
(5)			WB	39.2	72.2	1.4	2.0	38.2	73.7	37.4	74.8	36.6	75.9	35.6	77.4	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	59.8	66.4	66.7	65.4	62.0	58.0	54.8	53.1	53.4	55.6	57.9	60.7	63.6
	DBStd	5.85	3.38	3.33	3.47	3.49	3.28	2.63	2.57	2.94	3.28	3.84	3.76	3.86
	HDD50	9	0	0	0	0	0	1	3	4	1	0	0	0
	HDD65	2152	24	19	38	102	216	307	369	359	283	223	137	75
	CDD50	3569	509	467	478	359	249	144	98	110	169	245	321	420
	CDD65	238	68	66	50	11	1	0	0	1	3	8	30	30
	CDH74	184	45	45	20	9	0	0	0	1	6	21	9	28
	CDH80	20	1	1	1	3	0	0	0	0	1	6	4	3
Wind	WSAvg	16.3	18.2	16.8	16.5	15.0	14.8	14.4	14.5	15.1	17.3	17.2	18.2	18.3
Precipitation	PrecAvg	37.7	2.9	2.4	3.0	3.5	3.7	3.1	3.6	2.9	3.1	2.9	3.3	3.1
	PrecMax	59.2	14.8	7.5	10.2	16.3	15.1	11.7	12.0	7.3	7.1	8.3	10.1	10.4
	PrecMin	23.0	0.2	0.1	0.4	0.4	0.6	0.6	0.4	0.2	0.5	0.7	0.0	0.2
	PrecStd	9.7	2.6	1.9	2.1	3.2	2.6	2.2	2.7	1.5	1.8	1.9	2.3	2.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.5	77.9	76.1	73.8	69.9	64.7	64.2	67.2	71.7	75.9	73.4	77.3
		MCWB	69.1	69.8	68.5	64.2	59.8	57.4	53.5	55.2	57.6	58.9	64.6	66.3
	2%	DB	75.2	75.2	73.7	70.8	67.3	62.4	61.0	62.5	65.4	68.5	70.2	73.4
		MCWB	68.4	69.1	67.1	63.9	60.0	57.0	53.2	54.4	57.8	60.6	63.8	66.6
	5%	DB	73.5	73.5	72.1	69.0	65.3	60.8	59.2	60.4	63.1	66.1	68.3	71.3
		MCWB	67.4	68.1	66.4	63.2	59.2	55.8	52.8	54.2	57.2	60.4	62.9	65.5
	10%	DB	71.9	72.1	70.7	67.4	63.6	59.4	57.7	58.8	61.4	64.0	66.6	69.6
		MCWB	66.7	67.3	65.7	62.6	58.1	54.7	52.1	53.3	56.1	59.4	61.8	64.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.8	72.3	70.3	67.5	64.2	60.6	57.4	59.4	61.2	64.2	66.6	69.1
		MCDB	75.0	75.1	73.8	70.3	66.3	62.6	59.8	61.9	64.4	67.3	70.5	73.3
	2%	WB	69.5	70.6	68.9	65.8	62.4	58.6	55.7	57.2	59.8	62.7	65.1	67.5
		MCDB	73.3	73.7	72.0	68.8	65.0	61.0	58.3	60.6	63.4	65.9	68.6	71.2
	5%	WB	68.5	69.3	67.7	64.7	60.6	57.1	54.5	55.5	58.2	61.5	63.9	66.4
		MCDB	72.0	72.4	70.7	67.7	64.0	59.5	57.5	58.8	62.0	64.6	67.2	69.9
	10%	WB	67.5	68.1	66.6	63.5	59.0	55.7	53.2	54.0	56.8	60.1	62.7	65.4
		MCDB	70.9	71.1	69.8	66.8	63.0	58.7	56.8	57.9	60.6	63.5	66.0	68.9
Mean Daily Temperature Range	5% DB	MDBR	7.8	7.8	7.9	8.5	8.3	7.7	8.3	9.0	9.0	9.3	8.1	8.2
		MCDBR	9.8	9.5	9.4	10.5	10.5	9.4	10.6	11.7	12.3	12.9	10.6	10.4
		MCWBR	6.0	6.3	6.0	6.7	7.3	6.7	7.5	8.0	8.2	7.8	6.7	6.4
	5% WB	MCDBR	8.5	8.8	8.2	9.0	9.0	8.0	8.8	10.1	10.4	10.9	9.6	9.2
		MCWBR	5.9	6.7	5.8	6.5	7.3	6.5	7.1	8.0	8.3	7.6	6.8	6.5
Clear-Sky Solar Irradiance	taub	0.419	0.381	0.353	0.336	0.320	0.307	0.298	0.308	0.341	0.350	0.365	0.373	
	taud	2.345	2.499	2.562	2.590	2.590	2.622	2.643	2.611	2.513	2.516	2.501	2.494	
	Ebn at Noon	290	295	291	277	262	258	268	282	290	301	305	306	
	Edh at Noon	42	35	30	26	22	20	21	24	31	33	36	36	
All-Sky Solar Radiation	RadAvg	2075	1778	1492	1101	791	626	730	992	1378	1740	1957	2119	
	RadStd	136	126	98	75	41	42	51	54	88	86	135	143	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)		+0.68	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+209	+77

Nomenclature: See separate page