

MALLACOOTA, Australia

WMO: 949350

Lat: 37.5975S

Lon: 149.7289E

Elev: 22

StdP: 101.06

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	3.9	4.8	-0.4	3.7	10.0	0.8	4.0	9.1	9.7	12.1	8.5	11.9	3.4	300	0.487

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.8	28.9	20.4	26.9	20.0	25.3	19.5	21.7	26.4	20.9	25.1	20.2	24.0	5.2	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.2	14.9	23.6	19.5	14.3	23.0	18.8	13.7	22.4	63.5	26.5	60.7	25.2	58.2	23.9	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9.1	8.1	7.3	1.8	35.5	0.7	2.5	1.3	37.4	0.9	38.8	0.5	40.3	0.0	42.1
			1.0	23.7	0.7	1.3	0.5	24.6	0.1	25.4	-0.3	26.1	-0.8	27.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.8	19.5	19.4	18.1	15.6	13.2	11.2	10.4	10.8	12.5	14.0	15.9	17.5	(6)
	DBStd	4.07	3.25	2.98	2.76	2.44	2.03	1.72	1.62	1.96	2.39	2.81	3.02	3.20	(7)
	HDD10.0	38	0	0	0	0	1	7	14	12	3	1	0	0	(8)
	HDD18.3	1481	24	19	38	88	160	214	247	233	176	138	87	56	(9)
	CDD10.0	1793	293	263	251	168	100	43	26	37	78	126	177	232	(10)
	CDD18.3	193	58	49	31	6	0	0	0	0	1	5	13	29	(11)
	CDH23.3	907	301	208	108	20	1	0	0	1	11	31	67	159	(12)
	CDH26.7	214	79	47	17	4	0	0	0	0	3	9	16	40	(13)
(14) Wind	WSAvg	3.8	4.2	4.0	3.8	3.5	3.5	3.5	3.5	3.6	3.8	4.1	4.2	4.2	(14)
(15) Precipitation	PrecAvg	991	72	89	71	79	89	107	89	80	78	74	84	85	(15)
	PrecMax	1260	238	196	214	285	194	318	282	178	209	194	190	172	(16)
	PrecMin	703	11	16	7	5	32	27	28	28	27	22	21	24	(17)
	PrecStd	140	51	56	54	65	38	74	55	37	44	36	43	44	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	30.8	28.8	25.5	22.0	18.8	18.9	21.0	24.2	27.1	28.6	30.8	(19)
		MCWB	21.3	21.2	20.2	18.5	15.6	13.3	12.1	12.8	14.6	16.9	19.3	20.1	(20)
	2%	DB	28.7	27.8	26.1	22.9	20.1	17.0	16.7	18.2	20.9	23.1	25.0	27.1	(21)
		MCWB	21.0	20.7	19.8	17.4	15.1	13.0	11.5	12.0	14.4	16.1	18.0	19.8	(22)
	5%	DB	26.5	25.8	24.1	21.1	18.4	15.9	15.3	16.4	19.0	21.0	22.7	24.8	(23)
		MCWB	20.4	20.3	19.2	16.8	14.4	12.3	10.9	11.5	13.9	15.4	17.4	19.1	(24)
	10%	DB	24.5	24.0	22.4	19.8	17.2	14.9	14.1	15.1	17.2	19.1	20.8	22.7	(25)
		MCWB	19.8	19.6	18.6	16.3	13.8	11.8	10.5	11.0	13.0	14.8	16.6	18.3	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.8	23.0	21.7	19.5	17.2	15.2	13.7	14.6	16.5	18.5	20.4	21.7	(27)
		MCDB	28.5	27.6	25.7	23.4	19.3	16.9	16.0	17.6	20.6	23.2	25.7	27.1	(28)
	2%	WB	21.7	21.7	20.6	18.3	16.1	13.9	12.7	13.3	15.3	17.2	19.0	20.4	(29)
		MCDB	26.7	25.9	24.4	21.2	18.8	16.0	15.1	16.5	19.4	21.2	23.4	25.2	(30)
	5%	WB	20.9	20.7	19.7	17.5	15.2	13.0	11.8	12.3	14.4	16.3	18.0	19.5	(31)
		MCDB	25.1	24.4	23.1	20.2	17.9	15.2	14.4	15.4	18.0	19.9	21.7	23.6	(32)
	10%	WB	20.2	20.0	19.0	16.7	14.2	12.2	11.0	11.5	13.4	15.2	17.1	18.7	(33)
		MCDB	24.0	23.2	22.0	19.4	16.7	14.4	13.5	14.6	16.8	18.7	20.2	22.3	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	7.8	7.5	7.5	7.7	7.7	7.5	8.0	8.5	8.5	8.5	7.7	7.9	(35)
		MCDBR	11.2	10.4	9.9	9.9	9.9	9.2	10.1	11.0	11.6	11.8	10.9	11.3	(36)
		MCWBR	5.2	4.9	5.0	5.6	6.2	5.9	6.4	6.5	6.4	6.2	5.8	5.5	(37)
	5% WB	MCDBR	9.6	9.2	8.4	8.3	8.5	7.9	8.8	9.6	10.3	10.6	9.6	10.0	(38)
		MCWBR	5.0	4.9	4.7	5.1	5.7	5.6	6.0	6.2	6.4	6.2	5.5	5.4	(39)
(40) Clear-Sky Solar Irradiance	taub		0.417	0.380	0.352	0.336	0.319	0.305	0.297	0.307	0.339	0.349	0.362	0.372	(40)
	taud		2.346	2.496	2.555	2.582	2.588	2.624	2.642	2.613	2.515	2.514	2.507	2.492	(41)
	Ebn at Noon		917	929	916	871	827	814	847	892	915	950	964	966	(42)
	Edh at Noon		132	109	95	81	70	63	65	77	97	106	111	115	(43)
(44) All-Sky Solar Radiation	RadAvg		6.53	5.60	4.69	3.46	2.49	1.97	2.29	3.12	4.34	5.47	6.15	6.67	(44)
	RadStd		0.43	0.40	0.32	0.24	0.13	0.13	0.16	0.17	0.28	0.28	0.42	0.47	(45)

Historical Trends

		Heating		Cooling			Degree-Days					
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+0.32	N/A	N/A	+0.79	N/A	N/A	N/A	N/A	+164	+65	(46)
(47)	Regional (17 neighbors)	+0.39	N/A	N/A	N/A	N/A	N/A	N/A	-88	+126	+48	(47)

Nomenclature: See separate page