

HOGAN ISLAND, Australia

WMO: 949490

Lat: 39.222S

Lon: 146.984E

Elev: 117

StdP: 99.93

Time Zone: 10.00 (AUS)

Period: 03-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.2	7.9	1.4	4.2	9.1	2.4	4.6	9.3	28.4	10.6	26.3	10.3	13.3	260	0.966

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.7	25.3	18.1	23.0	18.2	21.7	18.1	20.4	22.3	19.7	21.5	19.0	20.8	6.7	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.0	14.9	20.9	19.2	14.2	20.3	18.4	13.5	19.8	59.4	22.5	57.0	21.6	54.7	20.7	22.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
24.8	22.4	20.3	DB	5.6	31.0	0.8	3.1	5.0	33.2	4.6	35.1	4.2	36.8	3.6	39.1	
			WB	4.0	21.8	0.7	0.7	3.5	22.3	3.0	22.7	2.6	23.0	2.1	23.5	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	17.8	17.9	17.2	15.5	13.5	11.8	10.8	10.8	11.6	12.9	14.6	16.3		
	DBStd	3.16	2.29	1.92	2.16	1.91	1.62	1.40	1.24	1.43	1.60	1.99	2.22	2.02		
	HDD10.0	18	0	0	0	0	0	2	6	7	3	1	0	0		
	HDD18.3	1569	37	28	48	87	149	197	232	234	202	170	116	69		
	CDD10.0	1553	242	220	223	166	109	55	32	32	52	90	138	196		
	CDD18.3	62	20	16	13	2	0	0	0	0	0	1	3	7		
	CDH23.3	183	75	17	36	5	0	0	0	0	0	6	14	31		
	CDH26.7	44	23	2	9	0	0	0	0	0	0	0	2	8		
(14) Wind	WSAvg	10.2	9.4	9.7	9.6	9.3	10.7	10.3	11.4	11.0	11.0	10.1	10.2	10.0		
(15) Precipitation	PrecAvg	960	54	51	58	73	87	111	123	119	91	74	66	54		
	PrecMax	1269	163	136	241	191	168	223	265	292	188	149	130	118		
	PrecMin	581	6	11	15	22	22	19	35	38	29	9	9	19		
	PrecStd	196	39	33	43	37	46	47	52	61	41	37	32	28		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	29.5	25.7	27.4	23.7	18.7	16.1	15.2	16.3	19.5	23.7	25.7	27.1		
		MCWB	19.5	19.2	18.5	15.9	14.2	13.2	10.9	11.8	13.5	15.3	17.3	18.1		
	2%	DB	25.0	23.0	23.0	20.6	17.6	15.1	13.9	14.8	16.3	19.3	21.9	22.5		
		MCWB	19.1	19.2	18.2	16.0	14.1	12.7	10.9	11.4	12.6	13.9	16.5	17.5		
	5%	DB	22.5	21.8	21.2	19.0	16.7	14.4	13.2	13.7	14.9	17.1	19.6	20.6		
		MCWB	19.0	19.0	18.3	16.0	13.9	12.3	10.7	10.9	12.1	13.9	15.9	17.2		
	10%	DB	21.1	20.7	20.1	18.0	15.9	13.7	12.7	12.9	14.0	15.7	17.8	19.3		
		MCWB	18.3	18.2	17.8	15.6	13.8	11.8	10.5	10.5	11.5	13.5	15.4	16.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.9	21.1	20.9	18.2	16.3	14.6	12.7	12.7	14.6	16.4	18.4	19.5		
		MCDB	24.3	22.7	22.4	19.5	16.9	15.1	13.1	14.0	16.4	19.3	21.6	22.5		
	2%	WB	20.4	20.4	19.9	17.3	15.3	13.6	11.8	12.1	13.2	15.3	17.2	18.5		
		MCDB	22.6	21.8	21.4	18.7	16.3	14.5	12.7	13.7	15.5	17.4	20.0	21.3		
	5%	WB	19.6	19.7	19.0	16.7	14.6	12.7	11.3	11.6	12.4	14.5	16.5	17.7		
		MCDB	21.7	21.0	20.4	18.2	15.9	14.0	12.5	13.2	14.4	16.5	18.6	20.0		
	10%	WB	18.8	19.0	18.0	15.9	13.9	12.1	10.9	11.0	11.8	13.7	15.6	17.0		
		MCDB	20.9	20.3	19.9	17.8	15.6	13.5	12.3	12.5	13.6	15.6	17.4	18.9		
(35) Mean Daily Temperature Range	5% DB	MDBR	5.4	4.7	4.6	3.9	3.0	2.7	2.8	3.4	4.0	4.8	5.0	5.3		
		MCDBR	7.9	5.9	6.2	5.2	3.9	3.2	3.3	4.3	5.6	7.1	7.6	7.5		
		MCWBR	3.9	3.4	3.4	3.0	2.6	2.4	2.4	2.7	3.4	3.6	3.9	4.0		
	5% WB	MCDBR	6.9	5.2	6.0	4.7	3.3	2.9	2.8	3.9	4.9	6.0	6.4	6.6		
		MCWBR	4.1	3.5	3.5	3.1	2.7	2.5	2.5	2.9	3.3	3.7	3.9	3.9		
(40) Clear-Sky Solar Irradiance	taub		0.358	0.355	0.335	0.324	0.310	0.304	0.302	0.311	0.337	0.338	0.343	0.345		
	taud		2.519	2.547	2.601	2.610	2.617	2.617	2.627	2.601	2.524	2.540	2.547	2.553		
	Ebn at Noon		972	951	931	877	827	801	829	878	912	958	982	991		
	Edh at Noon		110	103	89	77	66	61	64	76	95	102	107	108		
(44) All-Sky Solar Radiation	RadAvg		6.98	6.04	4.76	3.30	2.21	1.75	2.00	2.85	4.09	5.47	6.44	7.16		
	RadStd		0.42	0.29	0.25	0.17	0.10	0.12	0.08	0.14	0.27	0.31	0.38	0.39		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (14 neighbors)	+0.45	N/A	N/A	N/A	N/A	+0.39	N/A	-116	+156	+50

Nomenclature: See separate page