

SHEFFIELD, Australia

WMO: 949550

Lat: 41.3886S

Lon: 146.3219E

Elev: 966

StdP: 14.19

Time Zone: 10.00 (AUS)

Period: 97-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	33.2	34.9	26.6	21.3	41.1	28.5	23.2	41.1	28.3	46.4	25.0	46.5	3.6	340	0.568

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	18.4	77.6	63.5	74.2	62.0	71.5	60.8	66.1	73.6	64.3	70.3	62.8	68.8	10.1	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
63.6	91.2	68.4	62.0	86.1	67.2	60.3	80.9	65.7	31.4	74.1	30.0	70.3	28.9	68.8	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 24.0	20.9	18.3	DB	30.2	84.8	1.1	4.8	29.4	88.2	28.7	91.0	28.1	93.7	27.4	97.2	(4)
(5)			WB	29.1	69.7	1.4	1.6	28.2	70.9	27.4	71.8	26.6	72.7	25.6	73.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.1	60.8	60.7	57.8	52.9	48.9	46.1	44.9	45.4	47.3	50.2	54.3	57.0
	DBStd	7.00	5.09	4.72	4.91	4.24	3.76	3.34	3.01	3.37	3.58	4.15	4.60	4.67
	HDD50	673	0	0	2	20	66	122	159	146	95	49	11	3
	HDD65	4738	150	135	229	363	500	566	623	608	530	460	321	253
	CDD50	1459	336	299	245	107	32	6	1	4	15	54	141	219
	CDD65	45	20	14	7	0	0	0	0	0	0	0	0	4
	CDH74	329	180	71	35	1	0	0	0	0	0	0	9	33
	CDH80	58	45	6	4	0	0	0	0	0	0	0	0	3
Wind	WSAvg	7.8	8.5	7.7	7.2	6.7	7.3	6.7	7.4	7.9	8.4	8.4	8.3	8.7
Precipitation	PrecAvg	39.5	2.4	2.0	1.9	2.6	3.5	4.3	5.2	5.1	4.2	3.0	2.9	2.4
	PrecMax	61.9	7.5	4.8	4.6	7.3	8.9	11.7	8.7	11.2	7.7	7.4	6.8	6.0
	PrecMin	19.9	0.1	0.2	0.1	0.7	0.4	0.5	2.2	1.3	1.1	0.5	0.5	0.2
	PrecStd	8.3	2.0	1.1	1.3	1.5	2.2	2.2	1.8	2.4	1.8	1.6	1.7	1.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	85.4	80.1	78.1	69.2	61.8	57.6	55.4	57.6	62.1	68.7	74.7	78.4
		MCWB	63.9	64.9	65.0	59.1	54.7	51.8	49.9	51.0	53.7	57.5	60.9	63.5
	2%	DB	78.3	75.8	73.1	65.4	58.9	55.0	53.2	55.0	58.7	64.2	70.4	72.8
		MCWB	63.3	63.8	61.8	57.2	53.4	50.6	48.8	49.9	51.4	55.9	59.5	60.7
	5%	DB	74.4	72.8	69.5	62.7	57.2	53.5	51.8	53.2	56.3	61.0	66.6	69.8
		MCWB	61.9	61.7	60.4	56.0	52.7	49.9	48.4	49.1	50.3	53.9	57.6	59.2
	10%	DB	71.1	70.1	66.6	60.4	55.6	52.1	50.5	51.7	54.4	58.6	63.7	66.8
		MCWB	60.5	60.3	58.4	54.7	51.7	48.9	47.6	48.2	49.3	52.6	55.9	57.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	69.2	68.3	66.7	61.6	57.3	53.9	52.4	53.6	55.6	60.0	64.1	65.7
		MCDB	80.3	75.9	75.2	65.6	58.7	55.2	53.5	55.1	58.8	64.5	70.3	74.5
	2%	WB	66.2	65.8	64.3	59.4	55.5	52.2	50.5	51.7	53.5	57.6	61.2	63.2
		MCDB	74.3	72.2	69.7	62.8	57.5	53.8	51.8	53.4	56.5	61.7	67.3	69.6
	5%	WB	64.1	63.9	62.5	57.6	54.0	50.9	49.3	50.0	51.6	55.6	59.1	61.3
		MCDB	70.7	69.6	67.5	60.9	56.0	52.6	50.9	52.1	55.0	59.5	64.5	67.2
	10%	WB	62.1	62.3	60.4	55.9	52.6	49.5	48.2	48.7	50.0	53.6	57.1	59.2
		MCDB	68.9	68.1	64.8	59.4	54.9	51.4	50.0	51.0	53.5	57.8	62.5	64.9
Mean Daily Temperature Range	5% DB	MDBR	18.4	17.1	16.1	14.5	12.4	11.3	11.0	11.9	13.4	15.2	16.4	17.0
		MCDBR	23.1	20.2	19.0	17.0	13.5	12.0	11.6	13.3	15.5	18.1	20.4	21.4
		MCWBR	11.5	10.3	10.3	10.4	9.7	9.0	8.8	9.7	10.5	12.1	12.3	11.9
	5% WB	MCDBR	20.3	17.6	17.3	14.7	11.4	10.3	9.9	11.8	14.0	16.2	17.7	18.2
		MCWBR	12.3	10.4	11.2	10.3	9.3	8.5	8.5	9.6	10.5	12.1	11.6	11.9
Clear-Sky Solar Irradiance	taub	0.333	0.328	0.317	0.307	0.293	0.287	0.287	0.301	0.322	0.323	0.326	0.325	
	taud	2.528	2.557	2.582	2.591	2.604	2.605	2.614	2.573	2.499	2.512	2.531	2.546	
	Ebn at Noon	316	309	299	280	263	254	263	278	292	307	316	320	
	Edh at Noon	34	32	28	24	20	18	20	24	30	33	34	34	
All-Sky Solar Radiation	RadAvg	2194	1871	1414	957	611	476	518	767	1129	1630	1966	2146	
	RadStd	143	81	62	63	47	47	30	64	83	94	145	149	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (32 neighbors)	+0.56	N/A	N/A	+1.22	+0.63	+0.77	N/A	-176	+191	+22

Nomenclature: See separate page