

STRAHAN, Australia

WMO: 949560

Lat: 42.1533S

Lon: 145.2923E

Elev: 22

StdP: 101.06

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	1.3	2.4	-0.2	3.7	5.2	0.7	4.0	5.3	15.4	9.7	14.0	9.8	1.9	40	0.637

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.5	27.2	17.9	24.9	16.9	22.9	16.3	19.0	24.7	18.0	22.8	17.1	21.6	6.6	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.1	12.2	20.3	16.1	11.4	19.6	15.1	10.8	18.8	54.1	24.8	50.8	22.8	48.0	21.7	28.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.9	11.4	10.2	DB	-0.8	32.8	0.9	1.7	-1.5	34.1	-2.0	35.1	-2.4	36.1	-3.1	37.4	(4)
			WB	-0.9	21.7	0.8	1.9	-1.5	23.0	-2.0	24.1	-2.4	25.2	-3.1	26.5	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	12.0	15.5	15.7	14.5	12.4	10.7	9.2	8.7	9.0	10.1	11.2	12.8	14.1
	DBStd	3.49	2.81	2.93	2.80	2.49	2.31	2.11	2.02	2.14	2.26	2.59	2.84	2.78
	HDD10.0	199	0	0	1	5	19	39	50	44	26	12	3	1
	HDD18.3	2358	99	85	125	178	235	273	299	288	248	222	170	136
	CDD10.0	919	169	159	139	78	42	16	9	14	27	49	86	128
	CDD18.3	37	11	11	6	1	0	0	0	0	0	1	3	6
	CDH23.3	392	109	106	56	4	0	0	0	0	1	11	39	66
	CDH26.7	96	29	27	12	0	0	0	0	0	0	2	8	18
Wind	WSAvg	4.9	4.8	4.4	4.4	4.5	4.8	4.5	4.9	5.2	5.6	5.3	5.0	5.2
Precipitation	PrecAvg	2073	118	97	145	154	200	208	228	240	210	184	150	139
	PrecMax	2646	206	260	281	260	422	411	378	432	359	291	236	303
	PrecMin	1735	42	32	62	41	42	73	127	90	74	28	33	42
	PrecStd	224	46	52	48	53	92	83	62	88	71	59	55	49
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.3	30.2	28.0	23.8	18.9	16.1	15.0	17.5	20.6	24.7	27.7	29.3
		MCWB	19.1	19.0	18.6	16.3	13.9	12.2	11.2	11.7	13.4	15.4	16.7	17.0
	2%	DB	26.2	26.4	24.7	20.8	16.9	14.5	13.6	15.4	17.5	21.1	23.6	24.8
		MCWB	17.8	18.2	16.9	15.0	13.0	11.6	10.7	11.0	12.1	13.5	15.4	16.4
	5%	DB	23.5	23.8	22.0	18.5	15.5	13.5	12.7	13.8	15.6	18.2	20.6	21.9
		MCWB	17.0	17.3	16.4	14.2	12.7	11.2	10.3	10.6	11.5	12.8	14.6	15.6
	10%	DB	21.1	21.5	19.8	16.8	14.3	12.7	12.0	12.6	14.0	15.8	18.1	19.5
		MCWB	16.0	16.4	15.6	13.6	12.2	10.8	9.9	10.1	10.8	11.9	13.5	14.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.4	20.4	19.4	17.1	14.7	13.1	12.5	12.7	14.8	16.1	18.2	19.1
		MCDB	26.0	27.1	25.7	21.5	16.7	14.4	13.8	15.0	18.1	21.7	23.7	25.1
	2%	WB	18.8	18.9	17.9	15.7	13.9	12.4	11.5	11.7	13.0	14.5	16.6	17.4
		MCDB	24.5	24.4	22.5	19.0	15.6	13.7	12.7	13.8	15.7	18.9	21.8	22.8
	5%	WB	17.5	17.9	16.9	14.8	13.2	11.7	10.8	11.1	12.0	13.3	15.1	16.2
		MCDB	22.4	22.4	20.8	17.8	14.8	13.1	12.2	13.0	14.6	17.2	19.8	21.0
	10%	WB	16.4	16.8	15.9	14.0	12.5	11.1	10.2	10.5	11.3	12.3	13.9	15.1
		MCDB	20.7	21.0	19.5	16.6	14.1	12.5	11.6	12.3	13.6	15.4	17.3	18.9
Mean Daily Temperature Range	5% DB	MDBR	9.3	9.5	8.6	7.6	6.0	6.1	6.1	6.6	7.2	8.2	8.6	8.6
		MCDBR	14.6	14.0	12.9	10.7	6.8	6.4	6.4	7.9	9.8	12.6	14.0	13.9
		MCWBR	7.4	7.1	6.9	6.4	4.6	4.7	4.6	5.0	5.8	6.6	7.2	6.9
	5% WB	MCDBR	12.8	12.0	11.6	9.2	5.7	5.4	5.4	6.6	7.9	10.8	12.1	11.9
	MCWBR	7.0	6.8	6.7	6.7	5.9	4.6	4.4	4.4	4.8	5.2	6.2	7.0	6.6
Clear-Sky Solar Irradiance	taub	0.344	0.341	0.328	0.317	0.314	0.316	0.316	0.305	0.334	0.349	0.341	0.338	0.338
	taud	2.538	2.554	2.600	2.608	2.593	2.559	2.559	2.603	2.510	2.464	2.503	2.532	2.548
	Ebn at Noon	983	958	928	869	798	754	800	832	887	948	982	994	994
	Edh at Noon	107	100	87	74	64	60	62	80	98	104	107	107	107
All-Sky Solar Radiation	RadAvg	6.31	5.57	4.01	2.73	1.62	1.29	1.45	2.16	3.21	4.68	5.85	6.25	6.25
	RadStd	0.44	0.41	0.26	0.20	0.14	0.12	0.12	0.18	0.20	0.31	0.47	0.47	0.47

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		N/A	N/A	N/A	N/A	+0.56	+0.54	N/A	N/A	N/A	N/A
Regional (27 neighbors)		+0.31	N/A	N/A	+0.65	+0.32	+0.40	N/A	-98	+104	+12

Nomenclature: See separate page