

MAATSUYKER ISLAND LH, Australia

WMO: 949620

Lat: 43.657S Lon: 146.272E Elev: 486 StdP: 14.44 Time Zone: 10.00 (AUS) Period: 94-19 WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	40.8	42.0	29.5	24.0	46.3	31.4	26.1	46.1	66.9	48.8	61.9	47.8	25.0	320	0.915

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.0	74.7	59.5	70.5	58.7	67.2	57.8	62.4	69.1	60.8	67.1	59.4	65.0	16.3	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
60.2	79.3	63.8	58.5	74.5	62.5	57.0	70.6	61.3	28.4	69.7	27.2	67.1	26.3	65.3	71.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 59.0	53.6	48.8	DB	38.3	82.8	1.3	2.5	37.3	84.6	36.5	86.0	35.8	87.5	34.8	89.3	(4)
(5)			WB	34.7	65.5	1.0	2.1	34.0	67.0	33.5	68.2	32.9	69.4	32.2	70.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	52.5	57.2	57.7	56.4	53.8	51.6	49.5	48.6	48.3	49.2	50.5	52.3	54.6
	DBStd	5.17	4.58	4.53	4.50	4.04	3.56	3.16	2.87	3.31	3.83	4.23	4.49	4.61
	HDD50	334	1	0	2	7	21	46	62	74	58	39	19	5
	HDD65	4605	249	212	272	337	416	464	510	518	473	449	381	324
	CDD50	1227	225	215	199	121	70	31	17	21	35	55	89	149
	CDD65	27	8	8	5	1	0	0	0	0	0	1	1	3
	CDH74	126	38	36	24	1	0	0	0	0	0	2	8	17
	CDH80	11	4	4	1	0	0	0	0	0	0	0	2	
Wind	WSAvg	22.1	20.6	18.6	19.7	21.1	23.9	20.9	22.2	24.4	24.8	24.1	21.7	22.8
Precipitation	PrecAvg	54.2	3.4	3.1	3.5	4.7	5.0	5.2	5.9	5.5	5.1	4.6	3.9	3.9
	PrecMax	76.0	7.6	6.8	6.5	10.6	9.8	10.0	13.0	10.0	10.9	8.3	7.6	10.7
	PrecMin	35.1	0.5	0.7	1.2	1.6	1.8	0.9	2.6	2.0	1.6	1.8	0.7	0.9
	PrecStd	10.6	1.5	1.5	1.3	2.0	2.1	1.8	2.3	1.9	1.9	1.7	1.5	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	78.7	80.3	77.4	71.3	65.7	60.4	57.7	60.9	66.3	71.9	74.7	76.2
		MCWB	61.6	61.9	59.7	57.2	54.2	52.5	49.6	50.6	52.3	55.6	56.9	59.1
	2%	DB	72.7	73.0	70.5	65.7	61.5	57.5	55.4	57.5	60.4	65.3	67.7	69.8
		MCWB	60.7	61.6	59.1	55.6	53.5	50.6	49.1	49.6	50.4	53.5	56.0	57.9
	5%	DB	67.7	68.1	66.0	62.4	59.0	55.5	53.9	55.0	57.3	60.4	62.7	64.9
		MCWB	59.1	60.0	58.2	54.9	53.1	50.3	49.0	49.2	49.9	52.4	54.6	57.5
	10%	DB	63.9	64.6	62.6	59.6	56.7	54.0	52.8	53.0	54.4	56.6	58.6	61.0
		MCWB	58.0	58.6	57.6	54.5	52.5	49.7	48.5	48.6	49.2	51.6	53.3	55.7
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	64.9	65.1	63.3	59.6	57.1	54.8	53.0	53.3	54.4	57.7	59.9	62.3
		MCDB	72.5	73.3	69.4	65.0	59.9	57.2	54.5	56.2	60.1	66.0	68.0	68.0
	2%	WB	61.8	62.7	61.1	57.8	55.6	52.9	51.3	51.3	52.5	55.4	57.3	59.4
		MCDB	68.9	69.7	66.2	62.1	58.6	55.5	53.5	54.6	56.6	61.3	64.6	66.7
	5%	WB	60.0	61.0	59.5	56.3	54.3	51.6	50.2	50.2	51.1	53.5	55.5	57.6
		MCDB	66.6	66.9	64.3	60.4	57.5	54.0	52.6	53.3	55.1	58.9	60.7	63.7
	10%	WB	58.3	59.4	57.8	54.9	53.0	50.6	49.3	49.2	49.9	51.8	53.8	55.9
		MCDB	63.4	64.1	62.4	58.9	56.2	53.2	51.8	52.3	53.8	55.9	58.1	60.5
Mean Daily Temperature Range	5% DB	MDBR	8.6	8.0	7.3	6.4	5.3	4.9	5.0	5.7	6.7	7.4	7.6	7.8
		MCDBR	17.0	14.9	13.9	11.4	8.4	6.5	6.3	8.7	11.5	14.7	15.9	15.3
		MCWBR	8.5	7.6	7.4	6.4	5.7	5.1	5.1	5.6	6.5	7.5	7.8	8.2
	5% WB	MCDBR	14.7	12.5	10.9	9.1	6.7	5.3	5.2	6.9	9.0	12.1	12.9	13.2
MCWBR		8.5	7.6	7.0	6.3	5.8	5.1	5.4	5.6	6.6	7.4	7.9	7.9	
Clear-Sky Solar Irradiance	taub		0.341	0.333	0.335	0.317	0.314	0.302	0.308	0.319	0.345	0.339	0.334	0.336
	taud		2.547	2.576	2.568	2.598	2.580	2.593	2.579	2.562	2.471	2.507	2.537	2.550
	Ebn at Noon		312	305	290	272	248	240	248	267	281	300	312	316
	Edh at Noon		33	31	28	23	20	18	19	23	30	33	34	34
All-Sky Solar Radiation	RadAvg		1941	1669	1188	788	470	373	432	655	1004	1459	1799	1963
	RadStd		125	144	73	46	37	33	33	45	49	76	135	120

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only		+0.90	+0.81	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (20 neighbors)		+0.63	N/A	N/A	N/A	N/A	N/A	N/A	-185	+194	+22

Nomenclature: See separate page