

HOBART ELLERSLIE ROAD, AustraliaWMO: **949700**Lat: **42.8899S**Lon: **147.3276E**Elev: **51**StdP: **100.71**Time Zone: **10.00 (AUS)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	2.5	3.4	-2.5	3.1	10.2	-1.5	3.4	9.4	13.6	12.9	12.1	12.8	3.7	330	0.586

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	8.6	28.5	17.0	25.8	16.5	23.8	15.7	18.7	24.8	17.8	23.3	16.9	21.9	6.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
16.9	12.1	20.4	15.9	11.3	19.6	14.8	10.6	19.0	53.5	24.9	50.5	23.5	47.8	21.9	23.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
11.4	10.0	8.9	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
			0.9	35.5	0.8	2.4	0.3	37.2	-0.1	38.6	-0.5	40.0	-1.1	41.8
			0.3	20.9	0.6	1.0	-0.1	21.6	-0.5	22.2	-0.9	22.7	-1.3	23.4
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.9	17.2	17.1	15.8	13.3	11.3	9.1	8.9	9.5	10.9	12.4	14.0	15.7
	DBStd	4.00	3.14	3.07	2.95	2.73	2.52	2.25	1.98	2.31	2.57	2.97	3.12	3.04
	HDD10.0	172	0	0	0	3	14	43	47	37	18	7	2	0
	HDD18.3	2057	61	56	90	153	218	277	294	272	222	185	136	94
	CDD10.0	1236	222	198	180	102	54	17	12	23	46	83	123	177
	CDD18.3	79	24	20	12	2	0	0	0	0	0	3	7	12
	CDH23.3	587	180	133	79	9	0	0	0	0	2	26	59	98
(13)	CDH26.7	179	59	41	23	1	0	0	0	0	0	5	16	34
(14) Wind	WSAvg	4.5	4.6	4.3	4.2	4.2	4.4	4.2	4.4	4.6	4.8	4.7	4.6	4.7
(15) Precipitation	PrecAvg	589	43	40	41	49	42	40	54	61	52	57	52	54
	PrecMax	828	104	171	120	248	99	85	157	148	133	149	127	206
	PrecMin	390	8	3	5	6	5	2	9	9	14	9	2	0
	PrecStd	116	28	37	28	43	26	21	34	33	29	33	27	47
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.8	31.7	29.4	24.6	20.5	16.7	16.1	18.6	21.9	26.6	28.9	31.1
		MCWB	18.4	18.5	17.4	15.0	13.1	11.5	10.2	11.1	13.0	13.7	15.8	16.8
	2%	DB	27.5	27.0	25.2	21.7	18.2	15.2	14.6	16.5	18.8	22.5	24.5	25.7
		MCWB	17.4	17.4	16.4	14.2	12.1	10.6	9.6	10.3	11.5	13.3	15.1	16.2
	5%	DB	24.7	24.3	22.6	19.6	16.7	14.1	13.5	15.0	17.1	19.6	21.5	22.9
		MCWB	16.5	16.8	15.6	13.3	11.5	9.9	9.1	9.6	10.7	12.5	14.1	15.2
	10%	DB	22.5	22.2	20.6	17.9	15.4	13.0	12.4	13.7	15.5	17.5	19.1	20.8
		MCWB	15.4	16.0	14.9	12.8	10.9	9.3	8.6	9.1	10.0	11.6	13.1	14.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	20.2	19.1	16.5	14.4	13.2	11.4	12.1	14.1	15.9	17.8	18.8
		MCDB	27.2	25.9	24.1	21.6	17.5	14.6	13.8	15.5	19.5	20.9	24.4	25.5
	2%	WB	18.6	18.8	17.7	15.2	13.2	11.2	10.2	11.0	12.5	14.5	16.2	17.3
		MCDB	25.1	24.8	22.4	19.1	16.6	14.0	13.4	15.3	16.8	20.0	22.2	22.7
	5%	WB	17.4	17.8	16.7	14.1	12.3	10.4	9.5	10.1	11.4	13.3	15.0	16.2
		MCDB	23.0	23.0	21.2	18.2	15.7	13.2	12.7	14.1	15.7	18.6	20.2	21.3
	10%	WB	16.4	16.8	15.7	13.2	11.4	9.6	8.9	9.4	10.6	12.2	13.8	15.2
		MCDB	21.3	21.3	20.0	17.3	14.8	12.5	12.1	13.3	14.8	16.8	18.1	20.0
(35) Mean Daily Temperature Range	5% DB	MDBR	8.6	8.3	8.0	7.6	6.5	6.0	6.2	7.0	7.8	8.3	8.2	8.5
		MCDBR	13.2	11.9	11.6	10.1	7.9	7.0	7.2	8.6	10.1	12.1	12.5	12.2
		MCWBR	5.7	5.2	5.1	4.8	4.5	4.2	4.2	4.5	5.1	5.8	5.8	5.5
	5% WB	MCDBR	11.4	10.3	9.6	9.0	7.1	6.2	6.5	7.8	8.9	10.7	10.8	10.6
		MCWBR	5.8	5.4	4.8	4.9	4.5	4.1	4.2	4.5	5.3	5.7	5.8	5.6
(40) Clear-Sky Solar Irradiance	taub		0.343	0.331	0.330	0.311	0.304	0.292	0.293	0.305	0.325	0.329	0.332	0.337
	taud		2.517	2.573	2.567	2.599	2.595	2.610	2.609	2.582	2.511	2.518	2.532	2.527
	Ebn at Noon		982	968	922	871	804	781	809	864	911	959	988	994
	Edh at Noon		109	98	89	74	62	56	60	73	93	102	107	109
(44) All-Sky Solar Radiation	RadAvg		6.50	5.54	4.13	2.80	1.72	1.37	1.58	2.35	3.54	4.94	5.87	6.52
	RadStd		0.49	0.30	0.23	0.16	0.11	0.11	0.07	0.16	0.17	0.27	0.46	0.37

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		+0.45	N/A	N/A	N/A	N/A	+0.50	-31	-166	+151
(47) Regional (29 neighbors)		+0.32	N/A	N/A	+0.68	N/A	N/A	-100	+106	+14

Nomenclature: See separate page