

CAPE SORELL, Australia

WMO: 949740

Lat: 42.199S

Lon: 145.170E

Elev: 64

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a) 7	(b) 40.4	(c) 42.1	(d) 34.8	(e) 29.7	(f) 44.5	(g) 36.3	(h) 31.5	(i) 45.5	(j) 46.1	(k) 50.7	(l) 42.8	(m) 51.8	(n) 10.2	(o) 90	(p) 0.732

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 2	(b) 10.9	(c) 73.2	(d) 63.9	(e) 70.9	(f) 62.5	(g) 68.8	(h) 61.4	(i) 65.2	(j) 71.6	(k) 63.9	(l) 69.7	(m) 62.7	(n) 68.1	(o) 14.9	(p) 20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
62.7	85.3	67.1	61.4	81.4	66.3	60.3	78.4	65.7	30.2	71.8	29.2	69.8	28.4	68.4	73.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 40.6	(b) 35.5	(c) 31.9	(e) 38.1	(f) 79.2	(g) 1.3	(h) 3.6	(i) 37.1	(j) 81.8	(k) 36.3	(l) 83.9	(m) 35.6	(n) 85.9	(o) 34.6	(p) 88.5		
(4) 40.6	(5) 35.5	(6) 31.9	(7) N/A	(8) N/A	(9) N/A	(10) N/A	(11) N/A	(12) N/A	(13) N/A	(14) N/A	(15) N/A	(16) N/A	(17) N/A	(18) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	54.9	60.3	60.6	58.9	55.9	53.3	51.1	49.9	50.2	51.8	53.4	55.5	58.0		
	DBStd	5.12	3.74	3.88	3.82	3.61	3.43	3.18	2.98	3.13	3.13	3.45	3.96	3.92		
	HDD50	134	0	0	0	2	9	24	39	36	16	6	2	0		
	HDD65	3724	154	133	192	273	363	417	469	459	397	359	286	222		
	CDD50	1913	319	297	278	179	111	57	35	42	69	112	167	247		
	CDD65	28	8	10	4	1	0	0	0	0	0	0	1	4		
	CDH74	46	20	11	8	0	0	0	0	0	0	0	1	6		
	CDH80	3	2	0	1	0	0	0	0	0	0	0	0	0		
(14) Wind	WSAvg	15.6	14.1	13.5	13.7	14.8	15.9	16.1	17.3	17.6	17.5	16.5	15.1	15.2		
(15) Precipitation	PrecAvg	54.6	3.0	2.8	4.0	4.0	5.3	5.8	6.5	6.7	5.7	4.4	3.3	3.7		
	PrecMax	72.1	6.0	7.3	6.7	6.9	11.0	12.0	12.0	12.0	11.2	8.0	5.8	7.3		
	PrecMin	43.0	0.9	1.0	1.9	1.1	1.0	2.2	3.5	2.7	1.6	0.3	0.4	1.9		
	PrecStd	6.1	1.4	1.4	1.2	1.6	2.5	2.7	1.8	2.6	2.0	1.8	1.5	1.2		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	76.4	75.5	74.1	69.3	63.5	60.0	57.7	60.8	63.9	68.3	72.0	74.6		
		MCWB	64.9	64.8	64.5	60.9	56.8	54.4	52.4	54.3	55.7	57.9	62.0	63.6		
	2%	DB	72.5	72.7	70.7	66.2	61.4	58.2	56.4	58.3	60.8	64.7	68.0	70.5		
		MCWB	63.3	64.6	63.4	59.1	56.2	53.8	51.9	52.3	54.0	56.6	59.8	62.2		
	5%	DB	69.8	70.3	68.0	64.1	59.9	57.0	55.5	56.4	58.7	62.2	65.2	67.8		
		MCWB	62.3	62.8	61.8	58.2	55.8	53.0	51.7	51.4	53.3	55.2	58.3	60.9		
	10%	DB	67.3	67.9	65.5	62.1	58.5	56.0	54.4	54.9	56.9	59.5	62.6	65.2		
		MCWB	60.6	61.0	60.2	57.4	55.0	52.5	50.8	50.7	52.4	53.7	57.0	59.2		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.5	66.3	65.9	62.9	59.0	56.2	54.6	54.8	56.7	60.0	64.4	66.4		
		MCDB	73.7	72.8	74.4	67.5	60.2	58.0	55.9	59.6	61.7	66.5	71.6	72.3		
	2%	WB	64.9	64.6	64.1	60.9	57.9	55.0	53.2	53.1	55.6	57.7	62.0	63.4		
		MCDB	71.5	70.1	70.0	65.0	60.0	57.0	55.6	57.1	59.7	63.8	68.3	69.3		
	5%	WB	63.5	63.3	62.9	59.8	56.7	54.2	52.2	52.0	54.3	56.2	59.3	61.8		
		MCDB	69.9	68.0	68.0	64.4	59.4	56.6	54.8	55.2	58.3	61.5	65.1	67.1		
	10%	WB	61.8	62.1	61.3	58.7	55.6	53.3	51.2	51.1	53.3	54.8	57.4	60.2		
		MCDB	67.7	66.2	65.5	63.6	58.6	56.0	54.0	54.2	57.2	59.4	62.4	64.8		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	10.9	9.9	8.8	6.8	6.5	6.8	7.4	8.2	9.5	10.3	10.4		
		MCDBR	14.9	14.1	13.6	12.0	7.9	6.7	7.1	8.8	10.7	13.5	14.5	14.6		
	5% WB	MCWBR	8.8	8.8	8.1	7.0	5.5	5.4	5.3	6.5	6.4	8.3	7.8	8.8		
		MCWBR	14.2	11.7	11.8	10.0	6.4	5.2	6.1	7.6	8.5	12.0	12.2	12.2		
(40) Clear-Sky Solar Irradiance	taub		0.344	0.341	0.328	0.317	0.315	0.319	0.306	0.335	0.349	0.341	0.338	0.338		
	taud		2.543	2.559	2.607	2.612	2.592	2.548	2.605	2.510	2.467	2.508	2.538	2.553		
	Ebn at Noon		312	304	294	275	252	237	253	263	281	300	312	315		
	Edh at Noon		34	32	28	23	20	19	20	25	31	33	34	34		
(44) All-Sky Solar Radiation	RadAvg		2011	1774	1278	868	518	412	464	694	1032	1501	1871	2005		
	RadStd		136	132	83	62	43	37	38	56	59	95	146	144		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.59	N/A	N/A	N/A	N/A	N/A	N/A	-187	+173	N/A
(47) Regional (26 neighbors)		+0.54	N/A	N/A	+1.15	+0.63	+0.77	N/A	-171	+180	+20

Nomenclature: See separate page