

CAPE SORELL, Australia

WMO: 949740

Lat: 42.199S

Lon: 145.170E

Elev: 20

StdP: 101.09

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	4.7	5.6	1.6	4.2	6.9	2.4	4.5	7.5	20.6	10.4	19.1	11.0	4.5	90	0.732

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.0	22.9	17.7	21.6	17.0	20.5	16.3	18.4	22.0	17.7	20.9	17.1	20.0	6.7	20

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
17.0	12.2	19.5	16.3	11.6	19.1	15.7	11.2	18.7	52.3	22.1	50.1	21.0	48.2	20.2	23.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.2	15.9	14.3	DB	3.4	26.2	0.7	2.0	2.8	27.6	2.4	28.8	2.0	29.9	1.5	31.4	(4)
(5)			WB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	12.7	15.7	15.9	15.0	13.3	11.8	10.6	9.9	10.1	11.0	11.9	13.1	14.4	(6)	
	DBStd	2.84	2.08	2.15	2.12	2.01	1.90	1.77	1.66	1.74	1.74	1.91	2.20	2.18	(7)	
	HDD10.0	74	0	0	0	1	5	13	22	20	9	3	1	0	(8)	
	HDD18.3	2069	86	74	107	152	202	232	261	255	221	199	159	123	(9)	
	CDD10.0	1063	177	165	154	99	62	32	19	23	38	62	93	137	(10)	
	CDD18.3	16	4	6	2	1	0	0	0	0	0	0	1	2	(11)	
	CDH23.3	26	11	6	4	0	0	0	0	0	0	0	1	3	(12)	
	CDH26.7	2	1	0	1	0	0	0	0	0	0	0	0	0	(13)	
(14) Wind	WSAvg	7.0	6.3	6.0	6.1	6.6	7.1	7.2	7.8	7.9	7.8	7.4	6.7	6.8	(14)	
(15) Precipitation	PrecAvg	1386	76	70	101	102	135	148	165	171	145	113	84	93	(15)	
	PrecMax	1831	153	186	169	175	280	306	306	304	285	204	147	185	(16)	
	PrecMin	1091	23	26	49	27	26	55	90	69	41	8	10	47	(17)	
	PrecStd	154	36	35	30	40	64	69	46	66	52	45	39	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	24.7	24.2	23.4	20.7	17.5	15.6	14.3	16.0	17.7	20.2	22.2	23.7	(19)	
		MCWB	18.3	18.2	18.1	16.1	13.8	12.5	11.3	12.4	13.2	14.4	16.7	17.6	(20)	
	2%	DB	22.5	22.6	21.5	19.0	16.3	14.6	13.6	14.6	16.0	18.1	20.0	21.4	(21)	
		MCWB	17.4	18.1	17.4	15.1	13.5	12.1	11.1	11.3	12.2	13.7	15.4	16.8	(22)	
	5%	DB	21.0	21.3	20.0	17.8	15.5	13.9	13.0	13.6	14.8	16.8	18.4	19.9	(23)	
		MCWB	16.8	17.1	16.5	14.6	13.2	11.7	10.9	10.8	11.8	12.9	14.6	16.1	(24)	
	10%	DB	19.6	19.9	18.6	16.7	14.7	13.3	12.5	12.7	13.8	15.3	17.0	18.4	(25)	
		MCWB	15.9	16.1	15.7	14.1	12.8	11.4	10.4	10.4	11.4	12.0	13.9	15.1	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	20.3	19.0	18.8	17.2	15.0	13.4	12.5	12.7	13.7	15.6	18.0	19.1	(27)	
		MCDB	23.2	22.6	23.5	19.7	15.7	14.4	13.3	15.4	16.5	19.2	22.0	22.4	(28)	
	2%	WB	18.3	18.1	17.8	16.1	14.4	12.8	11.8	11.7	13.1	14.3	16.7	17.5	(29)	
		MCDB	21.9	21.1	21.1	18.3	15.6	13.9	13.1	14.0	15.4	17.7	20.2	20.7	(30)	
	5%	WB	17.5	17.4	17.1	15.4	13.7	12.3	11.2	11.1	12.4	13.4	15.2	16.6	(31)	
		MCDB	21.1	20.0	20.0	18.0	15.2	13.7	12.7	12.9	14.6	16.4	18.4	19.5	(32)	
	10%	WB	16.6	16.7	16.3	14.8	13.1	11.8	10.7	10.6	11.8	12.7	14.1	15.7	(33)	
		MCDB	19.8	19.0	18.6	17.6	14.8	13.4	12.2	12.3	14.0	15.2	16.9	18.2	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	6.0	6.0	5.5	4.9	3.8	3.6	3.8	4.1	4.6	5.3	5.7	5.8	(35)	
		MCDBR	8.3	7.8	7.5	6.7	4.4	3.7	3.9	4.9	6.0	7.5	8.0	8.1	(36)	
	5% WB	MCWBR	4.9	4.9	4.5	3.9	3.1	3.0	3.0	3.6	3.5	4.6	4.3	4.9	(37)	
		MCWBR	7.9	6.5	6.6	5.5	3.5	2.9	3.4	4.2	4.7	6.7	6.8	6.8	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.344	0.341	0.328	0.317	0.315	0.319	0.306	0.335	0.349	0.341	0.338	0.338	(40)	
		taud	2.543	2.559	2.607	2.612	2.592	2.548	2.605	2.510	2.467	2.508	2.538	2.553	(41)	
	Ebn at Noon		982	958	928	868	796	748	799	830	887	947	983	994	(42)	
		Edh at Noon	106	100	87	74	64	61	62	80	98	104	106	107	(43)	
(44) All-Sky Solar Radiation	RadAvg		6.34	5.59	4.03	2.74	1.63	1.30	1.46	2.19	3.25	4.73	5.90	6.32	(44)	
	RadStd		0.43	0.42	0.26	0.20	0.14	0.12	0.12	0.18	0.19	0.30	0.46	0.45	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+0.33	N/A	N/A	N/A	N/A	N/A	N/A	-104	+96	N/A
(47) Regional (26 neighbors)		+0.30	N/A	N/A	+0.64	+0.35	+0.43	N/A	-95	+100	+11

Nomenclature: See separate page