

EDDYSTONE POINT, Australia

WMO: 949830

Lat: 40.9928S

Lon: 148.3467E

Elev: 69

StdP: 14.66

Time Zone: 10.00 (AUS)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	39.9	41.5	29.8	23.9	44.8	31.8	26.3	45.6	41.3	52.8	38.0	54.1	11.8	270	0.719

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	11.9	75.4	65.2	73.0	64.1	71.1	62.9	67.7	72.5	66.4	70.4	65.3	69.0	15.8	300

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
66.1	96.6	69.4	64.8	92.2	68.3	63.8	88.7	67.5	32.2	72.5	31.1	70.6	30.2	69.0	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 36.8	32.2	28.9	DB	36.1	85.6	1.8	5.2	34.9	89.4	33.8	92.5	32.9	95.4	31.6	99.2	(4)
(5)			WB	32.8	70.3	1.5	1.8	31.7	71.6	30.9	72.7	30.0	73.7	28.9	75.0	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	57.0	63.8	64.6	62.8	58.7	54.9	52.0	50.6	50.8	52.7	55.2	57.9	60.8
	DBStd	6.00	3.82	3.85	3.98	3.75	3.44	3.08	2.79	2.99	3.11	3.51	3.81	3.75
	HDD50	84	0	0	0	0	4	14	26	27	10	2	1	0
	HDD65	3015	67	49	91	191	312	390	446	441	369	306	214	139
	CDD50	2650	429	409	396	261	157	74	46	51	91	162	239	335
	CDD65	106	31	38	22	2	0	0	0	0	0	1	3	9
	CDH74	180	64	54	25	1	0	0	0	0	0	5	8	23
	CDH80	30	12	10	3	0	0	0	0	0	0	0	1	4
Wind	WSAvg	15.2	15.5	14.8	14.6	14.5	15.1	15.0	14.7	15.5	15.6	15.8	15.3	15.6
Precipitation	PrecAvg	31.7	2.1	1.7	2.3	2.8	2.9	2.5	3.4	3.0	2.8	2.4	2.6	2.7
	PrecMax	42.7	6.5	5.5	6.0	12.2	9.7	5.2	7.0	7.7	5.7	6.7	5.9	6.9
	PrecMin	13.0	0.2	0.1	0.2	0.2	0.6	0.9	0.5	0.5	0.6	0.2	0.4	0.1
	PrecStd	6.1	1.5	1.4	1.5	2.3	1.9	1.2	1.6	1.7	1.3	1.4	1.4	1.8
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.9	79.4	76.9	71.8	66.1	61.9	59.9	61.2	65.3	70.7	73.5	76.6
		MCWB	65.8	67.4	66.5	63.0	59.0	56.3	53.7	54.2	55.7	58.4	63.5	63.9
	2%	DB	74.8	74.9	73.0	68.4	63.7	60.0	58.2	59.2	62.2	65.5	69.1	71.8
		MCWB	64.5	66.0	64.9	61.1	57.6	55.3	52.7	53.0	54.5	56.9	60.8	62.0
	5%	DB	72.2	72.5	70.8	66.5	62.1	58.5	56.9	57.5	60.2	63.0	66.4	69.3
		MCWB	63.2	64.5	63.4	60.0	56.9	54.1	51.9	52.0	53.5	55.7	59.0	60.9
	10%	DB	70.1	70.5	68.8	64.7	60.7	57.2	55.7	56.2	58.4	61.2	64.3	67.4
		MCWB	62.3	63.3	62.2	58.9	56.2	53.3	51.3	51.4	52.5	54.7	57.5	59.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	68.9	69.6	69.5	65.0	61.4	59.0	55.6	56.3	57.8	60.4	64.8	66.5
		MCDB	74.1	75.0	74.2	68.4	63.5	60.5	57.8	58.8	61.7	65.9	69.6	72.4
	2%	WB	66.8	68.0	67.1	63.2	59.7	56.7	54.1	54.7	56.3	58.8	62.3	64.5
		MCDB	71.8	72.7	70.9	66.4	62.0	58.5	56.5	57.2	59.8	63.0	67.2	69.5
	5%	WB	65.6	66.6	65.6	61.9	58.4	55.4	53.2	53.5	55.0	57.5	60.5	63.1
		MCDB	69.9	70.4	68.8	65.0	61.0	57.4	55.8	56.3	58.5	61.2	64.8	67.1
	10%	WB	64.3	65.5	64.1	60.4	56.9	54.1	52.2	52.5	53.8	56.2	59.0	61.7
		MCDB	67.9	68.9	67.4	63.7	60.1	56.5	55.0	55.5	57.4	60.1	62.7	65.5
Mean Daily Temperature Range	5% DB	MDBR	12.5	11.9	12.2	11.6	10.7	9.7	10.3	11.2	12.2	12.8	12.5	13.1
		MCDBR	16.0	14.3	13.7	13.2	11.9	10.5	11.0	12.0	14.0	14.9	15.4	15.7
		MCWBR	8.6	7.9	8.0	8.2	8.1	7.3	7.5	8.1	8.8	8.9	8.8	9.1
	5% WB	MCDBR	13.4	12.5	11.8	11.4	9.9	8.4	9.3	10.1	11.9	13.1	13.4	14.1
		MCWBR	8.2	7.7	7.8	8.0	7.6	6.5	7.0	7.4	8.3	8.5	8.5	9.0
Clear-Sky Solar Irradiance	taub	0.352	0.347	0.337	0.321	0.307	0.301	0.298	0.312	0.331	0.338	0.355	0.345	
	taud	2.517	2.549	2.570	2.595	2.601	2.607	2.622	2.580	2.516	2.509	2.479	2.524	
	Ebn at Noon	310	303	292	276	259	250	260	275	289	303	307	313	
	Edh at Noon	35	32	29	24	21	19	20	24	30	33	36	35	
All-Sky Solar Radiation	RadAvg	2121	1806	1441	987	667	527	598	869	1276	1676	1951	2199	
	RadStd	138	95	73	51	36	39	24	57	86	80	125	126	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (15 neighbors)	+0.56	N/A	N/A	+1.30	+0.74	N/A	N/A	-140	+167	+25

Nomenclature: See separate page